

LEFKOSA, Cyprus

WMO: 175150

Lat: 35.200N

Lon: 33.350E

Elev: 430

StdP: 14.47

Time Zone: 2.00 (EUE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.5	37.3	20.9	15.9	51.2	24.2	18.6	52.5	23.9	49.7	20.6	53.1	1.0	210	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	25.9	102.2	67.7	100.0	67.6	98.0	67.4	75.4	85.7	74.4	84.9	73.3	84.2	8.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.7	123.0	80.7	71.5	118.0	80.0	70.1	112.6	79.6	39.2	86.0	38.3	84.7	37.3	84.0	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	17.1	14.8	DB	29.3	107.4	2.6	3.3	27.4	109.7	25.9	111.7	24.4	113.5	22.6	115.9	(4)
(5)			WB	27.6	78.3	2.6	2.1	25.7	79.8	24.2	81.0	22.7	82.2	20.8	83.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	50.2	51.8	56.4	64.0	71.7	79.9	85.2	85.5	79.5	71.3	61.3	53.6		
	DBStd	13.29	4.31	4.50	4.57	5.28	5.37	5.17	3.47	2.95	3.82	4.39	4.57	4.26		
	HDD50	105	50	30	7	0	0	0	0	0	0	0	0	18		
	HDD65	1669	459	369	269	80	6	0	0	0	0	5	127	354		
	CDD50	6537	55	81	205	421	671	898	1092	1101	885	660	339	129		
	CDD65	2629	0	0	2	51	213	448	627	636	435	200	17	0		
	CDH74	31049	0	7	55	709	2202	5229	8245	8231	4535	1636	194	6		
	CDH80	16367	0	0	7	220	934	2830	4832	4724	2261	537	22	0		
(14) Wind	WSAvg	5.2	4.0	4.5	5.4	5.7	6.1	6.9	6.6	6.0	5.5	4.5	3.5	3.7		
(15) Precipitation	PrecAvg	12.6	2.0	2.0	1.5	0.9	0.9	0.2	0.1	0.2	0.3	0.8	1.3	2.3		
	PrecMax	19.7	5.4	4.9	4.0	3.2	4.4	2.1	1.1	2.5	2.8	4.8	5.0	5.7		
	PrecMin	7.5	0.6	0.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3		
	PrecStd	3.0	1.1	1.3	1.1	0.9	1.2	0.5	0.2	0.6	0.6	1.0	1.1	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.3	72.9	79.4	90.6	98.2	103.8	106.0	104.5	101.6	92.3	82.9	71.7		
		MCWB	55.1	56.1	57.6	59.7	62.9	66.4	67.7	68.8	67.1	62.9	60.5	56.1		
	2%	DB	64.0	67.8	74.6	85.6	93.7	100.0	102.2	101.4	97.2	88.8	79.1	68.6		
		MCWB	53.6	55.2	55.3	58.8	62.4	66.4	67.7	68.3	66.5	63.2	59.6	56.2		
	5%	DB	62.2	64.8	71.4	82.2	89.5	96.8	99.9	99.6	94.3	85.7	75.8	66.1		
		MCWB	52.8	53.9	55.3	58.0	62.2	65.6	67.7	68.0	66.8	63.0	59.3	55.5		
	10%	DB	60.0	62.3	68.1	77.9	85.4	93.5	97.8	97.6	91.5	82.7	72.9	63.8		
		MCWB	51.6	52.9	54.3	57.5	61.7	65.7	68.0	68.4	67.3	62.8	57.9	54.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.3	58.7	60.3	63.6	67.9	73.8	76.5	77.3	74.7	69.4	65.2	60.2		
		MCDB	64.0	67.4	72.5	79.5	81.1	86.1	88.1	88.2	84.2	80.6	75.2	66.7		
	2%	WB	55.2	56.9	58.5	61.5	66.1	71.9	74.9	75.9	72.8	67.8	63.1	58.4		
		MCDB	62.0	65.1	69.3	76.9	79.6	84.4	86.5	85.7	82.6	78.5	73.4	65.3		
	5%	WB	53.9	55.3	56.9	60.3	64.9	70.4	73.8	74.9	71.8	66.8	61.2	56.8		
		MCDB	60.4	63.3	66.7	74.4	78.5	83.8	85.3	84.8	82.0	77.4	71.4	64.1		
	10%	WB	52.4	53.8	55.6	59.1	63.8	69.0	72.8	74.0	70.8	65.7	59.6	55.2		
		MCDB	58.8	61.0	65.2	72.1	77.6	83.0	84.6	84.2	81.8	76.5	69.7	62.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.4	20.1	22.7	25.4	25.0	25.0	26.0	25.9	24.6	22.6	22.3	19.4		
		MCDBR	21.1	23.5	28.0	31.6	30.6	28.1	28.0	27.7	28.6	25.9	26.0	23.3		
		MCWBR	12.7	13.5	13.6	11.9	9.8	9.4	9.9	9.9	10.0	9.5	12.2	13.4		
		MCDBR	19.3	21.8	24.8	27.6	26.0	26.8	26.8	26.6	26.9	23.3	23.5	20.3		
	5% WB	MCWBR	12.4	13.5	12.9	11.3	9.1	9.5	9.5	9.2	9.5	9.2	11.8	12.5		
(40) Clear-Sky Solar Irradiance	taub		0.365	0.390	0.422	0.462	0.452	0.411	0.427	0.436	0.408	0.405	0.378	0.362		
	taud		2.358	2.266	2.169	2.075	2.165	2.333	2.296	2.264	2.346	2.329	2.362	2.390		
	Ebn at Noon		261	267	268	262	266	277	272	267	270	259	254	254		
	Edh at Noon		30	37	45	51	48	40	42	42	37	35	30	28		
(44) All-Sky Solar Radiation	RadAvg		789	1079	1531	1918	2228	2482	2416	2162	1840	1355	963	722		
	RadStd		59	93	81	94	108	50	46	36	54	66	56	64		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page