

NICOSIA ERCAN, Cyprus

WMO: 175210

Lat: 35.150N

Lon: 33.500E

Elev: 390

StdP: 14.49

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.8	38.9	24.4	18.8	49.9	27.6	21.8	50.7	25.3	53.7	22.5	53.7	7.0	250	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.0	102.3	70.1	100.3	69.9	98.4	69.9	77.1	89.8	75.8	87.9	74.8	86.8	9.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	127.7	81.0	73.0	124.5	80.8	71.6	118.3	80.1	40.8	89.5	39.6	87.8	38.6	86.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.7	18.9	16.9	DB	30.7	106.7	2.8	2.6	28.7	108.5	27.0	110.0	25.4	111.5	23.4	113.4	(4)
(5)			WB	28.9	79.5	2.8	2.5	26.8	81.2	25.2	82.7	23.6	84.1	21.6	85.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.2	51.0	52.5	57.3	63.8	72.2	80.3	85.7	85.5	79.8	71.8	62.3	54.6	(6)
(7)		DBStd	13.08	4.11	4.48	4.52	5.21	5.31	4.92	3.37	2.74	3.66	4.52	5.07	4.25	(7)
(8)		HDD50	81	37	25	5	0	0	0	0	0	0	0	1	13	(8)
(9)		HDD65	1552	434	351	243	83	4	0	0	0	0	6	108	323	(9)
(10)		CDD50	6707	68	95	229	414	688	910	1108	1101	894	676	369	155	(10)
(11)		CDD65	2705	0	0	3	47	227	460	643	636	444	218	27	0	(11)
(12)		CDH74	33100	0	4	70	659	2490	5697	8828	8434	4862	1818	233	5	(12)
(13)		CDH80	17895	0	0	10	191	1077	3176	5354	4936	2499	621	31	0	(13)
(14)	Wind	WSAvg	8.2	7.4	7.4	8.1	8.4	8.8	9.2	9.0	8.8	8.7	7.9	7.4	7.0	(14)
(15)	Precipitation	PrecAvg	16.0	3.0	2.5	1.4	0.9	1.1	0.4	0.2	0.1	0.3	1.0	1.9	3.3	(15)
(16)		PrecMax	24.9	9.3	6.3	4.5	2.6	3.1	1.9	1.1	0.5	1.5	3.4	7.0	8.8	(16)
(17)		PrecMin	7.9	0.8	0.6	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.1	0.0	0.5	(17)
(18)		PrecStd	4.2	1.9	1.5	0.9	0.6	0.8	0.5	0.3	0.1	0.4	0.8	1.5	2.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	73.2	80.7	91.0	98.4	104.1	107.2	104.3	100.6	92.9	83.8	71.9	(19)
(20)			MCWB	56.2	57.0	59.7	60.5	64.6	68.3	70.5	70.4	68.6	64.4	61.9	58.3	(20)
(21)		2%	DB	64.4	67.8	75.2	85.4	93.9	100.1	102.6	101.5	97.1	89.3	79.3	68.4	(21)
(22)			MCWB	55.2	56.4	57.7	60.4	64.2	68.1	70.8	70.5	68.3	65.3	61.3	57.2	(22)
(23)		5%	DB	62.5	64.8	71.8	81.2	89.9	97.0	100.5	99.5	94.8	86.1	76.6	66.3	(23)
(24)			MCWB	54.0	55.3	56.9	59.4	64.2	67.6	70.4	70.7	68.9	65.3	60.9	56.0	(24)
(25)		10%	DB	60.6	62.8	69.4	77.3	86.0	94.6	98.5	97.2	91.8	83.8	73.5	64.2	(25)
(26)			MCWB	53.0	54.2	56.4	59.2	63.3	67.7	70.5	71.1	68.9	64.8	59.7	55.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.2	60.2	63.0	65.2	69.3	74.6	78.8	79.0	75.6	71.5	67.0	61.2	(27)
(28)			MCD B	64.1	66.5	74.4	79.0	85.0	91.2	93.0	91.7	87.1	82.1	76.2	67.3	(28)
(29)		2%	WB	56.8	58.2	60.5	63.2	67.6	73.2	76.9	77.4	74.1	69.7	64.7	59.5	(29)
(30)			MCD B	62.0	65.4	69.6	77.6	82.5	87.6	91.3	89.2	85.4	79.8	74.0	65.7	(30)
(31)		5%	WB	55.2	56.6	58.9	61.7	66.5	72.0	75.6	76.4	73.0	68.4	62.9	57.9	(31)
(32)			MCD B	60.8	63.6	67.9	75.3	81.1	85.4	88.8	87.7	84.4	78.8	72.4	64.1	(32)
(33)		10%	WB	53.6	55.2	57.3	60.4	65.2	70.5	74.5	75.3	72.0	67.2	61.0	56.5	(33)
(34)			MCD B	59.5	61.5	66.5	73.1	79.9	84.3	87.6	86.3	83.4	77.7	70.2	62.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.0	19.9	23.2	24.9	25.3	25.8	26.0	25.4	24.8	22.5	21.0	18.4	(35)
(36)			MCDBR	20.5	22.4	27.1	30.0	29.7	28.3	28.3	27.3	28.1	25.2	24.0	21.4	(36)
(37)			MCWBR	13.0	13.7	14.1	12.5	10.5	10.0	10.1	10.2	10.9	10.5	11.4	12.6	(37)
(38)		5% WB	MCD BR	18.6	21.0	24.5	26.1	25.9	26.4	26.6	25.4	26.1	23.2	21.7	18.8	(38)
(39)			MCWBR	12.7	13.7	13.9	12.3	10.1	9.7	9.3	8.7	10.0	10.1	11.3	12.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.365	0.390	0.422	0.463	0.453	0.411	0.428	0.437	0.409	0.406	0.378	0.362	(40)	
(41)		taud	2.357	2.268	2.170	2.074	2.162	2.331	2.292	2.261	2.342	2.324	2.359	2.388	(41)	
(42)		Ebn at Noon	261	267	268	262	266	277	271	266	269	259	254	254	(42)	
(43)		Edh at Noon	31	37	45	52	48	40	42	42	37	35	30	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	794	1083	1533	1919	2230	2482	2417	2163	1844	1358	966	723	(44)	
(45)		RadStd	58	93	81	93	108	49	47	37	53	66	56	65	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.74	N/A	N/A	N/A	N/A	-1.62	N/A	N/A	N/A	N/A	(46)
(47)	Regional (12 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144	(47)

Nomenclature: See separate page