

NICOSIA ERCAN, Cyprus

WMO: 175210

Lat: 35.150N

Lon: 33.500E

Elev: 119

StdP: 99.90

Time Zone: 2.00 (EUE)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.1	3.8	-4.2	2.7	9.9	-2.5	3.1	10.4	11.3	12.0	10.1	12.0	3.1	250	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	39.1	21.2	37.9	21.1	36.9	21.1	25.1	32.1	24.3	31.1	23.8	30.4	4.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.2	27.2	22.8	17.8	27.1	22.0	16.9	26.7	77.1	31.9	74.3	31.0	71.9	30.3	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.5	7.5	DB	-0.7	41.5	1.6	1.4	-1.8	42.5	-2.8	43.3	-3.6	44.2	-4.8	45.2	(4)
			WB	-1.7	26.4	1.6	1.4	-2.9	27.4	-3.8	28.2	-4.7	28.9	-5.8	29.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	10.6	11.4	14.0	17.7	22.3	26.8	29.7	26.6	22.1	16.8	12.5	(6)	
(7)		DBStd	7.27	2.28	2.49	2.51	2.89	2.95	2.74	1.87	1.52	2.03	2.51	2.82	2.36	(7)
(8)		HDD10.0	45	21	14	3	0	0	0	0	0	0	0	1	7	(8)
(9)		HDD18.3	862	241	195	135	46	2	0	0	0	0	3	60	179	(9)
(10)		CDD10.0	3726	38	53	127	230	382	506	616	612	497	376	205	86	(10)
(11)		CDD18.3	1503	0	0	2	26	126	256	357	353	247	121	15	0	(11)
(12)		CDH23.3	18389	0	2	39	366	1383	3165	4904	4686	2701	1010	129	3	(12)
(13)		CDH26.7	9942	0	0	6	106	598	1764	2974	2742	1388	345	17	0	(13)
(14)	Wind	WSAvg	3.7	3.3	3.3	3.6	3.7	3.9	4.1	4.0	3.9	3.9	3.5	3.3	3.1	(14)
(15)	Precipitation	PrecAvg	407	77	64	35	22	29	9	4	2	7	25	48	84	(15)
(16)		PrecMax	632	235	160	115	65	78	47	27	13	38	86	179	223	(16)
(17)		PrecMin	200	20	15	0	1	4	0	0	0	0	3	0	12	(17)
(18)		PrecStd	106	47	38	22	15	20	12	7	3	10	21	39	54	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	22.9	27.0	32.8	36.9	40.1	41.8	40.2	38.1	33.8	28.8	22.2	(19)
(20)			MCWB	13.4	13.9	15.4	15.8	18.1	20.2	21.4	21.3	20.3	18.0	16.6	14.6	(20)
(21)		2%	DB	18.0	19.9	24.0	29.6	34.4	37.9	39.2	38.6	36.2	31.8	26.3	20.2	(21)
(22)			MCWB	12.9	13.6	14.3	15.8	17.9	20.1	21.5	21.4	20.2	18.5	16.3	14.0	(22)
(23)		5%	DB	17.0	18.2	22.1	27.3	32.2	36.1	38.0	37.5	34.9	30.1	24.8	19.1	(23)
(24)			MCWB	12.2	12.9	13.8	15.2	17.9	19.8	21.3	21.5	20.5	18.5	16.1	13.3	(24)
(25)		10%	DB	15.9	17.1	20.8	25.1	30.0	34.8	36.9	36.2	33.2	28.8	23.0	17.9	(25)
(26)			MCWB	11.7	12.4	13.5	15.1	17.4	19.8	21.4	21.7	20.5	18.2	15.4	13.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	15.7	17.2	18.4	20.7	23.7	26.0	26.1	24.2	21.9	19.4	16.2	(27)
(28)			MCD B	17.8	19.2	23.5	26.1	29.4	32.9	33.9	33.2	30.6	27.8	24.6	19.6	(28)
(29)		2%	WB	13.8	14.5	15.8	17.3	19.8	22.9	25.0	25.2	23.4	21.0	18.2	15.3	(29)
(30)			MCD B	16.7	18.6	20.9	25.3	28.0	30.9	32.9	31.8	29.7	26.5	23.4	18.7	(30)
(31)		5%	WB	12.9	13.7	15.0	16.5	19.2	22.2	24.2	24.6	22.8	20.2	17.2	14.4	(31)
(32)			MCD B	16.0	17.6	19.9	24.0	27.3	29.7	31.6	30.9	29.1	26.0	22.4	17.8	(32)
(33)		10%	WB	12.0	12.9	14.1	15.8	18.5	21.4	23.6	24.1	22.2	19.6	16.1	13.6	(33)
(34)			MCD B	15.3	16.4	19.1	22.8	26.6	29.0	30.9	30.2	28.5	25.4	21.2	17.0	(34)
(35)	Mean Daily Temperature Range	MDBR		10.0	11.0	12.9	13.8	14.0	14.3	14.5	14.1	13.8	12.5	11.7	10.2	(35)
(36)		5% DB	MCD BR	11.4	12.5	15.1	16.7	16.5	15.7	15.1	15.6	14.0	13.3	11.9	(36)	
(37)			MCWBR	7.2	7.6	7.8	6.9	5.8	5.5	5.6	6.0	5.8	6.3	7.0	(37)	
(38)		5% WB	MCD BR	10.3	11.7	13.6	14.5	14.4	14.7	14.8	14.1	14.5	12.9	12.0	10.4	(38)
(39)			MCWBR	7.0	7.6	7.7	6.8	5.6	5.4	5.2	4.9	5.6	6.3	6.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.365	0.390	0.422	0.463	0.453	0.411	0.428	0.437	0.409	0.406	0.378	0.362	(40)
(41)		taud		2.357	2.268	2.170	2.074	2.162	2.331	2.292	2.261	2.342	2.324	2.359	2.388	(41)
(42)		Ebn at Noon		823	842	845	827	839	872	854	840	849	815	801	802	(42)
(43)		Edh at Noon		97	117	141	163	151	127	132	133	117	110	96	89	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.50	3.42	4.83	6.05	7.03	7.82	7.62	6.82	5.81	4.28	3.04	2.28	(44)
(45)		RadStd		0.18	0.29	0.26	0.29	0.34	0.15	0.15	0.12	0.17	0.21	0.18	0.20	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (12 neighbors)	+0.41	N/A	N/A	N/A	N/A	-0.90	N/A	N/A	N/A	N/A
		+0.43	N/A	N/A	N/A	N/A	N/A	-80	+162	+80	

Nomenclature: See separate page