

GECITKALE, Cyprus

WMO: 175300

Lat: 35.233N

Lon: 33.733E

Elev: 45

StdP: 100.79

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.5	2.2	-4.2	2.7	7.9	-2.6	3.1	8.0	11.8	11.7	10.2	12.4	1.6	270	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.6	38.2	21.3	37.1	21.6	36.1	21.7	25.1	32.7	24.6	32.2	24.0	31.6	3.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	18.0	28.4	22.4	17.2	28.3	21.7	16.4	28.3	77.0	32.4	74.7	32.1	72.5	31.5	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	7.8	6.7	-2.3	41.1	1.2	1.3	-3.2	42.0	-3.9	42.8	-4.6	43.5	-5.5	44.5	
			DB												
			WB	-2.9	26.3	1.2	0.7	-3.8	26.8	-4.5	27.2	-5.2	27.6	-6.1	28.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	10.7	11.3	13.2	17.0	21.6	25.6	28.8	29.2	26.0	21.6	16.5	12.6
	DBStd	6.98	2.43	2.63	2.45	2.66	2.78	2.46	1.83	1.57	2.02	2.34	2.56	2.36
	HDD10.0	47	21	16	4	0	0	0	0	0	0	0	0	6
	HDD18.3	901	238	198	159	56	4	0	0	0	3	65	178	
	CDD10.0	3536	42	52	104	211	359	468	584	596	478	361	195	86
	CDD18.3	1347	0	0	1	17	104	218	326	337	228	106	10	0
	CDH23.3	17876	0	5	27	438	1381	2798	4570	4636	2708	1139	168	6
	CDH26.7	9486	0	0	0	122	569	1470	2711	2760	1423	409	22	0
Wind	WSAvg	2.3	2.4	2.5	2.5	2.2	2.3	2.4	2.4	2.2	2.1	2.3	2.5	2.4
Precipitation	PrecAvg	357	76	51	27	19	21	6	2	1	7	21	42	80
	PrecMax	525	230	151	100	54	64	25	20	6	23	67	147	275
	PrecMin	180	18	14	0	2	5	0	0	0	0	3	0	8
	PrecStd	97	44	33	20	12	16	7	5	2	8	16	36	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	24.0	25.7	32.6	36.9	39.0	40.3	39.8	38.2	33.6	28.8	23.0
		MCWB	14.4	15.3	14.6	16.4	18.5	20.9	21.5	21.9	21.0	18.2	17.2	15.5
	2%	DB	18.9	21.0	24.0	29.8	34.1	36.7	38.1	38.2	36.0	31.9	27.0	21.0
		MCWB	13.7	14.5	14.2	15.5	18.4	20.9	21.4	21.6	21.0	18.9	16.4	14.7
	5%	DB	17.9	19.2	22.4	28.1	31.8	35.0	36.9	37.0	34.6	30.5	25.2	19.8
		MCWB	13.0	13.5	14.1	15.7	18.4	20.8	21.7	22.0	21.5	18.9	16.6	14.2
	10%	DB	16.7	17.9	21.0	26.1	29.8	33.4	35.9	36.1	33.2	29.1	23.7	18.6
		MCWB	12.4	13.0	13.9	15.5	18.1	20.6	22.2	22.1	21.4	18.9	15.9	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.2	17.0	18.6	21.3	24.6	25.7	26.1	24.5	22.1	19.3	17.0
		MCDB	18.4	21.2	22.0	27.0	30.1	32.6	33.7	32.8	32.8	28.3	25.5	20.8
	2%	WB	14.4	15.2	15.9	17.7	20.4	23.6	25.0	25.3	23.7	21.1	18.1	15.9
		MCDB	18.0	20.1	21.1	26.0	28.8	31.0	32.5	32.6	31.9	28.0	24.3	19.8
	5%	WB	13.5	14.2	15.1	16.9	19.6	22.8	24.5	24.7	23.1	20.4	17.2	15.0
		MCDB	17.1	18.5	20.3	24.7	27.7	30.2	32.0	32.3	31.3	27.4	23.4	18.9
	10%	WB	12.7	13.3	14.2	16.1	18.9	22.1	23.9	24.2	22.5	19.7	16.5	14.1
		MCDB	16.0	17.3	19.7	23.6	27.0	29.6	31.5	31.8	30.5	26.7	22.5	17.6
Mean Daily Temperature Range	5% DB	MDBR	11.6	13.1	15.0	16.1	15.3	14.7	14.3	14.6	15.0	14.6	13.9	11.9
		MCDBR	13.4	14.9	16.9	19.1	18.0	16.1	15.3	15.6	16.6	16.2	15.9	13.8
		MCWBR	8.8	9.3	9.4	8.8	7.0	6.2	5.9	6.2	6.8	7.4	8.5	8.6
	5% WB	MCDBR	12.7	14.2	15.1	16.4	15.3	14.6	14.1	14.3	15.3	14.5	14.4	12.1
		MCWBR	8.7	9.4	9.1	8.6	6.8	6.0	5.6	5.7	6.6	7.1	8.1	7.9
Clear-Sky Solar Irradiance	taub	0.371	0.394	0.427	0.472	0.461	0.419	0.438	0.447	0.417	0.413	0.385	0.368	
	taud	2.346	2.263	2.165	2.061	2.151	2.323	2.279	2.246	2.331	2.309	2.342	2.372	
	Ebn at Noon	816	837	839	819	832	865	846	831	841	807	792	794	
	Edh at Noon	98	118	141	165	152	128	133	135	118	111	97	90	
All-Sky Solar Radiation	RadAvg	2.49	3.41	4.82	6.02	7.04	7.81	7.59	6.80	5.79	4.25	3.03	2.26	
	RadStd	0.18	0.29	0.25	0.30	0.33	0.16	0.14	0.12	0.17	0.21	0.18	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80

Nomenclature: See separate page