

ISKELE, Cyprus

WMO: 175350

Lat: 35.283N

Lon: 33.883E

Elev: 128

StdP: 14.63

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.8	40.7	25.1	19.3	44.7	28.2	22.3	46.6	28.0	54.4	24.0	52.6	5.5	10	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.7	95.5	72.0	93.7	72.6	92.1	73.0	78.2	89.1	77.3	88.4	76.3	87.7	10.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	132.2	85.3	73.8	126.6	85.0	72.6	121.5	84.7	41.9	89.4	40.9	88.4	40.0	87.6	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	18.4	15.8		33.7	101.3	2.5	2.5	31.9	103.1	30.4	104.6	29.1	106.0	27.3	107.8
				30.7	79.7	2.5	0.7	28.9	80.3	27.4	80.7	26.0	81.1	24.2	81.7
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.2	52.6	53.3	56.3	62.2	69.7	76.8	82.2	83.2	78.3	71.9	63.5	55.9
	DBStd	11.58	4.09	4.40	4.29	4.51	4.68	4.08	3.05	2.44	3.14	3.97	4.51	4.24
	HDD50	57	25	19	6	0	0	0	0	0	0	0	0	7
	HDD65	1465	384	328	271	107	10	0	0	0	2	80	283	
	CDD50	6349	106	111	202	366	611	805	998	1030	850	677	404	189
	CDD65	2282	0	0	1	23	156	355	533	565	400	215	34	0
	CDH74	25664	0	2	6	275	1423	3858	6817	7316	4197	1641	129	0
	CDH80	11444	0	0	0	48	377	1509	3450	3826	1827	402	5	0
Wind	WSAvg	6.4	6.9	7.3	7.0	6.1	6.2	6.3	6.3	5.9	5.7	5.9	6.6	6.7
Precipitation	PrecAvg	14.1	3.0	2.0	1.1	0.7	0.8	0.2	0.1	0.0	0.3	0.8	1.7	3.1
	PrecMax	20.7	9.1	5.9	3.9	2.1	2.5	1.0	0.8	0.2	0.9	2.6	5.8	10.8
	PrecMin	7.1	0.7	0.6	0.0	0.1	0.2	0.0	0.0	0.0	0.1	0.0	0.3	0.3
	PrecStd	3.8	1.7	1.3	0.8	0.5	0.6	0.3	0.2	0.1	0.3	0.6	1.4	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.3	72.2	74.6	86.7	91.7	96.2	97.9	98.2	95.1	89.8	80.7	70.1
		MCWB	56.8	59.2	58.4	61.0	66.6	68.8	71.6	72.2	70.4	66.2	65.2	60.0
	2%	DB	64.4	66.8	71.4	80.5	87.8	92.0	95.4	95.5	92.2	86.7	77.3	68.3
		MCWB	56.1	57.3	57.4	59.6	66.7	69.7	72.5	72.6	72.6	67.5	63.2	58.9
	5%	DB	62.7	64.6	69.2	77.0	84.0	89.7	93.5	93.9	90.1	84.1	75.1	66.7
		MCWB	55.1	56.1	57.0	60.2	65.0	70.2	72.8	73.3	72.8	67.6	61.9	57.6
	10%	DB	61.2	62.9	67.1	74.4	81.1	87.4	91.7	92.4	88.4	82.1	73.0	64.8
		MCWB	54.2	55.1	56.5	60.5	65.0	70.5	73.4	74.0	72.4	66.7	60.8	56.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.6	60.5	61.4	65.9	70.5	77.1	79.2	80.1	77.9	72.7	67.8	62.1
		MCDB	63.9	67.5	68.4	75.9	81.4	87.3	89.4	89.8	89.3	82.8	76.4	68.1
	2%	WB	57.3	58.6	60.0	64.1	69.0	75.3	78.1	78.6	76.3	70.8	65.4	60.5
		MCDB	62.7	65.4	67.8	74.5	80.7	85.4	88.6	89.8	87.9	82.0	74.4	66.8
	5%	WB	56.0	57.2	58.8	62.6	67.9	73.9	77.2	77.5	74.9	69.6	63.6	59.0
		MCDB	61.7	63.7	66.8	73.4	79.5	84.5	87.8	89.0	87.0	81.1	73.1	65.0
	10%	WB	54.6	55.7	57.4	61.2	66.6	72.5	76.2	76.6	73.7	68.3	62.1	57.3
		MCDB	60.4	62.0	65.4	71.8	78.2	83.5	87.2	88.4	86.0	79.7	71.3	63.5
Mean Daily Temperature Range	5% DB	MDBR	15.3	16.9	19.6	21.6	20.7	20.2	19.8	19.7	20.0	19.3	17.1	15.7
		MCDBR	17.3	18.7	22.4	25.2	24.3	22.2	21.7	21.3	22.1	21.2	18.4	17.6
		MCWBR	11.7	12.3	13.6	14.5	12.0	11.2	11.4	12.0	12.3	11.8	11.3	11.3
	5% WB	MCDBR	16.1	17.6	20.0	22.5	21.1	20.0	20.1	19.1	20.4	19.5	17.6	15.0
		MCWBR	11.7	12.6	13.5	14.4	11.5	10.7	10.9	11.1	12.3	11.7	11.8	10.4
Clear-Sky Solar Irradiance	taub	0.371	0.395	0.428	0.474	0.463	0.422	0.441	0.451	0.419	0.416	0.387	0.369	
	taud	2.349	2.268	2.170	2.062	2.153	2.326	2.279	2.246	2.334	2.309	2.342	2.371	
	Ebn at Noon	259	265	266	259	263	274	267	263	266	255	250	251	
	Edh at Noon	31	37	45	52	48	41	42	43	37	35	31	29	
All-Sky Solar Radiation	RadAvg	786	1079	1527	1906	2232	2474	2402	2151	1832	1345	957	714	
	RadStd	57	90	78	98	105	50	44	36	55	67	57	66	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page