

ISKELE, Cyprus

WMO: 175350

Lat: 35.283N

Lon: 33.883E

Elev: 39

StdP: 100.86

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.2	4.8	-3.8	2.8	7.1	-2.1	3.2	8.1	12.5	12.4	10.7	11.5	2.5	10	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.9	35.3	22.2	34.3	22.6	33.4	22.8	25.7	31.7	25.2	31.3	24.6	31.0	4.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	18.9	29.6	23.2	18.1	29.4	22.6	17.4	29.3	79.6	31.9	77.3	31.3	75.1	30.9	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.8	8.2	7.1	DB	0.9	38.5	1.4	1.4	-0.1	39.5	-0.9	40.3	-1.6	41.1	-2.6	42.1	
			WB	-0.7	26.5	1.4	0.4	-1.7	26.8	-2.5	27.1	-3.3	27.3	-4.3	27.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	11.5	11.8	13.5	16.8	21.0	24.9	27.9	28.5	25.7	22.1	17.5	13.3
	DBStd	6.43	2.27	2.44	2.38	2.51	2.60	2.26	1.70	1.36	1.74	2.21	2.50	2.36
	HDD10.0	32	14	11	3	0	0	0	0	0	0	0	0	4
	HDD18.3	814	213	182	151	59	6	0	0	0	1	44	157	
	CDD10.0	3527	59	62	112	203	339	447	554	572	472	376	224	105
	CDD18.3	1268	0	0	1	13	87	197	296	314	222	119	19	0
	CDH23.3	14258	0	1	3	153	791	2143	3787	4064	2332	912	72	0
	CDH26.7	6358	0	0	0	27	209	838	1917	2126	1015	223	3	0
Wind	WSAvg	2.9	3.1	3.2	3.1	2.7	2.8	2.8	2.6	2.6	2.6	3.0	3.0	
Precipitation	PrecAvg	357	76	51	27	19	21	6	2	1	7	21	42	80
	PrecMax	525	230	151	100	54	64	25	20	6	23	67	147	275
	PrecMin	180	18	14	0	2	5	0	0	0	3	0	0	8
	PrecStd	97	44	33	20	12	16	7	5	2	8	16	36	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.0	22.4	23.7	30.4	33.2	35.7	36.6	36.8	35.0	32.1	27.0	21.2
		MCWB	13.8	15.1	14.7	16.1	19.2	20.4	22.0	22.3	21.3	19.0	18.4	15.5
	2%	DB	18.0	19.3	21.9	26.9	31.0	33.3	35.2	35.3	33.4	30.4	25.2	20.2
		MCWB	13.4	14.0	14.1	15.4	19.3	20.9	22.5	22.5	22.6	19.7	17.3	14.9
	5%	DB	17.1	18.1	20.6	25.0	28.9	32.0	34.2	34.4	32.3	29.0	23.9	19.3
		MCWB	12.8	13.4	13.9	15.6	18.3	21.2	22.7	22.9	22.6	19.8	16.6	14.2
	10%	DB	16.2	17.1	19.5	23.6	27.3	30.8	33.2	33.5	31.3	27.8	22.8	18.2
		MCWB	12.3	12.8	13.6	15.9	18.3	21.4	23.0	23.3	22.4	19.3	16.0	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.3	15.8	16.3	18.8	21.4	25.0	26.2	26.7	25.5	22.6	19.9	16.7
		MCDB	17.7	19.7	20.2	24.4	27.4	30.7	31.9	32.1	31.8	28.2	24.7	20.1
	2%	WB	14.1	14.8	15.6	17.8	20.6	24.0	25.6	25.9	24.6	21.6	18.5	15.8
		MCDB	17.1	18.6	19.9	23.6	27.1	29.7	31.5	32.1	31.1	27.8	23.6	19.4
	5%	WB	13.3	14.0	14.9	17.0	20.0	23.3	25.1	25.3	23.8	20.9	17.6	15.0
		MCDB	16.5	17.6	19.3	23.0	26.4	29.2	31.0	31.7	30.6	27.3	22.8	18.3
	10%	WB	12.6	13.1	14.1	16.2	19.2	22.5	24.5	24.8	23.2	20.1	16.7	14.1
		MCDB	15.8	16.7	18.6	22.1	25.7	28.6	30.7	31.3	30.0	26.5	21.8	17.5
Mean Daily Temperature Range	5% DB	MDBR	8.5	9.4	10.9	12.0	11.5	11.2	11.0	10.9	11.1	10.7	9.5	8.7
		MCDBR	9.6	10.4	12.4	14.0	13.5	12.3	12.1	11.8	12.3	11.8	10.2	9.8
		MCWBR	6.5	6.8	7.6	8.0	6.7	6.2	6.3	6.7	6.9	6.6	6.3	6.3
	5% WB	MCDBR	8.9	9.8	11.1	12.5	11.7	11.1	11.2	10.6	11.3	10.8	9.8	8.3
		MCWBR	6.5	7.0	7.5	8.0	6.4	5.9	6.1	6.2	6.8	6.5	6.5	5.8
Clear-Sky Solar Irradiance	taub	0.371	0.395	0.428	0.474	0.463	0.422	0.441	0.451	0.419	0.416	0.387	0.369	
	taud	2.349	2.268	2.170	2.062	2.153	2.326	2.279	2.246	2.334	2.309	2.342	2.371	
	Ebn at Noon	815	836	839	817	830	863	843	828	838	804	789	792	
	Edh at Noon	97	117	141	165	152	128	133	135	118	111	97	90	
All-Sky Solar Radiation	RadAvg	2.48	3.40	4.81	6.01	7.04	7.80	7.57	6.78	5.77	4.24	3.02	2.25	
	RadStd	0.18	0.28	0.24	0.31	0.33	0.16	0.14	0.12	0.17	0.21	0.18	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80

Nomenclature: See separate page