

PAFOS INTL, Cyprus

WMO: 176000

Lat: 34.718N

Lon: 32.486E

Elev: 41

StdP: 14.67

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	41.9	44.4	28.2	22.2	48.4	31.7	26.1	50.5	31.5	56.0	28.0	56.9	8.3	30	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.5	89.6	79.2	88.1	78.9	87.3	78.5	81.5	87.5	80.4	86.8	79.4	85.6	10.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.9	86.6	78.7	149.2	86.1	77.3	142.3	85.0	45.3	88.0	44.3	86.6	43.2	86.2	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.4	20.4	17.9	36.6	94.9	3.3	2.4	34.2	96.6	32.3	98.1	30.5	99.4	28.1	101.2
			33.1	83.1	3.0	1.3	30.9	84.1	29.2	84.8	27.5	85.6	25.4	86.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.1	55.6	55.8	58.0	62.3	68.2	74.3	78.6	79.7	76.5	71.7	64.9	58.9
	DBStd	9.33	3.89	3.98	3.97	4.23	3.77	3.32	2.34	2.28	2.65	3.54	4.24	4.07
	HDD50	16	7	6	1	0	0	0	0	0	0	0	0	2
	HDD65	1128	293	258	221	101	12	0	0	0	0	2	50	191
	CDD50	6261	179	168	250	370	563	729	888	921	795	672	448	278
	CDD65	1898	0	0	5	21	110	279	423	456	345	209	47	3
	CDH74	17798	0	1	24	115	530	2364	4713	5207	3246	1394	198	6
	CDH80	5372	0	0	2	21	52	476	1644	2028	937	203	9	0
Wind	WSAvg	8.4	9.4	9.6	9.2	8.8	8.0	7.8	7.5	7.5	8.0	7.8	8.2	8.9
Precipitation	PrecAvg	16.3	3.5	2.8	1.5	0.7	0.5	0.1	0.0	0.0	0.2	0.9	2.2	3.9
	PrecMax	28.9	9.9	6.3	3.1	2.0	2.0	0.5	0.1	0.2	0.9	3.9	7.1	11.1
	PrecMin	8.4	0.3	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
	PrecStd	5.1	2.2	1.2	0.9	0.6	0.5	0.1	0.0	0.3	1.0	1.7	2.7	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.7	71.7	77.1	82.6	84.6	89.7	91.5	91.6	89.5	86.6	80.9	74.1
		MCWB	59.1	58.0	60.8	63.6	67.8	74.1	78.1	80.0	77.9	71.1	67.2	61.2
	2%	DB	66.6	68.1	71.8	77.0	80.7	86.2	89.2	89.8	87.5	83.9	78.5	71.2
		MCWB	57.9	58.7	59.5	63.5	69.5	75.7	79.3	80.4	77.8	72.5	66.1	61.3
	5%	DB	65.3	66.2	68.5	73.6	78.7	84.3	87.8	88.2	86.0	82.3	76.5	69.3
		MCWB	57.3	57.9	59.8	63.4	69.6	75.5	79.4	79.8	76.6	71.5	65.3	60.3
	10%	DB	64.2	64.4	66.7	71.5	76.9	82.6	86.3	87.6	84.5	80.6	73.9	67.7
		MCWB	56.6	56.7	59.0	63.1	68.8	74.5	78.5	79.4	75.5	70.7	63.8	59.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.9	62.8	64.1	68.2	73.9	79.8	82.6	83.7	81.0	76.3	71.1	64.8
		MCDB	66.2	68.2	70.5	75.1	79.9	85.7	88.1	89.1	87.3	83.2	78.2	71.3
	2%	WB	59.8	60.4	62.5	66.3	72.2	78.2	81.0	82.0	79.0	74.2	68.1	62.7
		MCDB	65.0	66.3	68.8	73.5	78.1	84.0	87.1	87.8	85.7	81.7	76.1	68.9
	5%	WB	58.5	58.9	61.0	64.9	70.8	76.9	80.1	80.9	77.9	72.6	66.3	61.1
		MCDB	64.1	64.9	67.3	71.7	76.7	82.8	86.3	87.2	84.7	80.5	74.6	67.7
	10%	WB	57.0	57.3	59.8	63.5	69.4	75.5	79.1	79.9	76.5	71.4	64.7	59.7
		MCDB	63.0	63.4	66.2	70.0	75.5	81.4	85.1	86.2	83.6	79.5	73.0	66.5
Mean Daily Temperature Range	5% DB	MDBR	14.7	15.3	16.3	16.5	16.1	15.9	15.8	15.5	16.0	16.4	16.4	15.0
		MCDBR	15.6	17.3	18.6	19.9	18.1	17.0	17.0	16.3	17.0	17.4	18.2	16.5
		MCWBR	11.2	12.8	13.8	14.7	15.4	15.1	15.8	14.6	14.4	14.2	14.3	12.1
	5% WB	MCDBR	14.4	16.1	17.3	18.3	17.1	16.6	16.4	15.8	16.8	16.6	16.5	14.8
		MCWBR	11.2	12.7	13.8	14.9	15.4	15.9	15.3	15.3	15.7	14.5	13.4	11.5
Clear-Sky Solar Irradiance	taub	0.369	0.400	0.436	0.473	0.463	0.417	0.430	0.442	0.415	0.410	0.382	0.364	
	taud	2.371	2.253	2.148	2.062	2.151	2.340	2.304	2.269	2.348	2.338	2.380	2.412	
	Ebn at Noon	261	264	264	260	264	275	271	266	268	258	254	255	
	Edh at Noon	30	38	46	52	49	40	41	42	37	35	30	28	
All-Sky Solar Radiation	RadAvg	820	1117	1581	1966	2280	2519	2446	2197	1880	1401	999	768	
	RadStd	57	101	71	105	109	51	37	31	51	56	51	61	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page