

PAFOS INTL, Cyprus

WMO: 176000

Lat: 34.718N

Lon: 32.486E

Elev: 13

StdP: 101.17

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.5	6.9	-2.1	3.2	9.1	-0.2	3.7	10.3	14.1	13.3	12.5	13.8	3.7	30	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.6	32.0	26.2	31.2	26.0	30.7	25.8	27.5	30.8	26.9	30.4	26.3	29.8	4.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	30.3	25.9	21.3	30.1	25.2	20.3	29.4	87.5	31.1	85.1	30.3	82.5	30.1	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	9.1	8.0	DB	2.6	34.9	1.8	1.3	1.2	35.9	0.2	36.7	-0.8	37.5	-2.2	38.4	(4)
			WB	0.6	28.4	1.6	0.7	-0.6	28.9	-1.6	29.3	-2.5	29.8	-3.7	30.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	13.1	13.2	14.4	16.9	20.1	23.5	25.9	26.5	24.7	22.0	18.3	14.9	(6)
(7)		DBStd	5.19	2.16	2.21	2.21	2.35	2.09	1.84	1.30	1.27	1.47	1.97	2.35	2.26	(7)
(8)		HDD10.0	9	4	3	1	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD18.3	627	163	143	123	56	7	0	0	0	0	1	28	106	(9)
(10)		CDD10.0	3478	99	93	139	206	313	405	493	512	442	373	249	154	(10)
(11)		CDD18.3	1054	0	0	3	12	61	155	235	253	192	116	26	2	(11)
(12)		CDH23.3	9888	0	1	13	64	294	1313	2618	2893	1803	774	110	3	(12)
(13)	CDH26.7	2984	0	0	1	12	29	264	913	1127	521	113	5	0	(13)	
(14)	Wind	WSAvg	3.7	4.2	4.3	4.1	3.9	3.6	3.5	3.3	3.4	3.6	3.5	3.7	4.0	(14)
(15)	Precipitation	PrecAvg	415	89	70	37	19	12	2	1	5	23	57	99	(15)	
(16)		PrecMax	733	252	159	79	52	52	12	3	6	23	100	181	281	(16)
(17)		PrecMin	214	7	21	1	0	0	0	0	0	0	0	7	(17)	
(18)		PrecStd	130	55	30	22	15	12	3	1	7	25	42	68	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	22.1	25.1	28.1	29.2	32.0	33.0	33.1	31.9	30.3	27.2	23.4	(19)
(20)			MCWB	15.0	14.4	16.0	17.6	19.9	23.4	25.6	26.7	25.5	21.7	19.5	16.2	(20)
(21)		2%	DB	19.2	20.1	22.1	25.0	27.1	30.1	31.8	32.1	30.9	28.9	25.8	21.8	(21)
(22)			MCWB	14.4	14.8	15.3	17.5	20.8	24.3	26.3	26.9	25.4	22.5	18.9	16.3	(22)
(23)		5%	DB	18.5	19.0	20.3	23.1	26.0	29.0	31.0	31.2	30.0	27.9	24.7	20.7	(23)
(24)			MCWB	14.0	14.4	15.5	17.5	20.9	24.2	26.3	26.5	24.8	21.9	18.5	15.7	(24)
(25)	10%	DB	17.9	18.0	19.3	21.9	25.0	28.1	30.1	30.9	29.2	27.0	23.3	19.8	(25)	
(26)		MCWB	13.7	13.7	15.0	17.3	20.4	23.6	25.8	26.3	24.2	21.5	17.7	15.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.6	17.1	17.8	20.1	23.3	26.6	28.1	28.7	27.2	24.6	21.7	18.2	(27)
(28)			MCDWB	19.0	20.1	21.4	24.0	26.6	29.8	31.2	31.7	30.7	28.4	25.6	21.8	(28)
(29)		2%	WB	15.5	15.8	16.9	19.1	22.4	25.7	27.2	27.8	26.1	23.5	20.1	17.1	(29)
(30)			MCDWB	18.4	19.1	20.4	23.0	25.6	28.9	30.6	31.0	29.8	27.6	24.5	20.5	(30)
(31)		5%	WB	14.7	14.9	16.1	18.3	21.5	24.9	26.7	27.2	25.5	22.6	19.1	16.2	(31)
(32)			MCDWB	17.9	18.3	19.6	22.1	24.9	28.2	30.2	30.6	29.3	26.9	23.7	19.8	(32)
(33)	10%	WB	13.9	14.1	15.4	17.5	20.8	24.2	26.2	26.6	24.7	21.9	18.2	15.4	(33)	
(34)		MCDWB	17.2	17.4	19.0	21.1	24.1	27.5	29.5	30.1	28.7	26.4	22.8	19.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.1	8.5	9.0	9.2	9.0	8.8	8.8	8.6	8.9	9.1	9.1	8.3	(35)
(36)			MCDBR	8.7	9.6	10.3	11.0	10.1	9.4	9.4	9.0	9.4	9.7	10.1	9.2	(36)
(37)			MCWBR	6.2	7.1	7.7	8.2	8.5	8.4	8.8	8.1	8.0	7.9	8.0	6.7	(37)
(38)		5% WB	MCDWB	8.0	9.0	9.6	10.2	9.5	9.2	9.1	8.8	9.3	9.2	9.2	8.2	(38)
(39)			MCWBR	6.2	7.1	7.6	8.3	8.5	8.8	8.8	8.5	8.7	8.0	7.4	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.400	0.436	0.473	0.463	0.417	0.430	0.442	0.415	0.410	0.382	0.364	(40)	
(41)		taud	2.371	2.253	2.148	2.062	2.151	2.340	2.304	2.269	2.348	2.338	2.380	2.412	(41)	
(42)		Ebn at Noon	822	833	833	820	831	867	853	837	845	814	802	805	(42)	
(43)		Edh at Noon	96	120	144	165	153	126	130	132	117	109	95	88	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.58	3.52	4.99	6.20	7.19	7.94	7.71	6.93	5.93	4.42	3.15	2.42	(44)	
(45)		RadStd	0.18	0.32	0.23	0.33	0.34	0.16	0.12	0.10	0.16	0.17	0.16	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.73	N/A	N/A	+0.52	+0.25	N/A	N/A	-140	+275	+125	(46)
(47)	Regional (11 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80	(47)

Nomenclature: See separate page