

AKROTIRI, Cyprus

WMO: 176010

Lat: 34.590N

Lon: 32.988E

Elev: 76

StdP: 14.66

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 41.7	(c) 44.4	(d) 25.9	(e) 19.9	(f) 48.6	(g) 29.8	(h) 24.0	(i) 50.8	(j) 27.9	(k) 56.6	(l) 26.0	(m) 57.3	(n) 5.1	(o) 330	(p) 0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.0	(c) 91.7	(d) 73.0	(e) 89.7	(f) 73.5	(g) 87.9	(h) 74.5	(i) 79.6	(j) 85.5	(k) 78.8	(l) 84.7	(m) 78.0	(n) 84.1	(o) 9.0	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.2	146.6	83.3	77.0	141.2	83.0	75.8	135.2	82.4	43.4	85.6	42.4	85.1	41.6	83.9	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	21.8	19.8	36.8	97.8	3.2	2.3	34.5	99.5	32.6	100.8	30.8	102.1	28.5	103.8
			32.9	81.8	3.2	1.7	30.6	83.0	28.7	84.1	26.9	85.0	24.6	86.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.9	54.9	55.5	58.4	63.5	70.3	76.6	80.8	81.3	77.6	72.1	64.5	57.9	(6)
	DBStd	10.21	3.97	4.01	3.98	4.37	4.29	3.75	2.72	2.46	2.72	3.80	4.52	4.01	(7)
	HDD50	18	9	6	1	0	0	0	0	0	0	0	0	2	(8)
	HDD65	1149	312	267	207	78	4	0	0	0	0	2	59	220	(9)
	CDD50	6539	162	159	262	406	628	798	954	972	828	686	436	248	(10)
	CDD65	2195	0	0	4	33	167	348	489	507	378	223	45	1	(11)
	CDH74	19582	0	0	6	149	842	2760	5237	5684	3368	1373	162	1	(12)
	CDH80	5986	0	0	0	24	199	760	1819	2056	894	225	9	0	(13)
(14) Wind	WSAvg	8.6	8.7	8.8	8.8	8.8	9.0	9.6	9.7	9.3	8.3	6.5	7.2	8.1	(14)
(15) Precipitation	PrecAvg	18.5	4.0	3.3	1.7	0.9	0.5	0.2	0.1	0.1	0.2	0.8	2.4	4.4	(15)
	PrecMax	31.3	14.2	6.7	3.8	2.5	2.1	1.1	0.5	0.5	1.1	3.8	9.7	13.5	(16)
	PrecMin	10.8	0.3	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	(17)
	PrecStd	5.7	3.0	1.6	1.0	0.6	0.5	0.3	0.1	0.2	0.3	0.9	2.0	3.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.1	69.5	74.5	83.3	89.9	93.6	95.0	94.8	91.5	88.2	81.2	71.6	(19)
		MCWB	58.7	59.4	59.0	61.5	65.3	69.2	72.2	73.6	71.9	68.3	66.2	61.0	(20)
	2%	DB	65.2	66.5	70.7	78.0	84.6	89.6	91.5	91.4	88.0	84.5	77.7	69.4	(21)
		MCWB	57.0	57.6	58.6	60.6	64.7	69.5	73.8	75.2	73.2	69.0	64.1	59.8	(22)
	5%	DB	64.1	64.7	68.2	74.8	81.6	86.4	89.3	89.4	86.1	82.3	75.5	67.7	(23)
		MCWB	56.1	56.5	58.1	60.7	65.5	70.1	74.7	76.0	73.5	68.9	63.4	58.8	(24)
	10%	DB	62.7	63.2	66.2	71.7	78.6	84.2	87.3	87.6	84.5	80.5	73.5	66.1	(25)
		MCWB	55.4	55.4	57.5	60.6	65.4	71.3	75.7	76.8	73.1	68.3	62.7	57.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.1	61.2	62.7	66.1	72.1	77.8	80.7	81.3	79.0	74.7	69.2	63.6	(27)
		MCDB	65.2	66.6	69.3	73.1	79.0	83.4	86.7	86.6	85.0	81.8	76.9	69.0	(28)
	2%	WB	59.1	59.4	61.0	64.2	70.2	76.1	79.4	80.0	77.4	72.6	67.2	61.5	(29)
		MCDB	63.7	65.0	66.8	71.2	77.2	82.5	85.3	85.7	83.8	79.9	74.9	67.0	(30)
	5%	WB	57.4	57.9	59.8	63.0	68.9	74.9	78.6	79.1	76.1	71.4	65.4	60.1	(31)
		MCDB	62.5	63.5	65.8	70.0	75.8	81.3	84.5	84.9	82.8	79.2	73.4	66.0	(32)
	10%	WB	56.0	56.5	58.7	61.9	67.6	73.8	77.7	78.4	74.9	69.9	63.7	58.8	(33)
		MCDB	61.4	62.2	64.9	68.9	74.5	80.2	83.8	84.4	82.1	78.3	71.6	64.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.6	14.1	14.3	14.2	13.9	13.4	13.0	13.0	14.1	15.8	15.8	14.1	(35)
		MCDBR	14.4	15.6	16.2	18.3	18.3	16.9	15.7	15.1	16.0	17.5	17.5	15.3	(36)
		MCWBR	9.6	10.5	10.3	9.8	9.8	10.5	11.0	11.3	12.4	12.8	12.3	10.4	(37)
	5% WB	MCDBR	13.2	14.6	14.5	15.2	15.1	14.1	13.8	13.7	14.6	15.6	15.8	13.7	(38)
		MCWBR	9.8	10.6	9.8	9.1	9.0	9.1	9.6	10.0	12.0	12.2	11.9	10.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.371	0.402	0.437	0.472	0.464	0.416	0.430	0.440	0.413	0.412	0.383	0.365	(40)
	taud		2.356	2.244	2.139	2.059	2.142	2.336	2.301	2.272	2.347	2.327	2.371	2.401	(41)
	Ebn at Noon		260	264	264	260	264	275	271	266	268	258	254	255	(42)
	Edh at Noon		31	38	46	52	49	40	41	42	37	35	30	28	(43)
(44) All-Sky Solar Radiation	RadAvg		836	1133	1589	1969	2285	2518	2448	2203	1890	1411	1007	771	(44)
	RadStd		53	97	72	100	110	46	38	33	51	57	50	63	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.52	N/A	N/A	N/A	N/A	+0.40	N/A	-103	+207	N/A
Regional (11 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-144	+292	+144

Nomenclature: See separate page