

LARNACA, Cyprus

WMO: 176090

Lat: 34.875N

Lon: 33.625E

Elev: 2

StdP: 101.30

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.2	5.9	-3.9	2.7	8.9	-1.9	3.2	10.1	13.1	13.8	11.0	14.4	3.2	310	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	34.8	22.9	33.8	23.3	32.8	23.6	27.0	30.9	26.3	30.4	25.8	30.1	5.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.3	29.2	25.1	20.3	29.0	24.5	19.4	28.8	85.2	31.1	82.3	30.5	80.0	30.2	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.2	9.8	8.6	DB	2.1	37.7	1.3	1.5	1.2	38.8	0.4	39.7	-0.3	40.6	-1.2	41.7	
			WB	0.0	27.9	1.6	0.8	-1.1	28.5	-2.0	29.0	-2.9	29.4	-4.0	30.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	12.5	12.8	14.5	17.6	21.7	25.5	27.9	28.2	26.0	22.8	18.2	14.4	(6)
(7)		DBStd	6.06	2.24	2.33	2.27	2.57	2.54	2.20	1.49	1.42	1.58	2.23	2.65	2.29	(7)
(8)		HDD10.0	14	7	5	1	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD18.3	656	181	155	119	43	2	0	0	0	0	1	32	123	(9)
(10)		CDD10.0	3746	84	84	142	228	363	464	554	565	479	398	247	138	(10)
(11)		CDD18.3	1345	0	0	2	21	107	214	296	307	229	141	29	1	(11)
(12)		CDH23.3	14276	0	1	7	146	791	2186	3624	3872	2428	1083	137	1	(12)
(13)	CDH26.7	5814	0	0	0	26	208	802	1677	1852	971	269	9	0	(13)	
(14)	Wind	WSAvg	3.7	3.7	3.7	3.7	3.8	3.9	4.0	4.1	3.9	3.6	3.3	3.6	3.6	(14)
(15)	Precipitation	PrecAvg	331	74	47	34	16	12	2	0	1	3	18	43	85	(15)
(16)		PrecMax	558	235	160	140	89	46	22	6	16	22	70	224	368	(16)
(17)		PrecMin	159	4	1	0	0	0	0	0	0	0	0	0	8	(17)
(18)		PrecStd	107	49	35	27	16	15	4	1	2	6	18	46	64	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	21.6	24.1	29.7	33.1	35.8	36.1	36.3	34.1	32.2	28.0	22.8	(19)
(20)			MCWB	15.4	15.5	15.5	17.3	18.9	20.8	22.3	23.4	22.5	20.6	19.7	17.2	(20)
(21)		2%	DB	19.1	19.9	22.3	26.9	30.9	33.4	34.6	34.8	32.9	30.5	26.1	21.2	(21)
(22)			MCWB	14.3	14.8	15.4	16.4	18.7	21.1	23.0	23.9	23.0	21.0	18.4	15.8	(22)
(23)		5%	DB	18.2	18.9	21.0	24.9	29.0	31.9	33.3	33.8	31.9	29.1	25.0	20.2	(23)
(24)			MCWB	13.6	14.2	15.1	16.6	19.1	21.5	23.7	24.3	23.2	20.8	17.8	15.1	(24)
(25)		10%	DB	17.2	18.0	20.0	23.2	27.2	30.6	32.4	32.8	31.0	28.1	23.8	19.2	(25)
(26)			MCWB	13.1	13.5	14.7	16.3	19.1	22.0	24.2	24.6	23.1	20.5	17.2	14.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.8	17.0	18.0	19.7	22.8	26.1	27.7	28.5	26.6	24.4	21.2	18.4	(27)
(28)			MCDWB	19.2	19.4	21.6	23.7	26.5	29.5	30.9	31.6	30.7	29.1	25.7	21.5	(28)
(29)		2%	WB	15.4	15.7	16.9	18.6	21.7	25.1	26.7	27.2	25.5	23.1	19.9	17.0	(29)
(30)			MCDWB	18.0	18.8	20.6	23.5	26.0	29.1	30.5	31.2	30.3	28.2	24.9	20.0	(30)
(31)		5%	WB	14.5	14.9	16.0	17.9	20.9	24.3	26.2	26.6	24.8	22.2	18.8	16.0	(31)
(32)			MCDWB	17.4	18.1	19.7	22.7	25.6	28.5	30.2	30.8	29.9	27.6	23.6	19.4	(32)
(33)		10%	WB	13.6	14.0	15.2	17.2	20.3	23.7	25.7	26.0	24.1	21.2	17.8	15.1	(33)
(34)			MCDWB	16.7	17.2	19.0	21.9	25.1	28.0	29.9	30.4	29.5	26.8	22.5	18.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	9.5	10.2	10.2	10.0	9.8	9.7	9.6	10.1	10.1	9.8	8.8	(35)
(36)			MCDBR	9.4	10.0	10.8	11.6	11.9	11.1	10.8	10.7	10.8	10.6	10.4	9.5	(36)
(37)			MCWBR	6.0	6.5	6.9	7.2	7.1	6.9	6.9	7.1	7.2	7.0	6.6	6.0	(37)
(38)		5% WB	MCDWB	8.6	9.4	10.0	10.3	10.0	9.8	9.7	9.6	10.0	9.9	9.8	8.8	(38)
(39)			MCWBR	6.0	6.4	6.8	6.8	6.3	6.2	6.1	6.2	6.8	7.0	6.5	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.371	0.396	0.431	0.471	0.462	0.417	0.435	0.443	0.415	0.413	0.384	0.367	(40)	
(41)		taud	2.350	2.255	2.152	2.060	2.143	2.324	2.282	2.255	2.334	2.310	2.353	2.384	(41)	
(42)		Ebn at Noon	818	836	837	821	831	867	849	836	843	809	796	799	(42)	
(43)		Edh at Noon	98	119	144	165	154	128	133	134	118	112	97	90	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.58	3.51	4.93	6.12	7.13	7.88	7.66	6.88	5.89	4.37	3.11	2.35	(44)	
(45)		RadStd	0.17	0.29	0.24	0.30	0.34	0.14	0.13	0.11	0.17	0.20	0.17	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.35	N/A	N/A	N/A	N/A	+0.42	N/A	-60	+127	N/A	(46)	
(47)	Regional (12 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-80	+162	+80	(47)	

Nomenclature: See separate page