

GMO IM E T KRENKELJA, Russian Federation

WMO: 200460

Lat: 80.626N

Lon: 58.059E

Elev: 25

StdP: 101.03

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-35.6	-33.5	-37.8	0.1	-35.5	-36.0	0.1	-33.4	19.5	-8.0	17.4	-15.7	3.8	50	1.143

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.8	3.4	2.7	2.7	2.0	2.1	1.6	2.9	3.2	2.2	2.5	1.7	2.0	4.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2.4	4.5	3.0	1.8	4.3	2.4	1.2	4.1	1.8	14.6	3.3	13.4	2.6	12.5	2.0	5.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.2	14.0	12.2	DB	-34.3	4.8	4.4	1.7	-37.4	6.0	-40.0	7.0	-42.5	8.0	-45.7	9.3	(4)
(5)			WB	-35.0	4.0	4.5	1.1	-38.3	4.8	-41.0	5.4	-43.5	6.0	-46.8	6.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.1	-18.6	-19.0	-20.3	-16.7	-8.3	-1.3	0.7	0.3	-1.5	-6.3	-12.9	-17.6		
	DBStd	9.88	8.60	8.70	7.55	6.17	4.02	1.77	1.01	1.28	2.05	5.03	7.50	7.86		
	HDD10.0	7324	887	813	938	800	568	338	287	300	344	507	687	856		
	HDD18.3	10366	1146	1046	1197	1050	826	588	545	558	594	765	937	1114		
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH27.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.6	5.9	5.6	5.8	5.5	5.1	5.0	4.6	4.8	5.8	6.5	6.2	6.0		
(15) Precipitation	PrecAvg	261	25	31	22	16	14	12	21	23	25	22	26	28		
	PrecMax	392	80	100	96	62	36	40	49	58	53	56	90	119		
	PrecMin	107	2	0	0	0	2	0	2	4	4	6	1	0		
	PrecStd	78	15	22	19	13	8	8	11	12	11	10	21	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.5	-1.1	-1.1	-1.8	0.5	3.1	5.0	4.6	3.4	1.4	0.6	-0.5		
		MCWB	-0.9	-1.6	-1.6	-2.5	0.0	1.6	3.9	3.7	2.9	1.0	0.1	-0.9		
	2%	DB	-2.4	-2.3	-2.9	-3.2	-0.6	1.9	3.5	3.3	2.5	0.5	-0.4	-2.1		
		MCWB	-2.9	-2.7	-3.3	-3.7	-1.2	0.8	2.7	2.7	2.1	0.1	-0.8	-2.5		
	5%	DB	-3.9	-3.9	-4.6	-4.8	-1.8	1.2	2.7	2.6	1.7	-0.3	-1.2	-3.7		
		MCWB	-4.2	-4.3	-5.0	-5.3	-2.4	0.4	2.0	2.1	1.3	-0.7	-1.7	-4.0		
	10%	DB	-5.8	-5.8	-7.7	-7.6	-2.8	0.8	2.1	2.1	1.1	-1.0	-2.4	-6.1		
		MCWB	-6.3	-6.2	-8.1	-8.1	-3.4	0.1	1.5	1.6	0.8	-1.4	-2.9	-6.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.8	-1.4	-1.4	-2.3	0.1	1.9	4.1	3.8	3.1	1.1	0.2	-0.7		
		MCDB	-0.6	-1.2	-1.1	-1.8	0.4	2.8	4.8	4.3	3.3	1.2	0.4	-0.4		
	2%	WB	-2.8	-2.6	-3.2	-3.8	-1.0	1.1	2.9	2.9	2.2	0.2	-0.7	-2.4		
		MCDB	-2.5	-2.4	-3.0	-3.3	-0.6	1.6	3.3	3.2	2.4	0.4	-0.5	-2.2		
	5%	WB	-4.3	-4.3	-4.9	-5.3	-2.3	0.6	2.2	2.2	1.4	-0.5	-1.6	-4.0		
		MCDB	-3.9	-4.0	-4.5	-4.8	-1.8	1.1	2.5	2.4	1.6	-0.3	-1.3	-3.7		
	10%	WB	-6.2	-6.2	-8.1	-8.0	-3.4	0.2	1.6	1.7	0.8	-1.3	-2.8	-6.4		
		MCDB	-5.8	-5.8	-7.8	-7.6	-2.9	0.7	2.0	1.9	1.0	-1.0	-2.3	-6.0		
(35) Mean Daily Temperature Range	MDBR		5.7	6.0	5.5	4.8	3.5	2.1	1.8	1.8	2.1	2.9	4.6	5.7		
	5% DB	MCDBR	6.4	8.0	7.6	6.2	3.9	2.3	2.6	2.4	2.3	3.0	3.7	6.2		
		MCWBR	6.3	7.9	7.5	6.2	3.7	2.0	2.2	2.2	2.3	3.1	3.8	6.1		
	5% WB	MCDBR	6.4	8.2	7.4	6.1	4.1	2.2	2.6	2.4	2.3	3.1	3.4	6.2		
		MCWBR	6.3	8.2	7.3	6.1	3.9	2.0	2.2	2.2	2.4	3.2	3.5	6.1		
(40) Clear-Sky Solar Irradiance	taub		N/A	N/A	0.237	0.286	0.311	0.302	0.309	0.301	0.238	N/A	N/A	N/A		
	taud		N/A	N/A	1.941	2.040	2.080	2.218	2.328	2.358	2.190	N/A	N/A	N/A		
	Ebn at Noon		0	0	455	707	778	820	795	718	513	0	0	0		
	Edh at Noon		0	0	45	87	106	98	83	65	36	0	0	0		
(44) All-Sky Solar Radiation	RadAvg		0.00	0.00	0.66	3.23	5.56	6.21	5.12	2.77	0.84	0.00	0.00	0.00		
	RadStd		0.00	0.00	0.05	0.21	0.37	0.43	0.40	0.21	0.07	0.00	0.00	0.00		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page