

OSTROV VIZE, Russian Federation

WMO: 200690

Lat: 79.491N

Lon: 76.981E

Elev: 10

StdP: 101.20

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-38.1	-36.1	-40.3	0.1	-38.1	-38.4	0.1	-36.0	19.5	-14.8	17.1	-17.5	4.0	10	1.200

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.7	3.8	3.4	3.2	2.8	2.5	2.1	3.6	3.8	2.9	3.1	2.2	2.4	6.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3.4	4.8	3.7	2.7	4.6	3.0	2.0	4.4	2.3	16.0	3.9	14.6	3.1	13.4	2.5	7.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	14.1	12.5	DB	-37.6	4.9	3.8	1.5	-40.3	6.0	-42.6	6.8	-44.7	7.6	-47.5	8.7	(4)
(5)			WB	-37.7	4.1	3.8	1.3	-40.4	5.0	-42.6	5.7	-44.7	6.4	-47.5	7.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.4	-22.1	-22.8	-22.1	-17.7	-8.9	-1.4	0.7	0.7	-1.5	-7.4	-15.0	-19.8	(6)
(7)		DBStd	10.85	8.66	8.52	7.46	5.94	4.18	1.89	1.14	1.35	2.88	6.06	7.29	8.13	(7)
(8)		HDD10.0	7799	994	918	996	830	584	343	289	289	346	539	749	922	(8)
(9)		HDD18.3	10841	1252	1151	1254	1080	843	593	548	547	596	798	999	1181	(9)
(10)		CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.3	6.4	6.0	6.1	5.9	5.5	6.1	6.0	6.1	6.6	7.2	6.7	6.7	(14)
(15)	Precipitation	PrecAvg	207	13	13	12	10	14	12	21	26	23	23	18	19	(15)
(16)		PrecMax	330	30	34	30	32	57	38	59	91	46	65	56	65	(16)
(17)		PrecMin	132	0	1	0	1	4	2	2	3	7	0	1	3	(17)
(18)		PrecStd	51	7	7	7	7	9	6	13	16	10	12	11	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.2	-1.7	-1.9	-1.2	0.0	2.7	6.0	4.7	4.0	2.5	0.2	-1.4	(19)
(20)			MCWB	-1.6	-2.2	-2.2	-1.5	-0.3	1.5	5.2	4.2	3.6	2.0	-0.4	-1.7	(20)
(21)		2%	DB	-2.7	-3.9	-4.2	-3.9	-0.9	1.6	4.0	3.7	3.3	1.1	-0.8	-2.3	(21)
(22)			MCWB	-3.0	-4.3	-4.5	-4.3	-1.3	0.9	3.5	3.4	3.1	0.8	-1.4	-2.6	(22)
(23)		5%	DB	-4.9	-6.4	-6.6	-6.5	-1.9	1.1	2.8	3.2	2.4	0.2	-2.0	-3.8	(23)
(24)			MCWB	-5.5	-6.7	-7.0	-6.8	-2.3	0.6	2.2	2.9	2.2	-0.1	-2.5	-4.2	(24)
(25)		10%	DB	-8.0	-9.8	-9.9	-9.0	-3.1	0.7	2.2	2.6	1.6	-0.7	-3.6	-6.8	(25)
(26)			MCWB	-8.4	-10.1	-10.2	-9.4	-3.5	0.2	1.7	2.3	1.4	-1.2	-4.1	-7.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.5	-2.2	-2.1	-1.5	-0.1	1.7	5.5	4.4	3.7	2.1	-0.2	-1.5	(27)
(28)			MCDB	-1.4	-1.8	-1.9	-1.3	-0.1	2.1	6.0	4.6	3.8	2.4	0.1	-1.4	(28)
(29)		2%	WB	-3.0	-4.2	-4.4	-4.2	-1.2	1.1	3.6	3.6	3.2	0.9	-1.3	-2.6	(29)
(30)			MCDB	-2.7	-3.9	-4.2	-3.9	-1.0	1.4	3.9	3.7	3.3	1.0	-0.9	-2.4	(30)
(31)		5%	WB	-5.4	-6.6	-6.9	-6.8	-2.2	0.7	2.4	3.0	2.2	0.0	-2.5	-4.2	(31)
(32)			MCDB	-4.9	-6.3	-6.6	-6.5	-1.9	0.9	2.7	3.1	2.3	0.1	-2.1	-3.8	(32)
(33)		10%	WB	-8.4	-10.1	-10.1	-9.4	-3.4	0.4	1.8	2.4	1.4	-1.1	-4.1	-7.2	(33)
(34)			MCDB	-7.9	-9.8	-9.9	-9.0	-3.1	0.6	2.0	2.5	1.5	-0.8	-3.6	-6.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	5.8	5.7	5.6	3.7	2.0	1.8	1.7	2.0	3.6	5.1	5.5	(35)
(36)			MCDBR	7.2	8.2	7.8	6.5	3.7	2.0	2.7	2.3	1.9	2.4	3.7	5.8	(36)
(37)			MCWBR	7.3	8.2	7.8	6.6	3.7	1.9	2.3	2.1	2.0	2.7	4.0	5.9	(37)
(38)		5% WB	MCDBR	7.4	8.3	7.7	6.5	3.6	1.9	2.6	2.2	1.9	2.3	3.8	5.9	(38)
(39)			MCWBR	7.5	8.3	7.7	6.5	3.6	1.9	2.3	2.1	2.0	2.7	4.0	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	N/A	0.248	0.288	0.312	0.305	0.324	0.321	0.266	N/A	N/A	N/A	(40)	
(41)		taud	N/A	N/A	1.924	1.999	2.039	2.215	2.367	2.441	2.289	N/A	N/A	N/A	(41)	
(42)		Ebn at Noon	0	0	479	718	785	826	790	718	530	0	0	0	(42)	
(43)		Edh at Noon	0	0	51	94	113	100	83	64	38	0	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.00	0.81	3.34	5.43	6.18	4.74	2.37	0.73	0.00	0.00	0.00	(44)	
(45)		RadStd	0.00	0.00	0.09	0.27	0.25	0.48	0.64	0.38	0.12	0.00	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+2.21	+3.66	+3.15	N/A	N/A	+0.52	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page