

OSTROV UEDINENIJA, Russian Federation

WMO: 202740

Lat: 77.511N

Lon: 82.233E

Elev: 23

StdP: 101.05

Time Zone: 7.00 (E07)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.1	-36.8	-40.6	0.1	-38.0	-39.1	0.1	-36.6	16.5	-17.0	15.3	-19.0	4.7	140	1.221

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.0	4.2	3.7	3.0	2.5	2.2	1.7	3.7	4.1	2.7	3.0	1.8	2.1	6.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
3.3	4.8	3.9	2.3	4.5	2.8	1.5	4.2	1.9	16.3	4.2	14.3	3.1	12.7	2.1	7.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	15.5	13.5	12.1	-41.5	7.4	2.8	1.8	-43.5	8.7	-45.1	9.7	-46.7	10.7	-48.7	12.0	
(5)				-41.5	5.5	2.8	1.1	-43.5	6.3	-45.1	7.0	-46.7	7.6	-48.7	8.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-13.6	-26.4	-26.1	-24.0	-19.1	-8.7	-1.8	0.6	-0.1	-2.8	-11.2	-20.6	-24.4
	DBStd	11.80	6.56	7.08	8.17	6.63	4.11	2.12	1.35	1.64	3.05	6.69	7.41	6.46
	HDD10.0	8630	1130	1009	1054	872	578	353	293	312	385	658	918	1068
	HDD18.3	11672	1388	1243	1312	1122	837	603	551	571	635	916	1168	1326
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.0	5.9	5.9	6.1	6.1	5.6	5.5	5.7	5.8	6.2	7.1	5.6	6.6
Precipitation	PrecAvg	158	8	7	7	6	7	12	26	31	22	16	7	10
	PrecMax	228	21	29	32	21	24	34	56	69	58	35	18	31
	PrecMin	47	1	1	1	0	0	1	2	4	7	3	0	2
	PrecStd	50	6	7	7	6	6	8	14	19	11	10	6	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.6	-2.9	-1.4	-0.5	0.3	3.6	6.2	5.2	2.7	0.1	-1.5	-1.8
		MCWB	-3.9	-3.3	-1.6	-0.9	0.1	2.8	4.8	4.9	2.3	-0.4	-1.6	-2.3
	2%	DB	-7.0	-7.1	-3.7	-2.8	-0.1	1.7	4.6	4.0	1.6	-0.4	-3.6	-5.6
		MCWB	-7.2	-7.4	-4.0	-3.3	-0.4	1.0	3.8	3.8	1.2	-0.7	-3.8	-5.9
	5%	DB	-12.2	-11.4	-6.1	-6.1	-1.2	0.9	3.3	2.9	1.0	-1.0	-5.7	-10.2
		MCWB	-12.3	-11.7	-6.2	-6.6	-1.7	0.4	2.7	2.5	0.8	-1.4	-6.0	-10.4
	10%	DB	-17.3	-14.8	-11.2	-8.8	-2.8	0.5	2.4	2.1	0.5	-2.0	-9.0	-15.0
		MCWB	-17.5	-14.9	-11.4	-9.2	-3.3	0.1	2.0	1.7	0.2	-2.7	-9.3	-15.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.9	-3.2	-1.6	-0.7	0.2	2.9	5.0	5.1	2.4	0.0	-1.8	-2.1
		MCDB	-3.6	-3.1	-1.5	-0.4	0.2	3.6	5.7	5.1	2.6	0.1	-1.7	-1.9
	2%	WB	-7.3	-7.3	-3.8	-3.1	-0.4	1.2	3.8	3.8	1.4	-0.6	-3.8	-5.8
		MCDB	-7.0	-7.1	-3.7	-2.6	-0.3	1.5	4.4	4.0	1.5	-0.5	-3.6	-5.5
	5%	WB	-12.5	-11.6	-6.3	-6.5	-1.7	0.6	2.9	2.6	0.8	-1.3	-5.9	-10.5
		MCDB	-12.2	-11.3	-6.0	-6.0	-1.3	0.8	3.3	2.8	0.9	-1.1	-5.7	-10.2
	10%	WB	-17.5	-15.0	-11.4	-9.2	-3.2	0.2	2.1	1.8	0.3	-2.8	-9.3	-15.4
		MCDB	-17.2	-14.8	-11.2	-8.7	-2.8	0.4	2.4	2.0	0.4	-2.1	-9.0	-15.1
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.9	6.7	5.9	3.6	2.1	2.0	2.0	2.5	4.3	6.1	5.0
		MCDBR	10.5	12.5	10.6	6.1	3.3	2.1	3.6	2.5	2.2	4.5	10.6	9.5
		MCWBR	10.4	12.7	10.6	5.7	3.2	1.8	2.9	2.5	2.2	4.6	10.7	9.4
	5% WB	MCDBR	10.3	12.8	10.6	5.3	3.4	2.1	3.5	2.5	2.2	4.9	10.8	9.4
		MCWBR	10.3	12.7	10.6	5.4	3.4	1.9	2.9	2.4	2.3	5.1	10.8	9.4
Clear-Sky Solar Irradiance	taub	N/A	0.182	0.258	0.292	0.315	0.311	0.334	0.328	0.284	0.353	N/A	N/A	
	taud	N/A	1.845	1.934	1.992	2.030	2.212	2.376	2.471	2.345	2.704	N/A	N/A	
	Ebn at Noon	0	62	535	741	798	833	794	736	576	92	0	0	
	Edh at Noon	0	7	61	101	118	104	85	66	43	10	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.04	1.03	3.55	5.46	5.94	4.30	2.27	0.81	0.11	0.00	0.00	
	RadStd	0.00	0.01	0.10	0.26	0.31	0.49	0.55	0.33	0.13	0.01	0.00	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page