

MYS ZHELANIYA, Russian Federation

WMO: 203530

Lat: 76.951N

Lon: 68.545E

Elev: 8

StdP: 101.23

Time Zone: 3.00 (E03)

Period: 86-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.0	-31.7	-35.5	0.1	-32.8	-34.0	0.2	-31.5	22.5	-14.7	21.3	-17.5	6.2	290	1.217

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.8	8.6	6.2	6.8	5.0	5.5	4.1	6.5	8.5	5.2	6.5	4.2	5.3	5.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.8	5.3	6.8	3.9	5.0	5.7	3.1	4.7	4.9	21.7	8.6	19.0	6.6	17.3	5.4	13.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.3	19.1	16.7	DB	-33.6	13.0	4.6	2.2	-36.9	14.5	-39.6	15.8	-42.2	17.1	-45.5	18.7	(4)
(5)			WB	-33.7	9.2	4.5	2.1	-37.0	10.7	-39.6	11.9	-42.2	13.0	-45.5	14.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.1	-19.4	-19.3	-17.5	-14.6	-6.5	-0.7	2.1	2.4	0.5	-6.0	-13.0	-17.9
	DBStd	10.26	7.51	8.42	8.13	7.16	4.13	2.31	2.10	2.15	2.86	5.15	7.20	8.08
	HDD10.0	6969	911	820	852	738	512	321	245	234	286	496	689	865
	HDD18.3	10011	1169	1053	1110	988	771	571	503	493	536	754	939	1123
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.4	8.4	8.3	8.6	7.4	6.7	6.2	6.3	6.1	6.4	7.3	7.9	8.7
Precipitation	PrecAvg	451	33	33	30	27	27	31	41	54	51	56	35	33
	PrecMax	649	63	66	65	53	50	61	106	87	87	94	73	69
	PrecMin	262	15	12	13	9	16	11	13	13	22	22	11	8
	PrecStd	93	12	12	12	9	8	12	19	17	17	16	16	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.5	-0.8	-0.4	2.6	4.2	7.8	12.1	12.0	9.5	3.5	1.1	0.2
		MCWB	-1.3	-1.3	-1.3	1.4	2.0	5.1	8.1	8.3	7.1	2.4	0.3	-1.1
	2%	DB	-2.6	-2.4	-1.6	-0.8	1.4	5.0	9.0	8.0	7.1	2.1	-0.2	-1.3
		MCWB	-3.5	-3.1	-2.4	-1.7	0.2	3.4	6.3	5.8	5.1	1.2	-1.0	-2.3
	5%	DB	-4.1	-4.1	-2.9	-2.5	-0.2	3.2	6.6	6.4	5.3	0.8	-1.4	-2.9
		MCWB	-4.7	-4.8	-3.7	-3.3	-1.0	2.0	4.7	5.0	4.0	0.0	-2.0	-3.8
	10%	DB	-7.4	-6.4	-4.9	-3.9	-1.2	2.0	5.1	5.3	4.2	0.0	-2.7	-4.8
		MCWB	-8.2	-7.1	-5.7	-4.7	-1.9	1.0	3.7	4.2	3.3	-0.7	-3.5	-5.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.4	-1.3	-0.9	1.6	2.1	5.6	9.5	8.4	7.3	2.6	0.5	-0.8
		MCDB	-0.6	-0.9	-0.4	2.7	3.7	7.7	11.5	10.8	9.2	3.3	1.0	0.1
	2%	WB	-3.4	-3.1	-2.3	-1.5	0.4	3.5	6.6	6.1	5.3	1.2	-0.8	-2.2
		MCDB	-2.7	-2.6	-1.7	-0.9	1.3	4.9	9.0	7.6	6.7	1.9	-0.3	-1.4
	5%	WB	-4.9	-4.8	-3.8	-3.2	-0.9	2.1	4.9	5.1	4.2	0.1	-1.9	-3.7
		MCDB	-4.0	-4.1	-3.0	-2.5	-0.3	3.1	6.3	6.2	5.2	0.7	-1.3	-2.9
	10%	WB	-8.2	-7.1	-5.6	-4.8	-1.9	1.1	3.8	4.4	3.4	-0.7	-3.5	-5.6
		MCDB	-7.5	-6.4	-4.9	-4.0	-1.3	1.8	5.0	5.3	4.3	0.0	-2.8	-4.8
Mean Daily Temperature Range	5% DB	MDBR	5.7	5.9	6.1	6.1	3.6	2.6	3.0	2.8	2.7	3.7	4.7	5.2
		MCDBR	6.6	7.9	7.9	7.7	5.1	4.8	6.5	5.2	4.2	4.4	5.6	4.6
		MCWBR	6.5	7.9	7.8	7.2	4.4	3.7	4.7	3.8	3.1	4.4	5.5	4.4
	5% WB	MCDBR	6.5	8.0	8.2	7.5	4.9	4.6	6.1	4.8	3.9	4.3	5.4	4.6
		MCWBR	6.5	7.9	8.2	7.2	4.4	3.6	4.8	3.7	2.9	4.3	5.4	4.4
Clear-Sky Solar Irradiance	taub	N/A	0.196	0.269	0.298	0.323	0.316	0.336	0.325	0.280	0.360	N/A	N/A	
	taud	N/A	1.877	1.998	2.062	2.099	2.286	2.368	2.404	2.317	2.699	N/A	N/A	
	Ebn at Noon	0	87	548	747	798	835	796	739	591	119	0	0	
	Edh at Noon	0	9	60	96	112	98	87	71	46	12	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.04	0.94	3.17	4.63	5.24	4.05	2.36	0.91	0.13	0.00	0.00	
	RadStd	0.00	0.01	0.16	0.43	0.56	0.82	0.52	0.23	0.07	0.01	0.00	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page