

RUSSKAYA GAVAN, Russian Federation

WMO: 203570

Lat: 76.189N

Lon: 62.597E

Elev: 30

StdP: 14.68

Time Zone: 3.00 (E03)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-27.1	-23.1	-33.1	0.8	-26.6	-29.4	1.1	-23.0	62.5	-10.2	53.1	2.6	5.2	270	1.107

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	52.5	45.9	49.2	43.8	46.4	41.9	46.4	51.6	44.2	48.7	42.2	45.8	8.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
42.3	39.9	48.2	40.4	36.9	45.7	38.8	34.7	43.5	18.4	51.8	17.2	49.1	16.3	45.9	59.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.0	40.7	35.0	-29.6	58.5	4.3	4.3	-32.7	61.6	-35.2	64.1	-37.6	66.5	-40.8	69.7		
(5)			-29.8	50.5	4.3	3.9	-32.9	53.3	-35.4	55.6	-37.8	57.8	-40.9	60.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	0.6	0.2	4.3	5.4	22.2	33.4	38.9	38.6	34.0	21.6	10.7	3.0	
	DBStd	17.93	12.90	14.63	13.31	13.28	7.54	6.07	5.45	4.43	5.19	8.98	11.43	11.19	
	HDD50	11744	1532	1394	1418	1339	861	500	347	355	479	882	1180	1457	
	HDD65	17213	1997	1814	1883	1789	1326	949	808	819	929	1347	1630	1922	
	CDD50	6	0	0	0	0	0	1	4	1	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	12.9	15.7	13.8	15.2	11.2	10.7	10.6	10.3	9.1	12.1	13.4	15.6	17.0	
Precipitation	PrecAvg	19.7	1.8	1.6	1.3	1.2	1.0	1.3	1.7	2.1	2.0	2.3	1.7	1.7	
	PrecMax	28.1	3.5	3.2	2.8	2.1	1.9	2.7	4.3	3.8	4.1	4.5	3.8	3.3	
	PrecMin	9.3	0.8	0.5	0.6	0.1	0.6	0.4	0.4	0.2	0.7	1.0	0.7	0.7	
	PrecStd	5.1	0.6	0.7	0.6	0.5	0.4	0.6	0.8	0.8	0.8	0.9	0.7	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	31.2	32.4	39.6	40.2	54.2	56.7	55.3	48.0	42.4	34.6	31.4	
		MCWB	29.0	29.5	30.4	34.1	35.9	46.0	49.5	47.0	43.4	38.7	32.1	29.9	
	2%	DB	28.7	29.2	29.9	33.2	37.1	49.9	53.1	49.9	44.9	38.4	32.9	27.8	
		MCWB	26.9	27.7	28.7	30.4	33.3	43.4	46.6	44.3	41.0	36.0	31.1	25.9	
	5%	DB	25.3	26.2	28.0	30.5	34.8	45.0	50.3	46.9	42.8	35.6	31.0	24.4	
		MCWB	23.4	24.4	26.6	28.1	31.5	39.8	44.7	42.3	39.3	33.3	29.2	22.5	
	10%	DB	21.0	22.2	24.8	26.3	32.4	41.7	47.8	44.4	41.2	32.9	28.1	20.2	
		MCWB	19.4	20.6	23.1	24.1	29.7	37.4	42.9	40.8	38.3	30.5	26.2	18.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.8	30.2	31.0	33.9	35.9	46.9	50.9	47.6	43.5	38.6	33.0	30.4
			MCDB	31.0	31.0	32.1	39.1	39.7	53.0	55.8	52.9	46.8	41.0	33.7	31.6
2%		WB	26.8	27.7	28.9	31.0	33.7	43.3	47.4	44.8	41.3	36.2	31.3	26.2	
		MCDB	28.7	29.2	29.7	33.2	36.5	49.4	52.2	49.3	44.4	38.1	32.7	27.5	
5%		WB	23.7	24.5	26.8	28.2	31.8	40.0	45.3	42.9	39.7	33.6	29.4	22.8	
		MCDB	25.3	26.2	28.0	30.3	34.4	44.4	50.1	45.6	42.1	35.6	31.1	24.4	
10%		WB	19.3	20.7	23.2	24.0	29.9	37.6	43.2	41.3	38.6	30.6	26.1	18.6	
		MCDB	21.0	22.3	24.7	26.2	32.3	41.1	47.4	44.0	40.8	32.8	28.3	20.2	
Mean Daily Temperature Range	5% DB	MDBR	11.1	10.7	13.6	13.1	7.7	6.3	6.2	5.7	5.8	7.7	8.9	10.2	
		MCDBR	13.3	12.8	14.9	15.5	9.0	11.2	10.3	10.3	7.4	10.4	9.9	12.4	
		MCWBR	12.8	12.8	14.2	13.2	7.8	7.6	7.3	6.6	5.8	9.3	9.9	11.7	
	5% WB	MCDBR	13.6	12.5	15.1	15.7	8.9	10.8	10.2	8.6	7.0	10.4	8.6	13.1	
		MCWBR	13.2	12.7	14.6	14.4	7.8	7.6	7.7	6.2	5.8	9.5	9.1	12.6	
Clear-Sky Solar Irradiance	taub	N/A	0.193	0.265	0.294	0.321	0.312	0.326	0.310	0.265	0.188	N/A	N/A		
	taud	N/A	1.873	2.016	2.070	2.094	2.227	2.273	2.316	2.260	1.931	N/A	N/A		
	Ebn at Noon	0	44	185	242	256	267	256	240	197	38	0	0		
	Edh at Noon	0	4	20	31	36	33	30	24	16	3	0	0		
All-Sky Solar Radiation	RadAvg	0	18	319	1020	1602	1769	1445	879	372	62	0	0		
	RadStd	0	2	41	115	186	206	132	80	25	5	0	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page