

IZVESTIJ TSIK, Russian Federation

WMO: 204710

Lat: 75.952N

Lon: 82.946E

Elev: 12

StdP: 101.18

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-35.8	-34.0	-38.8	0.1	-35.7	-36.9	0.1	-33.9	15.7	-18.9	14.0	-17.0	3.1	60	1.153

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.2	8.6	7.7	7.5	6.9	6.5	5.9	7.9	8.5	7.0	7.4	6.0	6.5	5.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.4	6.4	8.1	6.5	6.0	7.3	5.6	5.6	6.4	24.6	8.5	22.7	7.5	20.7	6.5	10.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.5	12.1	DB	-35.9	9.4	3.8	2.8	-38.7	11.5	-40.9	13.1	-43.0	14.7	-45.8	16.8	(4)
(5)			WB	-36.0	7.9	3.8	2.3	-38.8	9.5	-41.0	10.8	-43.1	12.1	-45.8	13.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.8	-22.4	-23.0	-19.9	-15.3	-7.7	-0.3	2.3	3.3	1.6	-3.9	-14.2	-19.3
	DBStd	11.02	7.19	7.10	7.17	5.08	4.08	1.47	2.49	2.22	2.26	4.11	6.45	6.34
	HDD10.0	7234	1004	924	926	759	550	310	238	208	253	431	724	908
	HDD18.3	10276	1263	1157	1184	1009	808	560	496	466	503	689	974	1166
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.0	5.6	5.4	6.0	5.4	5.9	5.8	5.6	6.1	6.5	7.1	6.4	6.5
Precipitation	PrecAvg	294	14	14	13	11	11	24	34	50	47	39	20	17
	PrecMax	469	39	36	35	40	25	63	102	92	92	95	48	37
	PrecMin	102	0	1	1	0	4	11	10	15	15	7	3	2
	PrecStd	83	8	9	8	8	5	11	19	20	21	20	12	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.6	-5.0	-1.6	0.1	0.5	4.5	10.4	9.8	7.6	3.4	-1.2	-2.3
		MCWB	-0.7	-5.1	-1.8	-0.2	-0.1	3.6	9.0	8.6	7.3	2.7	-1.5	-2.7
	2%	DB	-4.6	-7.0	-3.0	-3.5	-0.4	3.4	9.0	8.4	6.6	2.7	-2.5	-3.9
		MCWB	-4.7	-7.2	-3.2	-4.0	-0.8	2.8	7.9	7.7	6.2	2.2	-2.9	-4.1
	5%	DB	-8.4	-9.9	-5.4	-6.0	-1.1	2.6	7.8	7.6	5.7	2.0	-3.9	-6.5
		MCWB	-8.6	-10.1	-5.5	-6.6	-1.5	2.1	6.9	7.0	5.4	1.6	-4.3	-6.7
	10%	DB	-12.5	-12.6	-7.6	-7.9	-1.9	1.8	6.5	6.7	4.9	1.0	-5.2	-9.3
		MCWB	-12.7	-12.8	-7.8	-8.2	-2.3	1.3	5.8	6.2	4.5	0.6	-5.7	-9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.6	-5.1	-1.7	-0.1	0.2	3.8	9.5	8.7	7.4	3.1	-1.5	-2.4
		MCDB	-0.6	-4.9	-1.6	0.1	0.4	4.3	10.2	9.3	7.5	3.2	-1.4	-2.3
	2%	WB	-4.6	-7.1	-3.3	-4.0	-0.9	2.9	8.0	7.9	6.3	2.2	-3.0	-4.2
		MCDB	-4.5	-6.9	-3.1	-3.6	-0.7	3.3	8.9	8.3	6.5	2.5	-2.7	-4.0
	5%	WB	-8.6	-10.1	-5.5	-6.5	-1.6	2.2	7.0	7.1	5.5	1.7	-4.3	-6.7
		MCDB	-8.4	-9.8	-5.4	-6.0	-1.3	2.5	7.8	7.5	5.7	2.0	-3.9	-6.5
	10%	WB	-12.7	-12.8	-7.7	-8.2	-2.5	1.5	5.8	6.2	4.6	0.6	-5.7	-9.6
		MCDB	-12.5	-12.6	-7.5	-7.7	-2.1	1.7	6.5	6.6	4.9	0.9	-5.3	-9.3
Mean Daily Temperature Range	5% DB	MDBR	5.7	5.8	6.1	5.6	3.9	2.1	2.7	2.2	1.8	2.4	4.9	5.2
		MCDBR	7.6	9.0	6.6	5.5	3.3	2.9	4.4	3.2	2.0	1.8	4.8	7.3
		MCWBR	7.8	9.1	6.6	5.5	3.3	2.6	3.9	2.8	2.0	1.8	4.8	7.3
	5% WB	MCDBR	7.7	9.0	6.4	5.6	3.4	2.7	4.4	3.2	2.1	1.5	5.0	7.3
		MCWBR	7.8	9.1	6.5	5.5	3.3	2.5	3.9	2.9	2.1	1.7	5.0	7.3
Clear-Sky Solar Irradiance	taub	N/A	0.184	0.267	0.298	0.319	0.319	0.347	0.336	0.296	0.355	N/A	N/A	
	taud	N/A	1.843	1.941	1.989	2.041	2.256	2.352	2.448	2.376	2.698	N/A	N/A	
	Ebn at Noon	0	162	571	753	808	837	790	741	604	178	0	0	
	Edh at Noon	0	14	68	106	121	102	90	70	47	14	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.07	1.22	3.68	5.56	5.83	4.47	2.46	0.93	0.15	0.00	0.00	
	RadStd	0.00	0.01	0.10	0.23	0.32	0.62	0.59	0.35	0.10	0.02	0.00	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page