

MYS MENSHIKOVA, Russian Federation

WMO: 209430

Lat: 70.719N

Lon: 57.563E

Elev: 46

StdP: 14.67

Time Zone: 3.00 (E03)

Period: 82-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.3	-23.5	-31.9	0.9	-26.6	-28.6	1.1	-23.5	36.8	21.7	33.4	17.0	9.5	340	1.102

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.9	52.1	50.1	49.3	47.3	47.3	45.6	50.3	52.0	47.7	49.0	45.8	47.0	10.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.2	51.9	51.1	46.8	47.3	48.6	44.8	43.8	46.6	20.5	52.0	19.1	49.1	18.1	47.2	60.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.8	31.8	28.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.7	-1.4	0.8	7.1	9.2	23.2	33.9	40.1	40.5	38.8	27.7	18.6	8.9		
	DBStd	18.03	14.86	15.68	13.44	12.38	7.47	4.92	5.10	5.23	3.08	7.37	10.68	11.83		
	HDD50	10690	1593	1379	1331	1223	831	482	312	298	336	690	941	1274		
	HDD65	16158	2058	1799	1796	1673	1296	932	773	760	786	1155	1391	1739		
	CDD50	7	0	0	0	0	0	0	4	3	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	14.6	14.9	14.9	14.5	13.4	13.5	12.2	12.6	13.1	14.8	17.0	17.1	16.9		
	PrecAvg	16.8	1.0	1.0	0.8	0.7	0.8	1.1	1.4	1.8	2.2	2.5	1.9	1.6		
Precipitation	PrecMax	23.5	2.4	2.0	1.9	1.9	1.9	2.4	2.8	3.7	4.6	4.2	4.3	3.6		
	PrecMin	7.0	0.1	0.0	0.0	0.0	0.1	0.4	0.1	0.9	0.6	1.1	0.4	0.3		
	PrecStd	3.9	0.7	0.6	0.5	0.4	0.4	0.5	0.7	0.6	1.0	0.9	0.9	0.8		
	PrecStd	3.9	0.7	0.6	0.5	0.4	0.4	0.5	0.7	0.6	1.0	0.9	0.9	0.8		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.4	33.3	33.0	34.1	35.9	50.9	60.7	55.5	47.7	42.1	34.3	31.5		
		MCWB	29.3	31.9	31.5	32.5	34.4	47.5	55.7	52.2	45.1	40.6	33.4	30.4		
	2%	DB	28.6	29.5	31.2	32.8	34.2	45.9	52.9	52.4	46.0	40.6	33.3	29.6		
		MCWB	27.4	28.7	30.3	31.7	33.1	43.8	50.9	50.3	44.8	39.7	32.4	28.4		
	5%	DB	26.1	27.0	29.4	31.6	33.4	43.1	49.4	49.7	44.8	38.8	32.8	28.1		
		MCWB	25.1	26.1	28.5	30.8	32.4	41.0	47.5	47.8	43.9	38.1	32.0	27.2		
	10%	DB	22.7	24.4	27.2	29.5	32.4	40.5	47.5	47.7	43.4	36.9	31.9	26.2		
		MCWB	21.8	23.5	26.2	28.6	31.5	38.9	45.8	45.9	42.5	36.2	31.2	25.2		
	0.4%	WB	29.7	32.3	32.1	33.1	34.8	48.4	56.4	53.0	46.2	41.2	33.9	30.6		
		MCDB	30.2	33.3	32.8	33.6	35.6	50.2	59.5	54.5	46.8	41.6	34.0	31.3		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.6	28.8	30.4	32.0	33.5	44.2	51.1	50.2	45.2	39.6	33.0	28.6		
		MCDB	28.4	29.4	31.1	32.6	33.9	46.0	53.0	51.9	45.8	40.2	33.2	29.3		
	5%	WB	25.2	26.3	28.6	30.7	32.7	41.3	47.8	48.4	44.0	38.0	32.2	27.2		
		MCDB	26.2	27.1	29.4	31.5	33.2	42.7	49.0	49.6	44.6	38.6	32.6	28.0		
	10%	WB	21.7	23.5	26.2	28.6	31.7	38.8	45.9	46.3	42.7	36.3	31.3	25.2		
		MCDB	22.7	24.3	27.2	29.5	32.4	40.2	47.3	47.4	43.3	36.9	31.8	26.2		
Mean Daily Temperature Range	5% DB	MDBR	11.9	12.3	12.4	13.0	7.9	5.4	5.9	4.9	4.1	7.2	8.3	11.6		
		MCDBR	15.1	14.1	11.3	11.0	5.9	10.0	10.2	7.9	6.5	7.0	5.5	12.9		
		MCWBR	15.5	14.2	11.5	11.0	5.6	8.2	8.4	6.1	5.8	6.7	5.4	13.0		
		MCDBR	15.2	14.0	11.5	10.8	5.3	9.7	9.7	7.8	5.3	6.1	5.4	12.2		
	5% WB	MCWBR	15.5	14.2	11.7	10.9	5.4	8.4	8.5	6.3	5.2	6.1	5.6	12.2		
		taub	N/A	0.239	0.287	0.317	0.333	0.333	0.366	0.348	0.314	0.257	N/A	N/A		
		taud	N/A	1.940	2.024	2.056	2.108	2.282	2.370	2.459	2.461	2.145	N/A	N/A		
		Ebn at Noon	0	132	215	252	264	270	255	246	220	129	0	0		
All-Sky Solar Radiation	RadAvg	0	82	538	1210	1759	1849	1575	973	471	115	0	0	0		
	RadStd	0	16	64	102	163	187	192	92	33	15	0	0	0		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+3.10	+5.00	+6.05	+2.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page