

OSTROV ZHOKHOVA, Russian Federation

WMO: 213580

Lat: 76.150N

Lon: 152.833E

Elev: 14

StdP: 101.16

Time Zone: 10.00 (E10)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -37.9	(c) -36.5	(d) -40.3	(e) 0.1	(f) -37.6	(g) -38.8	(h) 0.1	(i) -36.4	(j) 15.8	(k) -22.4	(l) 14.1	(m) -23.0	(n) 2.2	(o) 170	(p) 1.205

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 2.2	(c) 5.3	(d) 4.4	(e) 4.3	(f) 3.5	(g) 3.3	(h) 2.5	(i) 4.6	(j) 5.2	(k) 3.6	(l) 4.2	(m) 2.6	(n) 3.2	(o) 6.4	(p) 190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 4.2	(b) 5.1	(c) 5.0	(d) 2.9	(e) 4.7	(f) 4.1	(g) 1.8	(h) 4.3	(i) 2.9	(j) 18.0	(k) 5.2	(l) 16.0	(m) 4.4	(n) 14.2	(o) 3.3	(p) 11.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.3	12.1	10.8	-39.2	7.0	1.9	3.1	-40.6	9.3	-41.7	11.1	-42.8	12.8	-44.2	15.1
			-39.5	5.3	1.9	2.6	-40.8	7.2	-41.9	8.7	-43.0	10.2	-44.3	12.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-14.8	-28.5	-28.3	-27.1	-20.2	-8.8	-1.4	1.1	0.3	-3.4	-13.3	-22.4	-26.4
	DBStd	12.20	4.22	4.47	4.45	5.49	4.18	2.12	1.53	2.19	3.58	5.74	5.29	4.91
	HDD10.0	9049	1193	1072	1151	907	584	341	275	301	403	721	973	1128
	HDD18.3	12091	1451	1306	1409	1157	843	591	533	559	653	979	1223	1386
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.2	4.9	4.6	4.8	5.1	5.1	5.5	5.7	5.8	6.2	5.4	4.8	5.0
Precipitation	PrecAvg	203	8	7	6	7	10	18	30	38	34	23	12	8
	PrecMax	278	20	29	17	20	23	37	60	73	74	42	26	21
	PrecMin	131	0	0	0	0	3	6	8	15	14	10	4	1
	PrecStd	39	5	6	4	5	5	8	13	16	13	8	5	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-14.8	-15.3	-12.4	-4.7	0.3	4.5	8.1	7.4	3.5	-0.8	-6.1	-9.6
		MCWB	-15.0	-15.6	-12.6	-4.9	-0.5	3.0	5.6	6.6	2.2	-1.1	-6.5	-10.2
	2%	DB	-17.3	-18.4	-16.2	-8.2	-0.5	2.6	5.7	5.3	1.8	-2.5	-10.0	-14.7
		MCWB	-17.6	-18.7	-16.4	-8.6	-1.1	1.5	4.5	4.7	1.1	-3.1	-10.6	-14.9
	5%	DB	-19.3	-20.5	-19.0	-10.3	-1.5	1.6	4.4	4.5	1.2	-3.5	-12.6	-17.3
		MCWB	-19.5	-20.7	-19.1	-10.7	-2.1	0.8	3.4	3.9	0.5	-4.0	-13.1	-17.6
	10%	DB	-21.8	-22.2	-21.0	-12.4	-2.9	1.0	3.3	3.6	0.7	-5.0	-14.8	-19.3
		MCWB	-22.0	-22.3	-21.2	-12.7	-3.4	0.2	2.5	3.0	0.1	-5.6	-15.2	-19.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-15.0	-15.4	-12.6	-5.1	-0.2	3.2	6.4	6.7	2.5	-1.1	-6.6	-9.7
		MCDB	-14.8	-15.2	-12.4	-5.0	0.1	4.1	7.9	7.0	3.5	-0.7	-6.3	-9.0
	2%	WB	-17.5	-18.6	-16.3	-8.5	-1.0	1.8	4.6	4.9	1.3	-3.0	-10.4	-14.9
		MCDB	-17.4	-18.4	-16.1	-8.3	-0.6	2.4	5.5	5.3	1.7	-2.7	-10.1	-14.7
	5%	WB	-19.5	-20.7	-19.2	-10.6	-2.1	1.0	3.6	4.0	0.7	-4.0	-12.9	-17.5
		MCDB	-19.4	-20.5	-19.0	-10.2	-1.5	1.4	4.3	4.4	1.1	-3.5	-12.5	-17.3
	10%	WB	-21.9	-22.3	-21.1	-12.8	-3.4	0.4	2.6	3.1	0.2	-5.5	-15.3	-19.5
		MCDB	-21.8	-22.2	-21.0	-12.5	-2.9	0.8	3.3	3.5	0.6	-5.0	-14.9	-19.4
Mean Daily Temperature Range	5% DB	MDBR	4.8	4.5	4.9	5.7	3.7	2.2	2.2	2.2	3.1	5.0	5.0	4.8
		MCDBR	7.1	6.4	7.5	6.5	4.0	2.7	4.0	3.7	2.2	4.8	7.7	7.5
		MCWBR	7.0	6.3	7.5	6.3	4.0	2.4	3.4	3.4	2.2	4.8	7.6	7.3
	5% WB	MCDBR	7.2	6.4	7.7	6.5	3.6	2.5	3.8	3.3	2.2	4.8	7.7	7.5
		MCWBR	7.1	6.4	7.6	6.3	3.6	2.5	3.4	3.2	2.3	4.9	7.7	7.4
Clear-Sky Solar Irradiance	taub	N/A	0.164	0.255	0.302	0.326	0.314	0.338	0.342	0.286	N/A	N/A	N/A	N/A
	taud	N/A	1.867	1.967	1.959	2.012	2.174	2.276	2.365	2.357	N/A	N/A	N/A	N/A
	Ebn at Noon	0	186	590	742	795	837	794	724	610	N/A	0	0	0
	Edh at Noon	0	12	65	109	124	110	96	75	47	N/A	0	0	0
All-Sky Solar Radiation	RadAvg	0.00	0.07	1.25	3.69	5.61	6.55	5.10	2.79	1.01	0.17	0.00	0.00	0.00
	RadStd	0.00	0.01	0.07	0.25	0.31	0.50	0.56	0.43	0.16	0.02	0.00	0.00	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page