

PRONCHISHCHEVOY, Russian Federation

WMO: 214050

Lat: 75.533N

Lon: 113.517E

Elev: 20

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.3	-38.4	-44.9	0.4	-41.0	-41.9	0.5	-38.3	32.6	-17.2	30.0	-10.8	5.7	20	1.155

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	54.2	49.4	49.6	46.1	46.2	43.4	50.0	53.2	46.2	49.5	43.5	46.0	10.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
47.6	48.7	53.0	43.7	42.0	48.0	41.0	37.9	45.0	20.4	53.1	18.3	49.7	16.9	46.1	67.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.1	27.9	25.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-20.5	-20.6	-17.1	-7.0	14.9	31.7	39.0	37.6	29.8	9.6	-12.0	-16.5	
	DBStd	24.75	12.00	11.21	11.24	10.73	7.46	6.26	4.98	5.42	6.42	10.88	9.19	10.66	
	HDD50	16107	2185	1977	2079	1709	1089	550	346	389	607	1254	1861	2061	
	HDD65	21573	2650	2397	2544	2159	1554	1000	806	850	1057	1719	2311	2526	
	CDD50	8	0	0	0	0	0	0	4	4	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	10.5	9.2	8.6	9.9	10.9	11.7	11.2	10.6	11.0	10.7	11.7	10.0	9.8	
Precipitation	PrecAvg	10.2	0.5	0.4	0.4	0.6	0.7	0.9	1.3	1.5	1.6	1.2	0.7	0.5	
	PrecMax	14.8	1.2	1.2	1.0	1.5	1.8	1.5	2.6	2.6	3.0	1.8	1.6	1.1	
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.2	0.3	0.6	0.6	0.7	0.4	0.2	0.1	
	PrecStd	2.6	0.3	0.3	0.3	0.4	0.3	0.4	0.5	0.6	0.6	0.4	0.3	0.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.7	15.4	22.2	27.1	36.5	52.4	65.0	61.5	47.1	32.8	19.7	20.3	
		MCWB	14.1	15.0	20.7	25.2	33.8	46.8	57.0	56.7	44.0	30.7	18.1	19.5	
	2%	DB	8.2	5.6	12.4	19.6	31.2	46.5	55.7	54.0	42.5	29.5	10.1	11.7	
		MCWB	7.0	4.6	11.1	18.1	29.6	42.6	49.9	50.2	39.9	28.1	9.4	11.1	
	5%	DB	2.8	0.9	4.9	14.4	28.1	42.1	50.5	49.4	39.7	27.3	4.4	5.1	
		MCWB	2.3	0.3	4.3	13.2	26.6	39.2	46.5	46.2	37.8	26.2	3.9	4.4	
	10%	DB	-2.3	-4.1	-0.8	9.8	25.6	38.7	47.1	45.7	37.7	25.0	0.4	-0.6	
		MCWB	-2.7	-4.7	-1.3	9.0	24.3	36.4	44.0	43.3	36.0	23.8	-0.2	-1.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	15.0	20.9	25.4	34.3	47.3	57.6	57.0	44.9	30.9	18.0	19.7
			MCDB	15.6	15.7	22.6	27.4	35.6	51.6	63.2	60.7	46.4	32.0	19.4	20.7
2%		WB	7.1	4.8	11.4	18.5	29.6	42.9	51.1	50.4	40.4	28.4	9.6	11.0	
		MCDB	8.3	5.6	12.7	19.8	31.3	46.2	54.7	53.6	42.0	29.5	10.5	11.7	
5%		WB	2.4	0.5	4.3	13.4	26.8	39.2	46.8	46.3	38.1	26.2	4.1	4.4	
		MCDB	3.0	1.0	5.1	14.3	28.0	42.0	50.4	49.1	39.8	27.2	4.5	4.9	
10%		WB	-2.6	-4.4	-1.5	9.0	24.5	36.7	43.9	43.5	36.2	23.7	-0.1	-1.1	
		MCDB	-2.2	-4.1	-1.0	9.9	25.7	38.4	46.8	45.6	37.8	24.9	0.3	-0.7	
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.2	10.5	12.0	7.6	5.9	8.5	7.0	6.2	8.6	9.1	9.7	
		MCDBR	16.4	15.6	18.2	16.5	8.2	11.9	16.5	15.1	9.3	8.2	14.1	14.2	
		MCWBR	16.2	15.0	17.6	15.7	7.3	9.3	12.8	11.8	7.5	7.9	13.7	13.9	
	5% WB	MCDBR	16.4	15.6	18.2	16.2	8.1	11.8	16.4	14.5	8.9	8.5	13.9	14.3	
		MCWBR	16.1	15.0	17.4	15.6	7.4	9.2	13.4	11.8	7.5	8.2	13.5	13.9	
Clear-Sky Solar Irradiance	taub	N/A	0.172	0.264	0.300	0.325	0.323	0.361	0.344	0.281	0.188	N/A	N/A		
	taud	N/A	1.878	2.003	2.048	2.075	2.275	2.333	2.403	2.372	1.945	N/A	N/A		
	Ebn at Noon	0	71	190	241	256	265	246	232	201	55	0	0		
	Edh at Noon	0	5	21	32	37	32	30	23	15	4	0	0		
All-Sky Solar Radiation	RadAvg	0	24	390	1147	1635	1745	1420	848	334	62	0	0		
	RadStd	0	3	25	81	91	180	155	105	29	6	0	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page