

PRONCHISHCHEVOY, Russian Federation

WMO: 214050

Lat: 75.533N

Lon: 113.517E

Elev: 6

StdP: 101.25

Time Zone: 7.00 (E07)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.7	-39.1	-42.7	0.1	-40.6	-41.1	0.1	-39.0	14.6	-27.3	13.4	-23.8	2.5	20	1.155

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	12.3	9.7	9.8	7.8	7.9	6.3	10.0	11.8	7.9	9.7	6.4	7.8	4.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
8.6	7.0	11.6	6.5	6.0	8.9	5.0	5.4	7.2	29.5	11.7	24.7	9.9	21.5	7.8	19.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.5	11.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-14.5	-29.2	-29.2	-27.3	-21.7	-9.5	-0.2	3.9	3.1	-1.2	-12.5	-24.5	-26.9
	DBStd	13.75	6.67	6.23	6.24	5.96	4.14	3.48	2.77	3.01	3.57	6.04	5.11	5.92
	HDD10.0	8948	1214	1098	1155	949	605	306	192	216	337	697	1034	1145
	HDD18.3	11985	1472	1332	1413	1199	863	556	448	472	587	955	1284	1403
	CDD10.0	4	0	0	0	0	0	0	2	2	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.7	4.1	3.8	4.4	4.9	5.2	5.0	4.7	4.9	4.8	5.2	4.5	4.4
Precipitation	PrecAvg	258	12	10	10	14	19	22	33	37	40	30	17	13
	PrecMax	377	30	30	26	37	46	39	66	67	75	46	40	27
	PrecMin	121	0	1	0	1	4	8	14	14	18	11	6	2
	PrecStd	65	8	7	7	9	8	9	12	15	14	9	8	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.0	-9.2	-5.4	-2.7	2.5	11.4	18.3	16.4	8.4	0.4	-6.8	-6.5
		MCWB	-10.0	-9.4	-6.3	-3.8	1.0	8.2	13.9	13.7	6.7	-0.7	-7.7	-7.0
	2%	DB	-13.2	-14.6	-10.9	-6.9	-0.5	8.1	13.2	12.2	5.8	-1.4	-12.2	-11.3
		MCWB	-13.9	-15.2	-11.6	-7.7	-1.3	5.9	9.9	10.1	4.4	-2.1	-12.6	-11.6
	5%	DB	-16.2	-17.3	-15.0	-9.8	-2.2	5.6	10.3	9.7	4.3	-2.6	-15.3	-14.9
		MCWB	-16.5	-17.6	-15.4	-10.5	-3.0	4.0	8.0	7.9	3.2	-3.2	-15.6	-15.4
	10%	DB	-19.1	-20.0	-18.2	-12.3	-3.5	3.7	8.4	7.6	3.2	-3.9	-17.5	-18.1
		MCWB	-19.3	-20.4	-18.5	-12.8	-4.3	2.4	6.7	6.3	2.2	-4.6	-17.9	-18.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.0	-9.4	-6.1	-3.6	1.3	8.5	14.2	13.9	7.2	-0.6	-7.8	-6.8
		MCDB	-9.1	-9.1	-5.2	-2.6	2.0	10.9	17.3	15.9	8.0	0.0	-7.0	-6.3
	2%	WB	-13.8	-15.1	-11.5	-7.5	-1.3	6.1	10.6	10.2	4.7	-2.0	-12.4	-11.7
		MCDB	-13.2	-14.7	-10.7	-6.8	-0.4	7.9	12.6	12.0	5.6	-1.4	-12.0	-11.3
	5%	WB	-16.4	-17.5	-15.4	-10.4	-2.9	4.0	8.2	8.0	3.4	-3.2	-15.5	-15.4
		MCDB	-16.1	-17.2	-15.0	-9.8	-2.2	5.5	10.2	9.5	4.3	-2.7	-15.3	-15.0
	10%	WB	-19.2	-20.2	-18.6	-12.8	-4.2	2.6	6.6	6.4	2.3	-4.6	-17.8	-18.4
		MCDB	-19.0	-20.0	-18.4	-12.3	-3.5	3.6	8.2	7.5	3.2	-4.0	-17.6	-18.2
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.7	5.9	6.7	4.2	3.3	4.7	3.9	3.5	4.8	5.0	5.4
		MCDBR	9.1	8.6	10.1	9.2	4.5	6.6	9.2	8.4	5.2	4.6	7.8	7.9
		MCWBR	9.0	8.3	9.8	8.7	4.1	5.1	7.1	6.5	4.2	4.4	7.6	7.7
	5% WB	MCDBR	9.1	8.6	10.1	9.0	4.5	6.5	9.1	8.1	4.9	4.7	7.7	7.9
		MCWBR	9.0	8.3	9.7	8.7	4.1	5.1	7.4	6.5	4.1	4.5	7.5	7.7
Clear-Sky Solar Irradiance	taub	N/A	0.172	0.264	0.300	0.325	0.323	0.361	0.344	0.281	0.188	N/A	N/A	
	taud	N/A	1.878	2.003	2.048	2.075	2.275	2.333	2.403	2.372	1.945	N/A	N/A	
	Ebn at Noon	0	225	599	761	806	835	777	732	635	172	0	0	
	Edh at Noon	0	15	65	101	118	101	93	74	48	12	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.08	1.23	3.62	5.16	5.50	4.48	2.67	1.05	0.19	0.00	0.00	
	RadStd	0.00	0.01	0.08	0.26	0.29	0.57	0.49	0.33	0.09	0.02	0.00	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page