

MYS SHALAUROVA, Russian Federation

WMO: 216470

Lat: 73.183N

Lon: 143.233E

Elev: 72

StdP: 14.66

Time Zone: 10.00 (E10)

Period: 90-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -41.1	(c) -38.9	(d) -44.2	(e) 0.4	(f) -40.3	(g) -41.8	(h) 0.5	(i) -38.5	(j) 33.5	(k) -9.9	(l) 30.2	(m) -9.0	(n) 6.1	(o) 270	(p) 1.176

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.6	(c) 51.6	(d) 48.8	(e) 48.0	(f) 45.9	(g) 44.9	(h) 43.2	(i) 49.2	(j) 51.4	(k) 46.1	(l) 47.9	(m) 43.4	(n) 44.7	(o) 7.6	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
47.6	49.0	50.9	44.6	43.6	47.1	42.1	39.6	44.5	19.9	51.2	18.2	48.0	16.9	44.8	62.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 31.6	(b) 27.4	(c) 23.7	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 31.6	(b) 27.4	(c) 23.7	(d) WB	(e) -44.2	(f) 53.0	(g) 3.0	(h) 4.4	(i) -46.3	(j) 56.1	(k) -48.1	(l) 58.7	(m) -49.8	(n) 61.1	(o) -52.0	(p) 64.3	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-23.6	-22.3	-18.9	-3.4	18.2	32.4	37.0	37.7	30.7	13.5	-9.0	-21.0
	DBStd	25.22	9.61	8.07	9.29	9.02	8.36	5.35	4.28	6.07	5.74	9.85	10.49	10.05
	HDD50	16024	2281	2023	2136	1602	987	529	403	385	578	1130	1769	2201
	HDD65	21494	2746	2443	2601	2052	1452	979	867	846	1028	1595	2219	2666
	CDD50	5	0	0	0	0	0	0	1	4	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	11.3	9.3	8.9	9.4	11.1	13.0	12.5	12.6	12.6	12.5	12.6	10.7	10.0
	PrecAvg	4.6	0.2	0.2	0.1	0.2	0.2	0.7	1.0	1.1	0.8	0.4	0.2	0.2
(15) Precipitation	PrecMax	7.4	0.9	0.6	0.4	1.1	1.1	1.8	3.7	3.1	1.9	1.1	0.6	0.9
	PrecMin	3.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.0	0.0
	PrecStd	1.5	0.2	0.2	0.1	0.2	0.2	0.5	0.7	0.7	0.4	0.2	0.2	0.2
	PrecStd	1.5	0.2	0.2	0.1	0.2	0.2	0.5	0.7	0.7	0.4	0.2	0.2	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	7.8	3.7	10.4	26.6	36.8	52.3	55.7	59.3	45.1	32.8	18.9	8.5	8.5
	0.4% MCWB	6.9	3.3	9.7	26.0	34.9	48.4	51.9	55.6	43.3	31.8	18.1	8.0	8.0
	2% DB	-0.8	-3.2	4.4	21.0	34.4	45.8	50.7	53.0	42.6	30.5	13.5	2.1	2.1
	2% MCWB	-1.4	-3.7	4.0	20.6	33.1	43.1	47.9	50.4	41.6	29.3	13.0	1.8	1.8
	5% DB	-5.2	-6.1	-0.6	14.1	32.6	41.9	46.9	49.4	39.9	28.7	9.0	-2.5	-2.5
	5% MCWB	-5.4	-6.4	-1.3	13.3	31.7	39.8	45.0	47.5	38.8	27.6	8.4	-3.3	-3.3
	10% DB	-9.3	-10.0	-4.4	9.9	30.3	38.7	43.6	45.8	37.7	26.1	5.3	-6.3	-6.3
	10% MCWB	-9.7	-10.3	-4.6	9.3	29.5	36.8	41.7	44.2	36.7	25.0	4.8	-6.7	-6.7
	0.4% WB	7.6	3.5	9.8	25.7	35.1	49.2	52.3	56.2	43.9	32.2	18.3	8.0	8.0
	0.4% MCDB	8.4	3.9	9.9	26.3	36.1	51.6	55.6	58.5	45.4	32.5	19.0	8.3	8.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	-1.2	-3.5	4.1	20.7	33.2	43.4	48.0	50.8	41.7	29.9	13.1	1.8	1.8
	2% MCDB	-0.8	-3.2	4.5	21.2	34.1	45.6	50.4	52.8	42.7	30.5	13.6	2.1	2.1
	5% WB	-5.5	-6.5	-0.9	13.6	31.7	40.0	45.3	47.4	38.9	27.4	8.4	-2.8	-2.8
	5% MCDB	-5.2	-6.2	-0.6	14.2	32.6	41.9	47.1	49.3	39.5	28.3	8.9	-2.3	-2.3
	10% WB	-9.6	-10.3	-4.8	9.3	29.6	36.9	41.9	44.4	36.9	25.1	4.9	-6.7	-6.7
	10% MCDB	-9.3	-10.0	-4.5	9.9	30.4	38.3	43.3	45.5	37.6	26.1	5.3	-6.3	-6.3
(35) Mean Daily Temperature Range	MDBR	10.3	10.1	10.1	12.0	8.7	6.4	7.0	5.6	4.8	7.6	9.9	9.3	9.3
	5% DB	13.7	14.7	16.8	16.0	8.5	11.9	13.7	10.3	5.9	6.3	13.4	12.8	12.8
	5% WB	13.6	14.6	16.5	15.8	7.8	9.7	11.1	7.7	5.2	6.2	13.3	12.7	12.7
	MCDBR	13.2	14.4	17.2	16.1	8.7	11.7	14.0	10.1	5.6	6.4	13.6	12.9	12.9
	MCWBR	13.1	14.4	16.8	15.9	8.1	9.8	11.6	7.7	5.1	6.4	13.4	12.8	12.8
	MCWBR	13.1	14.4	16.8	15.9	8.1	9.8	11.6	7.7	5.1	6.4	13.4	12.8	12.8
(40) Clear-Sky Solar Irradiance	taub	N/A	0.180	0.277	0.313	0.345	0.335	0.372	0.359	0.301	N/A	N/A	N/A	N/A
	taud	N/A	1.895	1.985	1.981	1.980	2.215	2.246	2.375	2.402	N/A	N/A	N/A	N/A
	Ebn at Noon	0	121	201	243	252	264	246	233	209	N/A	0	0	0
	Edh at Noon	0	9	24	36	43	35	33	26	17	N/A	0	0	0
(44) All-Sky Solar Radiation	RadAvg	0	43	473	1274	1866	1850	1518	892	410	94	0	0	0
	RadStd	0	5	18	52	95	147	108	111	41	15	0	0	0

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page