

MYS SHALAUROVA, Russian Federation

WMO: 216470

Lat: 73.183N

Lon: 143.233E

Elev: 22

StdP: 101.06

Time Zone: 10.00 (E10)

Period: 90-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -40.6	(c) -39.4	(d) -42.3	(e) 0.1	(f) -40.2	(g) -41.0	(h) 0.1	(i) -39.2	(j) 15.0	(k) -23.3	(l) 13.5	(m) -22.8	(n) 2.7	(o) 270	(p) 1.176

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.1	(c) 10.9	(d) 9.3	(e) 8.9	(f) 7.7	(g) 7.1	(h) 6.2	(i) 9.6	(j) 10.8	(k) 7.8	(l) 8.8	(m) 6.3	(n) 7.0	(o) 3.4	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
8.7	7.0	10.5	7.0	6.2	8.4	5.6	5.7	6.9	28.4	10.7	24.5	8.9	21.4	7.1	16.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.1	(b) 12.3	(c) 10.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 14.1	(b) 12.3	(c) 10.6	(e) -42.3	(f) 11.7	(g) 1.7	(h) 2.4	(i) -43.5	(j) 13.4	(k) -44.5	(l) 14.8	(m) -45.4	(n) 16.2	(o) -46.7	(p) 18.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-14.4	-30.9	-30.1	-28.3	-19.7	-7.7	0.2	2.8	3.2	-0.7	-10.3	-22.8	-29.4		
	DBStd	14.01	5.34	4.49	5.16	5.01	4.64	2.97	2.38	3.37	3.19	5.47	5.83	5.58		
	HDD10.0	8902	1267	1124	1187	890	548	294	224	214	321	628	983	1223		
	HDD18.3	11941	1526	1357	1445	1140	807	544	482	470	571	886	1233	1481		
	CDD10.0	3	0	0	0	0	0	0	1	2	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH27.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.0	4.2	4.0	4.2	4.9	5.8	5.6	5.6	5.6	5.6	5.6	4.8	4.5		
(15) Precipitation	PrecAvg	116	4	4	3	4	6	17	26	27	20	11	4	4		
	PrecMax	189	22	14	11	28	28	46	94	78	49	28	15	23		
	PrecMin	75	0	0	0	0	1	2	3	3	3	2	0	0		
	PrecStd	38	5	4	3	6	6	12	19	17	9	6	4	5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-13.5	-15.7	-12.0	-3.0	2.7	11.3	13.2	15.2	7.3	0.5	-7.3	-13.1		
		MCWB	-14.0	-15.9	-12.4	-3.4	1.6	9.1	11.1	13.1	6.3	-0.1	-7.7	-13.4		
	2%	DB	-18.2	-19.5	-15.3	-6.1	1.3	7.7	10.4	11.7	5.9	-0.8	-10.3	-16.6		
		MCWB	-18.5	-19.8	-15.6	-6.3	0.6	6.2	8.8	10.2	5.3	-1.5	-10.6	-16.8		
	5%	DB	-20.6	-21.2	-18.1	-10.0	0.3	5.5	8.3	9.7	4.4	-1.9	-12.8	-19.2		
		MCWB	-20.8	-21.3	-18.5	-10.4	-0.2	4.3	7.2	8.6	3.8	-2.5	-13.1	-19.6		
	10%	DB	-22.9	-23.3	-20.2	-12.3	-0.9	3.7	6.4	7.7	3.2	-3.3	-14.8	-21.3		
		MCWB	-23.1	-23.5	-20.4	-12.6	-1.4	2.7	5.4	6.8	2.6	-3.9	-15.1	-21.5		
	0.4%	WB	-13.6	-15.8	-12.4	-3.5	1.7	9.6	11.3	13.4	6.6	0.1	-7.6	-13.3		
		MCDB	-13.1	-15.6	-12.3	-3.2	2.3	10.9	13.1	14.7	7.4	0.3	-7.2	-13.2		
	2%	WB	-18.4	-19.7	-15.5	-6.3	0.6	6.3	8.9	10.4	5.4	-1.2	-10.5	-16.8		
		MCDB	-18.2	-19.6	-15.3	-6.0	1.1	7.5	10.2	11.5	6.0	-0.9	-10.2	-16.6		
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	-20.8	-21.4	-18.3	-10.2	-0.1	4.5	7.4	8.5	3.9	-2.6	-13.1	-19.3		
		MCDB	-20.7	-21.2	-18.1	-9.9	0.3	5.5	8.4	9.6	4.2	-2.0	-12.9	-19.1		
	10%	WB	-23.1	-23.5	-20.4	-12.6	-1.3	2.7	5.5	6.9	2.7	-3.8	-15.1	-21.5		
		MCDB	-23.0	-23.3	-20.3	-12.3	-0.9	3.5	6.3	7.5	3.1	-3.3	-14.8	-21.3		
	5% DB	MDBR	5.7	5.6	5.6	6.7	4.8	3.6	3.9	3.1	2.6	4.2	5.5	5.2		
		MCDBR	7.6	8.2	9.3	8.9	4.7	6.6	7.6	5.7	3.3	3.5	7.5	7.1		
(36) Mean Daily Temperature Range	5% WB	MCWBR	7.5	8.1	9.1	8.8	4.3	5.4	6.2	4.3	2.9	3.5	7.4	7.0		
		MCDBR	7.3	8.0	9.5	8.9	4.8	6.5	7.8	5.6	3.1	3.6	7.5	7.2		
	5% WB	MCWBR	7.3	8.0	9.3	8.8	4.5	5.4	6.5	4.3	2.8	3.5	7.5	7.1		
		MCDBR	7.3	8.0	9.3	8.8	4.5	5.4	6.5	4.3	2.8	3.5	7.5	7.1		
(40) Clear-Sky Solar Irradiance	taub		N/A	0.180	0.277	0.313	0.345	0.335	0.372	0.359	0.301	N/A	N/A	N/A		
	taud		N/A	1.895	1.985	1.981	1.980	2.215	2.246	2.375	2.402	N/A	N/A	N/A		
	Ebn at Noon		0	382	635	766	795	833	777	736	660	N/A	0	0		
	Edh at Noon		0	27	76	115	135	111	105	81	54	N/A	0	0		
(44) All-Sky Solar Radiation	RadAvg		0.00	0.14	1.49	4.01	5.88	5.83	4.78	2.81	1.29	0.30	0.00	0.00		
	RadStd		0.00	0.02	0.06	0.17	0.30	0.46	0.34	0.35	0.13	0.05	0.00	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page