

SASKYLAKH, Russian Federation

WMO: 218020

Lat: 71.967N

Lon: 114.083E

Elev: 56

StdP: 14.67

Time Zone: 9.00 (E09)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-58.6	-53.9	-62.8	0.1	-57.9	-58.1	0.2	-53.4	32.8	2.1	29.2	-6.2	1.6	160	0.962

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	76.1	61.8	70.5	58.6	65.7	55.8	63.0	73.7	59.6	69.2	56.7	64.5	8.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.1	72.3	68.2	54.9	64.2	64.6	51.8	57.3	61.2	28.6	74.0	26.2	69.0	24.3	64.7	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
25.2	20.5	18.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-60.9	82.3	4.8	6.1	-64.3	86.7	-67.1	90.2	-69.8	93.6	-73.2	98.0
			-61.8	65.9	6.0	3.4	-66.2	68.3	-69.7	70.3	-73.1	72.2	-77.4	74.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	-27.1	-30.8	-15.9	2.7	22.4	45.8	52.8	48.6	36.2	11.9	-13.1	-25.6
	DBStd	32.81	16.88	14.87	16.94	13.60	10.58	10.72	8.15	6.99	6.75	13.33	13.84	14.62
	HDD50	15186	2389	2264	2043	1418	856	207	60	112	417	1182	1894	2344
	HDD65	20381	2854	2684	2508	1868	1320	583	391	508	865	1647	2344	2809
	CDD50	299	0	0	0	0	1	80	146	70	2	0	0	0
	CDD65	20	0	0	0	0	0	7	12	1	0	0	0	0
	CDH74	209	0	0	0	0	0	76	119	14	0	0	0	0
	CDH80	33	0	0	0	0	0	13	20	0	0	0	0	0
	WSAvg	7.9	7.5	6.6	6.9	8.2	9.0	9.5	8.6	8.2	8.4	7.4	7.0	6.9
	PrecAvg	8.6	0.4	0.4	0.4	0.4	0.6	1.1	1.3	1.3	0.9	0.7	0.5	0.4
(15) Precipitation	PrecMax	12.7	0.9	1.9	1.2	1.1	1.9	3.1	3.8	3.9	2.1	1.3	1.3	1.1
	PrecMin	4.1	0.0	0.0	0.0	0.1	0.0	0.1	0.2	0.2	0.1	0.0	0.2	0.0
	PrecStd	2.2	0.2	0.3	0.2	0.3	0.4	0.7	0.9	0.8	0.5	0.3	0.3	0.2
	PrecStd	2.2	0.2	0.3	0.2	0.3	0.4	0.7	0.9	0.8	0.5	0.3	0.3	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.6	12.8	30.6	42.0	54.7	82.0	82.9	75.9	60.3	38.3	27.3	16.0
		MCWB	16.8	11.8	28.4	36.4	45.9	61.3	66.8	61.1	52.5	36.4	26.2	15.0
	2%	DB	7.4	3.5	24.6	34.6	45.8	75.0	78.0	70.5	53.2	34.0	18.6	10.3
		MCWB	6.5	2.9	22.7	31.1	40.1	60.1	64.3	58.0	47.4	32.3	17.4	9.5
	5%	DB	2.9	-3.4	18.6	28.9	41.4	68.1	71.9	65.5	48.5	31.0	11.6	3.0
		MCWB	2.0	-4.0	17.4	26.8	36.8	56.2	60.4	55.8	44.3	29.6	10.5	2.2
	10%	DB	-1.3	-8.8	10.9	22.8	37.3	62.5	66.9	60.6	45.0	28.4	6.5	-3.0
		MCWB	-1.9	-9.3	9.7	21.0	34.1	52.7	57.1	53.9	41.9	27.1	5.7	-3.7
	0.4%	WB	17.1	11.8	28.8	36.5	46.5	63.9	69.6	63.4	52.4	36.9	26.2	15.3
		MCDB	17.7	12.8	31.0	41.9	54.8	76.6	79.8	72.4	58.5	38.2	27.5	15.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	6.6	2.8	22.7	31.2	40.1	60.6	64.7	59.6	48.2	32.3	17.6	9.6
		MCDB	7.2	3.5	24.3	33.8	45.3	72.8	75.5	68.1	52.3	33.6	18.6	10.3
	5%	WB	2.1	-3.7	17.3	26.6	36.8	57.2	61.4	56.9	44.7	29.8	10.6	2.3
		MCDB	2.9	-3.1	18.6	28.9	41.0	67.7	70.4	63.8	48.1	31.0	11.6	3.0
	10%	WB	-1.9	-9.2	9.8	21.1	34.3	53.1	57.9	54.0	42.2	27.1	5.7	-3.5
		MCDB	-1.3	-8.6	11.0	22.8	37.2	62.1	66.0	60.1	44.8	28.3	6.5	-2.9
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.1	15.3	17.5	11.3	13.6	14.2	13.8	9.6	10.5	12.5	12.4
		MCDBR	16.9	18.7	16.7	20.4	15.3	22.5	22.5	22.8	16.9	10.2	15.4	17.9
		MCWBR	16.6	18.3	15.7	17.8	10.9	12.0	11.7	12.1	11.4	9.4	15.3	17.6
		MCDBR	16.8	19.2	16.8	20.9	13.8	22.1	21.0	19.7	15.2	9.8	15.3	17.9
	5% WB	MCWBR	16.5	18.8	15.7	18.5	10.1	12.9	12.3	12.1	10.9	9.4	15.2	17.6
		MCWBR	16.5	18.8	15.7	18.5	10.1	12.9	12.3	12.1	10.9	9.4	15.2	17.6
(40) Clear-Sky Solar Irradiance	taub		N/A	0.198	0.281	0.312	0.343	0.345	0.384	0.382	0.301	0.206	N/A	N/A
	taud		N/A	1.945	2.033	2.067	2.106	2.404	2.324	2.273	2.400	1.997	N/A	N/A
	Ebn at Noon		0	137	211	250	258	266	246	227	216	125	0	0
	Edh at Noon		0	10	24	35	38	30	31	29	18	9	0	0
(44) All-Sky Solar Radiation	RadAvg		0	68	527	1310	1819	1692	1531	989	442	116	0	0
	RadStd		0	6	25	57	119	131	114	132	54	17	0	0

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page