

CHOKURDAKH, Russian Federation

WMO: 219460

Lat: 70.617N

Lon: 147.883E

Elev: 61

StdP: 100.59

Time Zone: 11.00 (E11)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -44.5	(c) -42.5	(d) -46.8	(e) 0.0	(f) -44.3	(g) -44.9	(h) 0.0	(i) -42.4	(j) 11.8	(k) -24.4	(l) 10.1	(m) -26.3	(n) 2.5	(o) 230	(p) 0.984

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.9	(c) 23.6	(d) 16.0	(e) 20.6	(f) 14.7	(g) 17.9	(h) 12.9	(i) 16.7	(j) 22.3	(k) 15.0	(l) 19.7	(m) 13.3	(n) 17.6	(o) 3.9	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.1	19.2	12.4	9.0	18.0	10.6	8.0	15.8	47.1	22.3	42.2	19.7	37.6	17.8	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.0	9.2	8.0	-46.0	27.1	1.8	1.9	-47.3	28.4	-48.4	29.6	-49.4	30.6	-50.7	32.0
			-46.1	18.7	1.8	1.4	-47.4	19.8	-48.4	20.6	-49.4	21.4	-50.7	22.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-12.5	-33.0	-33.0	-26.7	-16.9	-5.0	6.6	10.2	8.2	1.7	-10.2	-23.0	-30.8		
	DBStd	16.96	5.35	5.54	6.51	6.40	5.65	5.49	4.93	4.29	3.69	5.95	6.50	6.16		
	HDD10.0	8354	1334	1203	1138	806	465	132	58	88	250	626	989	1265		
	HDD18.3	11276	1593	1436	1396	1056	723	354	257	315	499	884	1239	1523		
	CDD10.0	129	0	0	0	0	1	29	66	33	1	0	0	0		
	CDD18.3	9	0	0	0	0	0	2	6	1	0	0	0	0		
	CDH23.3	74	0	0	0	0	0	23	47	4	0	0	0	0		
	CDH26.7	7	0	0	0	0	0	2	6	0	0	0	0	0		
(14) Wind	WSAvg	3.8	3.4	3.5	3.4	3.6	4.1	4.5	4.4	4.0	3.8	3.6	3.7	3.6		
(15) Precipitation	PrecAvg	213	13	12	10	8	11	21	32	26	24	23	19	12		
	PrecMax	357	33	31	27	26	28	65	116	73	67	63	55	27		
	PrecMin	91	2	1	1	0	1	1	2	2	2	9	5	3		
	PrecStd	57	7	7	6	5	6	14	24	17	13	11	11	7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-16.4	-16.9	-6.9	0.3	13.4	26.3	27.1	24.2	15.0	0.7	-5.8	-11.9		
		MCWB	-16.7	-17.2	-7.5	-2.0	8.3	15.1	18.6	17.2	10.0	-0.2	-5.9	-12.3		
	2%	DB	-19.8	-20.1	-10.7	-2.5	8.0	22.6	24.5	21.0	11.4	-0.3	-8.6	-16.4		
		MCWB	-20.1	-20.3	-11.4	-4.0	4.5	13.9	16.9	14.6	8.1	-0.8	-8.9	-16.8		
	5%	DB	-22.5	-22.6	-14.2	-5.1	4.8	18.7	21.6	18.2	8.9	-1.3	-11.5	-19.0		
		MCWB	-22.7	-22.8	-14.8	-6.2	2.4	12.5	15.8	13.2	6.5	-1.8	-11.8	-19.3		
	10%	DB	-25.0	-24.7	-17.3	-7.6	2.7	15.6	18.7	15.5	6.6	-2.7	-14.0	-21.8		
		MCWB	-25.2	-24.9	-17.7	-8.5	0.9	10.6	14.1	11.8	5.1	-3.2	-14.3	-22.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-16.7	-17.2	-7.4	-1.8	8.3	16.3	19.2	17.5	10.8	0.2	-5.8	-12.2		
		MCDB	-16.6	-17.0	-7.0	-0.1	13.3	24.1	25.6	23.1	13.8	0.5	-5.7	-11.9		
	2%	WB	-20.1	-20.4	-11.3	-4.0	4.6	14.4	17.6	15.4	8.5	-0.7	-8.9	-16.7		
		MCDB	-19.9	-20.3	-10.7	-2.5	7.6	21.3	23.4	19.8	11.0	-0.3	-8.6	-16.4		
	5%	WB	-22.7	-22.8	-14.8	-6.2	2.5	12.6	16.0	13.5	6.6	-1.8	-11.7	-19.3		
		MCDB	-22.5	-22.6	-14.2	-5.2	4.6	18.3	21.0	17.3	8.6	-1.4	-11.4	-19.0		
	10%	WB	-25.2	-24.9	-17.7	-8.5	1.0	10.7	14.4	12.0	5.1	-3.3	-14.3	-22.0		
		MCDB	-25.0	-24.7	-17.3	-7.7	2.5	15.5	18.5	15.4	6.5	-2.8	-14.0	-21.8		
(35) Mean Daily Temperature Range	MDBR		6.0	5.8	6.7	7.9	6.2	8.1	7.9	7.1	4.5	4.6	5.9	6.0		
	5% DB	MCDBR	9.0	7.0	8.6	9.4	7.9	12.6	12.0	11.5	8.7	3.7	7.3	9.0		
		MCWBR	8.9	6.9	8.1	8.5	5.4	6.9	6.8	6.4	5.7	3.4	7.2	8.9		
	5% WB	MCDBR	9.0	7.0	8.6	9.2	7.7	12.3	11.3	10.4	8.0	3.7	7.3	8.9		
		MCWBR	8.9	6.9	8.1	8.4	5.3	7.2	6.9	6.4	5.6	3.4	7.3	8.8		
(40) Clear-Sky Solar Irradiance	taub		N/A	0.205	0.278	0.318	0.358	0.351	0.395	0.360	0.306	0.227	N/A	N/A		
	taud		N/A	2.013	2.074	2.055	2.137	2.427	2.303	2.383	2.431	2.069	N/A	N/A		
	Ebn at Noon		0	506	700	792	807	839	773	759	702	445	0	0		
	Edh at Noon		0	37	79	113	120	94	103	84	58	33	0	0		
(44) All-Sky Solar Radiation	RadAvg		0.00	0.30	1.91	4.33	5.95	5.57	4.70	3.22	1.50	0.46	0.00	0.00		
	RadStd		0.00	0.03	0.10	0.15	0.37	0.53	0.36	0.40	0.13	0.05	0.00	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.23	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page