

OSTROV VRANGELYA, Russian Federation

WMO: 219820

Lat: 70.983N

Lon: 178.650W

Elev: 15

StdP: 14.69

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-27.4	-24.4	-32.2	0.9	-27.0	-28.7	1.1	-23.7	53.0	-14.1	46.6	-5.5	4.5	50	1.073

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	48.3	44.8	45.8	43.4	43.9	42.0	45.6	47.5	43.8	45.4	42.3	43.7	10.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.2	42.9	45.9	42.6	40.2	44.5	41.0	37.8	43.0	17.9	47.6	17.1	45.5	16.3	43.9	57.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.7	35.2	30.5	-28.1	54.3	5.6	4.2	-32.1	57.4	-35.4	59.9	-38.5	62.3	-42.6	65.3		
(5)			-29.2	50.0	6.4	3.5	-33.8	52.5	-37.5	54.5	-41.1	56.5	-45.7	59.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	-5.5	-6.4	-5.5	4.4	22.4	34.2	38.2	37.4	33.7	25.0	12.2	-0.3	(6)
(7)		DBStd	19.18	10.08	11.13	11.00	9.59	8.49	4.22	3.55	4.05	4.86	7.45	10.70	10.80	(7)
(8)		HDD50	12427	1720	1579	1719	1368	855	474	365	391	488	775	1133	1560	(8)
(9)		HDD65	17902	2185	1999	2184	1818	1320	924	830	856	938	1240	1583	2025	(9)
(10)		CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	11.3	13.9	13.9	10.4	9.5	9.5	7.8	8.3	9.3	9.9	13.7	14.6	15.3	(14)
(15)	Precipitation	PrecAvg	5.8	0.4	0.4	0.2	0.3	0.4	0.4	0.8	0.9	0.6	0.6	0.5	0.4	(15)
(16)		PrecMax	8.3	1.0	1.1	1.1	0.7	1.0	1.3	2.0	2.0	2.8	1.7	1.5	1.1	(16)
(17)		PrecMin	2.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.1	0.0	0.0	(17)
(18)		PrecStd	1.5	0.2	0.3	0.3	0.2	0.2	0.3	0.5	0.6	0.6	0.4	0.4	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	28.1	27.8	32.3	41.7	50.0	54.2	50.8	46.6	43.3	32.6	28.5	(19)
(20)			MCWB	26.3	27.5	26.7	31.4	38.0	44.1	49.8	46.2	43.9	42.1	31.3	27.3	(20)
(21)		2%	DB	22.0	21.6	23.4	27.6	36.6	45.4	49.2	47.1	43.9	37.5	30.6	24.6	(21)
(22)			MCWB	21.1	20.7	22.5	26.4	34.8	41.7	45.7	44.6	42.6	36.6	29.4	23.7	(22)
(23)		5%	DB	15.4	15.3	17.6	21.8	34.3	42.5	46.4	45.1	42.2	35.3	29.2	20.7	(23)
(24)			MCWB	14.7	14.6	16.6	20.6	32.9	39.6	43.7	43.4	41.2	34.1	28.1	19.8	(24)
(25)		10%	DB	8.9	9.0	11.5	17.8	32.8	40.0	44.0	43.2	40.6	33.6	27.6	16.5	(25)
(26)			MCWB	8.0	8.2	10.7	16.8	31.7	37.6	41.8	41.9	39.5	32.4	26.4	15.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	27.5	26.9	31.5	38.0	44.6	50.3	47.6	44.9	42.0	32.0	27.8	(27)
(28)			MCD B	27.1	28.0	27.8	32.2	41.0	48.9	54.0	49.3	45.8	43.5	32.5	28.4	(28)
(29)		2%	WB	21.1	20.9	22.5	26.4	35.0	42.1	46.1	45.3	43.0	36.6	29.7	23.9	(29)
(30)			MCD B	21.8	21.5	23.3	27.6	36.2	45.1	48.6	46.4	43.6	37.3	30.4	24.7	(30)
(31)		5%	WB	14.8	14.6	16.8	20.7	33.2	39.8	44.0	43.6	41.3	34.4	28.2	19.8	(31)
(32)			MCD B	15.5	15.2	17.5	21.7	34.1	42.2	46.0	44.8	42.1	35.2	29.1	20.6	(32)
(33)		10%	WB	8.0	8.3	10.8	16.8	31.9	37.7	42.1	42.0	39.6	32.6	26.4	15.7	(33)
(34)			MCD B	8.8	9.0	11.6	17.8	32.7	39.6	43.7	43.2	40.4	33.5	27.6	16.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.4	10.0	10.5	10.5	7.3	6.4	6.9	6.0	4.9	5.3	7.7	8.2	(35)
(36)			MCDBR	15.9	16.3	14.1	12.0	7.6	11.5	11.6	9.8	6.4	4.9	6.8	11.0	(36)
(37)			MCWBR	15.3	16.0	13.6	11.2	6.4	8.2	8.7	8.0	5.6	4.6	6.9	10.4	(37)
(38)		5% WB	MCDBR	15.9	16.2	13.8	11.6	7.5	11.5	10.6	9.1	5.8	4.8	6.5	10.4	(38)
(39)			MCWBR	15.4	15.9	13.4	11.0	6.4	8.4	8.5	7.8	5.2	4.7	6.8	10.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.202	0.249	0.312	0.338	0.347	0.358	0.350	0.307	0.222	N/A	N/A	(40)	
(41)		taud	N/A	1.976	2.139	1.998	2.018	2.174	2.347	2.419	2.436	2.099	N/A	N/A	(41)	
(42)		Ebn at Noon	0	154	237	251	260	264	257	244	220	141	0	0	(42)	
(43)		Edh at Noon	0	11	23	38	43	38	31	25	18	10	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0	91	599	1347	1921	2133	1580	955	443	114	0	0	(44)	
(45)		RadStd	0	10	38	74	52	115	135	100	33	14	0	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page