

OSTROV VRANGELYA, Russian Federation

WMO: 219820

Lat: 70.983N

Lon: 178.650W

Elev: 5

StdP: 101.27

Time Zone: 12.00 (E12)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-33.0	-31.3	-35.7	0.1	-32.8	-33.7	0.2	-31.0	23.7	-25.6	20.8	-20.8	2.0	50	1.073

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.8	9.0	7.1	7.7	6.3	6.6	5.6	7.5	8.6	6.6	7.4	5.7	6.5	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.8	6.1	7.7	5.9	5.7	6.9	5.0	5.4	6.1	23.9	8.7	21.8	7.5	20.1	6.6	14.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.7	13.6	DB	-33.4	12.4	3.1	2.4	-35.6	14.1	-37.4	15.5	-39.2	16.8	-41.4	18.5	(4)
(5)			WB	-34.0	10.0	3.5	2.0	-36.6	11.4	-38.6	12.5	-40.6	13.6	-43.2	15.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-8.9	-20.8	-21.3	-20.8	-15.3	-5.3	1.2	3.5	3.0	1.0	-3.9	-11.0	-17.9	(6)
(7)		DBStd	10.66	5.60	6.19	6.11	5.33	4.72	2.34	1.97	2.25	2.70	4.14	5.95	6.00	(7)
(8)		HDD10.0	6904	956	877	955	760	475	263	203	217	271	431	629	867	(8)
(9)		HDD18.3	9946	1214	1111	1213	1010	733	513	461	476	521	689	879	1125	(9)
(10)		CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.1	6.2	6.2	4.6	4.2	4.3	3.5	3.7	4.1	4.4	6.1	6.5	6.8	(14)
(15)	Precipitation	PrecAvg	148	9	9	6	7	9	9	20	24	16	16	12	9	(15)
(16)		PrecMax	212	25	29	29	18	25	33	50	52	70	43	38	29	(16)
(17)		PrecMin	55	3	0	0	1	1	0	0	3	5	3	1	1	(17)
(18)		PrecStd	38	6	7	7	5	6	7	13	14	14	9	9	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.7	-2.2	-2.3	0.2	5.4	10.0	12.4	10.5	8.1	6.3	0.3	-1.9	(19)
(20)			MCWB	-3.1	-2.5	-2.9	-0.4	3.3	6.7	9.9	7.9	6.6	5.6	-0.4	-2.6	(20)
(21)		2%	DB	-5.5	-5.8	-4.8	-2.4	2.6	7.4	9.6	8.4	6.6	3.1	-0.8	-4.1	(21)
(22)			MCWB	-6.0	-6.3	-5.3	-3.1	1.5	5.4	7.6	7.0	5.9	2.5	-1.4	-4.6	(22)
(23)		5%	DB	-9.2	-9.3	-8.0	-5.6	1.3	5.8	8.0	7.3	5.7	1.8	-1.5	-6.3	(23)
(24)			MCWB	-9.6	-9.7	-8.6	-6.3	0.5	4.2	6.5	6.4	5.1	1.2	-2.2	-6.8	(24)
(25)		10%	DB	-12.8	-12.8	-11.4	-7.9	0.4	4.5	6.7	6.2	4.8	0.9	-2.5	-8.6	(25)
(26)			MCWB	-13.3	-13.2	-11.8	-8.5	-0.2	3.1	5.4	5.5	4.1	0.2	-3.1	-9.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.2	-2.5	-2.8	-0.3	3.3	7.0	10.1	8.7	7.2	5.6	0.0	-2.3	(27)
(28)			MDCB	-2.7	-2.2	-2.4	0.1	5.0	9.4	12.2	9.6	7.7	6.4	0.3	-2.0	(28)
(29)		2%	WB	-6.1	-6.2	-5.3	-3.1	1.6	5.6	7.8	7.4	6.1	2.6	-1.3	-4.5	(29)
(30)			MDCB	-5.7	-5.9	-4.8	-2.4	2.3	7.3	9.2	8.0	6.5	2.9	-0.9	-4.1	(30)
(31)		5%	WB	-9.6	-9.7	-8.5	-6.3	0.7	4.3	6.7	6.5	5.2	1.3	-2.1	-6.8	(31)
(32)			MDCB	-9.2	-9.3	-8.0	-5.7	1.2	5.7	7.8	7.1	5.6	1.8	-1.6	-6.3	(32)
(33)		10%	WB	-13.3	-13.2	-11.8	-8.4	-0.1	3.2	5.6	5.6	4.2	0.3	-3.1	-9.1	(33)
(34)			MDCB	-12.9	-12.8	-11.4	-7.9	0.4	4.2	6.5	6.2	4.7	0.9	-2.5	-8.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.2	5.6	5.9	5.9	4.1	3.6	3.8	3.3	2.7	3.0	4.3	4.5	(35)
(36)			MCDBR	8.8	9.0	7.8	6.7	4.2	6.4	6.4	5.5	3.6	2.7	3.8	6.1	(36)
(37)			MCWBR	8.5	8.9	7.6	6.2	3.6	4.6	4.8	4.4	3.1	2.5	3.8	5.8	(37)
(38)		5% WB	MCDBR	8.8	9.0	7.7	6.5	4.2	6.4	5.9	5.0	3.2	2.7	3.6	5.8	(38)
(39)			MCWBR	8.6	8.8	7.5	6.1	3.6	4.7	4.7	4.3	2.9	2.6	3.8	5.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.202	0.249	0.312	0.338	0.347	0.358	0.350	0.307	0.222	N/A	N/A	(40)	
(41)		taud	N/A	1.976	2.139	1.998	2.018	2.174	2.347	2.419	2.436	2.099	N/A	N/A	(41)	
(42)		Ebn at Noon	0	484	748	792	821	831	811	770	695	443	0	0	(42)	
(43)		Edh at Noon	0	36	72	119	134	119	98	80	57	31	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.29	1.89	4.25	6.05	6.72	4.98	3.01	1.40	0.36	0.00	0.00	(44)	
(45)		RadStd	0.00	0.03	0.12	0.23	0.16	0.36	0.42	0.32	0.10	0.04	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page