

TERIBERKA, Russian Federation

WMO: 220280

Lat: 69.2022N

Lon: 35.1069E

Elev: 100

StdP: 14.64

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.7	0.5	-8.9	3.4	-2.6	-4.7	4.3	1.9	47.6	27.7	44.5	24.0	11.3	170	0.947

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	73.4	61.2	69.1	59.3	64.9	56.9	63.0	71.7	60.0	67.2	57.4	63.8	12.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.0	74.8	67.9	56.2	67.5	64.4	53.8	61.9	61.3	28.6	72.0	26.5	67.2	24.7	63.8	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.4	36.8	32.4	DB	-6.7	79.4	4.7	4.6	-10.2	82.7	-12.9	85.3	-15.6	87.9	-19.0	91.2	(4)
(5)			WB	-7.2	66.0	4.9	3.7	-10.7	68.7	-13.6	70.8	-16.3	72.9	-19.8	75.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.9	19.2	18.2	23.7	31.0	38.4	46.2	53.5	52.0	46.6	36.9	28.1	24.2	
	DBStd	14.09	9.01	9.28	7.46	6.21	6.80	7.63	7.93	6.12	5.68	6.31	6.76	7.62	
	HDD50	5855	956	891	814	571	367	167	47	45	135	405	656	801	
	HDD65	10995	1421	1311	1279	1021	825	566	369	408	553	870	1106	1266	
	CDD50	356	0	0	0	0	7	54	157	106	32	0	0	0	
	CDD65	21	0	0	0	0	0	3	14	4	0	0	0	0	
	CDH74	110	0	0	0	0	1	9	82	18	0	0	0	0	
	CDH80	15	0	0	0	0	0	0	14	1	0	0	0	0	
Wind	WSAvg	15.7	17.8	17.9	18.2	16.2	14.2	12.7	12.2	12.2	14.9	16.7	17.3	18.2	
Precipitation	PrecAvg	18.6	1.1	0.8	0.9	0.9	1.3	1.9	2.4	2.1	2.2	2.6	1.2	1.2	
	PrecMax	25.0	2.4	1.5	2.2	2.1	3.8	4.8	4.5	3.6	5.4	4.0	2.2	2.6	
	PrecMin	14.9	0.4	0.2	0.3	0.2	0.4	0.3	0.6	0.6	1.2	1.3	0.4	0.5	
	PrecStd	2.2	0.5	0.3	0.5	0.4	0.6	1.1	0.9	0.9	0.9	0.7	0.5	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.0	38.0	40.9	47.7	63.6	75.1	82.1	76.4	65.0	53.0	44.1	40.4	
		MCWB	34.3	35.3	36.3	41.1	52.3	59.6	65.3	63.9	56.3	48.6	41.6	38.1	
	2%	DB	34.8	35.1	37.9	43.5	57.2	69.5	75.7	69.9	60.9	49.9	40.0	37.9	
		MCWB	32.4	32.7	34.6	38.9	47.9	57.7	63.5	60.5	54.2	46.4	38.0	35.9	
	5%	DB	32.7	32.7	35.2	40.8	52.8	64.5	71.0	65.2	57.8	47.4	38.2	36.0	
		MCWB	30.5	30.5	32.4	37.0	45.7	54.7	60.5	57.8	52.6	44.4	36.1	34.0	
	10%	DB	30.6	30.0	33.0	38.6	48.5	59.4	66.9	61.4	54.9	45.1	36.6	33.9	
		MCWB	28.6	27.8	30.7	35.6	43.0	51.5	58.5	55.7	51.0	42.7	34.6	31.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	36.2	36.9	41.9	53.6	63.0	67.6	64.7	57.7	48.9	41.6	38.5
			MCDB	36.6	37.9	39.5	46.9	62.3	71.3	76.6	74.1	62.6	51.8	43.5	40.1
2%		WB	32.5	33.1	34.7	39.4	48.9	57.9	64.4	61.1	55.1	46.6	38.4	35.9	
		MCDB	34.2	35.1	37.5	43.2	55.5	67.8	74.1	68.1	59.9	49.3	39.9	37.5	
5%		WB	30.7	30.6	32.7	37.5	46.3	55.0	61.8	58.5	53.1	44.7	36.3	34.3	
		MCDB	32.6	32.6	34.9	40.2	52.4	63.8	69.6	63.9	57.2	47.1	37.9	35.9	
10%		WB	28.6	28.2	30.8	35.9	43.2	51.9	58.9	56.1	50.9	42.9	34.8	31.9	
		MCDB	30.5	29.9	32.9	38.1	48.0	59.0	66.4	60.7	54.7	45.1	36.4	33.7	
Mean Daily Temperature Range		5% DB	MDBR	8.1	7.9	6.9	6.2	7.2	8.4	9.4	7.7	6.5	5.4	6.5	7.5
			MCDBR	8.8	8.2	6.5	8.0	15.3	17.6	18.1	15.2	11.0	6.3	5.3	7.0
	MCWBR		8.3	7.7	5.8	6.0	9.0	9.4	9.1	8.0	6.2	4.9	5.1	6.8	
	5% WB	MCDBR	8.9	8.0	6.4	6.9	14.8	16.5	16.6	13.6	10.1	5.9	5.2	6.7	
		MCWBR	8.4	7.7	5.9	5.4	9.4	10.0	9.8	8.1	6.3	5.1	5.3	6.7	
Clear-Sky Solar Irradiance	taub	N/A	0.265	0.311	0.337	0.350	0.346	0.367	0.347	0.319	0.280	0.360	N/A		
	taud	N/A	2.080	2.158	2.238	2.368	2.474	2.444	2.477	2.496	2.208	2.622	N/A		
	Ebn at Noon	N/A	150	219	252	265	271	259	251	227	144	18	0		
	Edh at Noon	N/A	14	25	31	31	29	29	25	19	12	3	0		
All-Sky Solar Radiation	RadAvg	5	101	462	964	1325	1504	1385	940	520	142	17	0		
	RadStd	0	10	31	75	147	131	161	96	57	17	2	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page