

TERIBERKA, Russian Federation

WMO: 220280

Lat: 69.2022N

Lon: 35.1069E

Elev: 30

StdP: 100.96

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.8	-17.5	-22.7	0.5	-19.2	-20.4	0.6	-16.7	21.3	-2.4	19.9	-4.5	5.0	170	0.947

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	23.0	16.2	20.6	15.1	18.3	13.8	17.2	22.0	15.6	19.6	14.1	17.7	5.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.7	20.0	13.4	9.6	18.0	12.1	8.8	16.3	48.6	22.2	43.7	19.5	39.7	17.7	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	16.4	14.5	DB	-21.5	26.3	2.6	2.5	-23.4	28.1	-25.0	29.6	-26.4	31.0	-28.4	32.9	(4)
(5)			WB	-21.8	18.9	2.7	2.1	-23.7	20.4	-25.3	21.6	-26.8	22.7	-28.8	24.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.6	-7.1	-7.7	-4.6	-0.6	3.6	7.9	12.0	11.1	8.1	2.7	-2.1	-4.4
	DBStd	7.83	5.01	5.16	4.14	3.45	3.78	4.24	4.40	3.40	3.15	3.51	3.76	4.23
	HDD10.0	3253	531	495	452	317	204	93	26	25	75	225	364	445
	HDD18.3	6108	789	728	711	567	458	314	205	227	307	483	614	703
	CDD10.0	198	0	0	0	0	4	30	87	59	18	0	0	0
	CDD18.3	12	0	0	0	0	0	2	8	2	0	0	0	0
	CDH23.3	61	0	0	0	0	1	5	46	10	0	0	0	0
	CDH26.7	8	0	0	0	0	0	0	8	1	0	0	0	0
Wind	WSAvg	7.0	8.0	8.0	8.1	7.2	6.3	5.7	5.4	5.4	6.7	7.5	7.7	8.1
Precipitation	PrecAvg	472	27	20	24	23	34	49	60	53	56	65	31	31
	PrecMax	636	61	38	56	53	97	122	114	91	137	102	55	67
	PrecMin	379	9	5	7	6	9	8	15	16	31	34	10	13
	PrecStd	57	13	7	12	9	16	27	24	22	23	19	12	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.8	3.3	4.9	8.7	17.6	23.9	27.8	24.7	18.3	11.7	6.7	4.7
		MCWB	1.3	1.8	2.4	5.1	11.3	15.3	18.5	17.7	13.5	9.2	5.4	3.4
	2%	DB	1.5	1.7	3.3	6.4	14.0	20.8	24.3	21.1	16.0	10.0	4.5	3.3
		MCWB	0.2	0.4	1.5	3.9	8.8	14.3	17.5	15.8	12.3	8.0	3.3	2.1
	5%	DB	0.4	0.4	1.8	4.9	11.5	18.1	21.7	18.4	14.3	8.5	3.4	2.2
		MCWB	-0.8	-0.8	0.2	2.8	7.6	12.6	15.8	14.3	11.4	6.9	2.3	1.1
	10%	DB	-0.8	-1.1	0.5	3.7	9.2	15.2	19.4	16.3	12.7	7.3	2.6	1.1
		MCWB	-1.9	-2.3	-0.7	2.0	6.1	10.8	14.7	13.2	10.5	5.9	1.4	-0.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	2.3	2.7	5.5	12.0	17.2	19.8	18.2	14.3	9.4	5.3	3.6
		MCDB	2.6	3.3	4.2	8.3	16.9	21.8	24.8	23.4	17.0	11.0	6.4	4.5
	2%	WB	0.3	0.6	1.5	4.1	9.4	14.4	18.0	16.2	12.8	8.1	3.5	2.2
		MCDB	1.2	1.7	3.0	6.2	13.1	19.9	23.4	20.1	15.5	9.6	4.4	3.1
	5%	WB	-0.7	-0.8	0.4	3.0	7.9	12.8	16.5	14.7	11.7	7.0	2.4	1.3
		MCDB	0.3	0.3	1.6	4.5	11.3	17.7	20.9	17.7	14.0	8.4	3.3	2.2
	10%	WB	-1.9	-2.1	-0.7	2.2	6.2	11.0	15.0	13.4	10.5	6.1	1.6	-0.1
		MCDB	-0.8	-1.2	0.5	3.4	8.9	15.0	19.1	15.9	12.6	7.3	2.5	0.9
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.4	3.8	3.5	4.0	4.7	5.2	4.3	3.6	3.0	3.6	4.2
		MCDBR	4.9	4.6	3.6	4.4	8.5	9.8	10.1	8.5	6.1	3.5	2.9	3.9
		MCWBR	4.6	4.3	3.2	3.3	5.0	5.2	5.0	4.4	3.4	2.7	2.8	3.8
	5% WB	MCDBR	4.9	4.4	3.5	3.8	8.2	9.2	9.2	7.6	5.6	3.3	2.9	3.7
		MCWBR	4.7	4.3	3.3	3.0	5.2	5.5	5.4	4.5	3.5	2.8	2.9	3.7
Clear-Sky Solar Irradiance	taub	N/A	0.265	0.311	0.337	0.350	0.346	0.367	0.347	0.319	0.280	0.360	N/A	
	taud	N/A	2.080	2.158	2.238	2.368	2.474	2.444	2.477	2.496	2.208	2.622	N/A	
	Ebn at Noon	N/A	472	689	796	835	853	816	791	715	453	57	0	
	Edh at Noon	N/A	44	79	98	98	91	91	79	59	38	8	0	
All-Sky Solar Radiation	RadAvg	0.01	0.32	1.46	3.04	4.18	4.74	4.37	2.96	1.64	0.45	0.05	0.00	
	RadStd	0.00	0.03	0.10	0.24	0.46	0.41	0.51	0.30	0.18	0.05	0.01	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page