

LOVOZERO, Russian Federation

WMO: 221270

Lat: 68.004N

Lon: 35.031E

Elev: 162

StdP: 99.40

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-34.4	-31.1	-36.8	0.1	-34.4	-33.4	0.2	-31.1	10.9	-8.6	9.6	-6.2	0.2	40	0.736

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	24.5	16.9	22.1	15.7	20.0	14.6	18.0	23.0	16.6	20.9	15.2	19.0	3.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.9	11.5	19.7	14.6	10.6	18.7	13.3	9.7	17.3	51.3	23.1	47.0	21.1	43.2	19.1	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.3	6.2	DB	-37.3	27.0	3.3	2.2	-39.7	28.6	-41.6	29.9	-43.5	31.1	-45.9	32.7	(4)
(5)			WB	-37.4	19.3	3.3	1.7	-39.7	20.6	-41.7	21.6	-43.5	22.6	-45.9	23.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.8	-13.2	-13.7	-8.5	-2.0	3.7	9.4	13.3	11.0	6.4	0.2	-6.7	-10.0	(6)
(7)		DBStd	10.75	7.98	8.33	6.25	4.64	4.26	4.36	4.05	3.56	3.35	4.30	6.22	6.96	(7)
(8)		HDD10.0	4165	719	664	572	361	201	63	14	29	116	305	501	620	(8)
(9)		HDD18.3	6982	978	897	831	611	454	269	163	229	357	563	751	878	(9)
(10)		CDD10.0	235	0	0	0	0	5	46	116	60	8	0	0	0	(10)
(11)		CDD18.3	11	0	0	0	0	0	2	7	2	0	0	0	0	(11)
(12)		CDH23.3	106	0	0	0	0	1	18	65	22	0	0	0	0	(12)
(13)		CDH26.7	10	0	0	0	0	0	2	6	2	0	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.3	2.4	2.7	2.9	3.0	2.9	2.5	2.3	2.4	2.5	2.3	2.5	(14)
(15)	Precipitation	PrecAvg	495	25	25	26	26	39	62	75	60	50	47	30	31	(15)
(16)		PrecMax	674	38	44	79	67	74	113	115	114	93	95	66	53	(16)
(17)		PrecMin	404	6	6	13	4	17	17	31	22	2	11	8	10	(17)
(18)		PrecStd	66	8	11	14	13	15	30	21	21	28	22	14	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.5	3.0	5.7	10.7	20.6	26.0	27.4	25.9	18.9	11.0	5.3	3.8	(19)
(20)			MCWB	0.8	0.8	2.2	5.9	12.2	16.8	18.9	18.1	13.4	8.5	3.8	1.8	(20)
(21)		2%	DB	0.2	1.2	3.2	7.9	16.5	22.2	25.2	22.6	16.4	8.9	3.2	2.2	(21)
(22)			MCWB	-0.8	-0.3	0.7	4.3	10.2	14.7	17.3	16.3	12.1	6.9	1.8	0.6	(22)
(23)		5%	DB	-1.5	-0.5	1.5	5.9	13.8	19.8	23.2	19.8	14.3	7.3	1.9	0.6	(23)
(24)			MCWB	-2.4	-1.7	-0.4	2.8	8.5	13.4	16.7	15.0	11.1	5.9	0.8	-0.5	(24)
(25)		10%	DB	-3.2	-2.3	0.0	4.3	11.3	17.5	21.1	17.5	12.1	5.9	0.6	-0.9	(25)
(26)			MCWB	-3.8	-3.2	-1.4	1.8	7.1	12.1	15.7	13.8	9.9	4.8	-0.1	-1.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.2	1.5	2.5	6.3	13.1	17.7	20.2	18.8	14.1	8.7	4.1	2.1	(27)
(28)			MCDWB	2.2	2.8	5.2	10.1	19.7	24.4	25.2	24.7	17.3	10.4	5.1	3.5	(28)
(29)		2%	WB	-0.6	-0.2	1.0	4.5	10.6	15.7	18.7	17.0	12.5	7.2	2.1	0.8	(29)
(30)			MCDWB	0.2	1.0	2.8	7.5	15.9	21.0	23.6	21.3	15.6	8.4	2.9	1.9	(30)
(31)		5%	WB	-2.4	-1.7	-0.3	3.1	8.8	14.0	17.4	15.5	11.3	6.1	0.9	-0.4	(31)
(32)			MCDWB	-1.6	-0.5	1.1	5.5	13.1	18.9	21.8	19.0	13.9	7.3	1.7	0.6	(32)
(33)		10%	WB	-3.8	-3.2	-1.4	2.1	7.2	12.6	16.1	14.2	10.1	4.9	0.0	-1.7	(33)
(34)			MCDWB	-3.2	-2.3	0.0	4.0	11.1	17.0	20.2	17.1	12.0	5.8	0.6	-1.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	9.3	9.6	8.0	7.6	8.4	8.8	7.9	7.1	5.0	6.3	8.2	(35)
(36)			MCDBR	8.1	8.2	8.9	9.3	13.1	12.5	13.2	12.5	11.8	6.7	5.0	6.8	(36)
(37)			MCWBR	7.4	7.2	7.1	6.2	7.7	6.4	6.5	7.0	7.7	5.1	4.4	6.0	(37)
(38)		5% WB	MCDBR	7.6	8.0	7.8	8.7	12.4	11.1	11.6	10.8	10.4	6.3	4.7	6.7	(38)
(39)			MCWBR	7.1	7.2	6.5	6.0	7.6	6.3	6.2	6.4	7.2	5.0	4.3	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.209	0.262	0.303	0.335	0.348	0.347	0.368	0.347	0.319	0.281	N/A	N/A	(40)	
(41)		taud	1.902	2.036	2.079	2.126	2.318	2.454	2.418	2.450	2.490	2.237	N/A	N/A	(41)	
(42)		Ebn at Noon	82	513	711	801	841	856	820	798	731	503	N/A	0	(42)	
(43)		Edh at Noon	9	50	88	112	104	94	95	82	61	41	N/A	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.04	0.48	1.91	3.71	4.56	4.86	4.53	3.09	1.71	0.52	0.09	0.00	(44)	
(45)		RadStd	0.00	0.06	0.12	0.24	0.49	0.49	0.60	0.30	0.18	0.08	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page