

MYS ABRAOVSKIY, Russian Federation

WMO: 223650

Lat: 66.409N

Lon: 43.267E

Elev: 66

StdP: 14.66

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.5	-9.5	-19.4	1.9	-14.6	-13.7	2.6	-9.4	40.9	21.2	35.8	21.0	7.9	180	0.893

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.1	70.9	62.5	66.9	60.0	63.9	58.6	63.4	69.7	61.2	65.8	59.2	63.3	10.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.5	79.0	65.9	58.7	74.0	64.5	56.9	69.3	62.6	28.8	70.4	27.3	65.8	25.9	63.3	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
32.0	28.3	26.5		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
				WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	32.9	13.2	14.7	21.4	28.7	37.4	47.3	53.3	46.6	35.6	23.9	18.2
		DBStd	16.58	12.00	11.31	8.62	6.60	8.14	6.97	7.30	5.53	5.44	6.49	11.32
		HDD50	6608	1142	989	886	639	404	134	46	22	130	448	782
		HDD65	11720	1607	1409	1351	1089	857	532	372	356	552	912	1232
		CDD50	374	0	0	0	0	12	53	147	134	28	0	0
		CDD65	12	0	0	0	0	0	1	8	3	0	0	0
		CDH74	60	0	0	0	0	0	8	35	17	0	0	0
		CDH80	1	0	0	0	0	0	1	0	0	0	0	0
(14)	Wind	WSAvg	13.4	15.5	14.6	14.6	13.3	12.2	12.5	11.6	12.3	12.7	13.8	13.7
(15)	Precipitation	PrecAvg	28.8	2.3	1.9	1.5	1.5	1.9	2.4	2.4	3.1	2.8	3.4	2.9
(16)		PrecMax	38.4	3.5	4.1	3.1	2.6	3.7	4.7	4.9	5.9	5.4	6.1	4.6
(17)		PrecMin	24.6	0.9	0.7	0.5	0.3	0.7	0.8	0.7	0.8	1.1	1.6	1.3
(18)		PrecStd	2.9	0.6	0.7	0.7	0.6	0.7	0.9	1.1	1.1	1.0	1.0	0.8
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	33.6	34.8	37.3	48.0	66.3	73.1	78.7	76.1	65.3	52.2	39.5	35.0
(20)		0.4% MCWB	32.3	33.2	33.8	41.9	52.7	63.7	64.7	64.8	59.7	49.9	38.4	33.2
(21)		2% DB	32.0	33.2	34.9	42.8	59.7	66.4	72.3	69.6	60.5	47.9	36.7	33.6
(22)		2% MCWB	31.4	32.0	32.9	38.2	52.4	59.1	63.1	62.0	55.8	46.3	35.4	32.3
(23)		5% DB	30.2	32.0	33.6	39.5	54.7	62.7	67.7	65.8	56.8	45.6	35.2	32.4
(24)		5% MCWB	29.3	31.3	32.1	35.8	49.5	55.9	60.7	59.9	53.2	43.9	34.0	31.4
(25)		10% DB	27.7	30.1	32.4	37.0	49.4	58.5	64.3	62.7	54.1	43.7	34.1	30.8
(26)		10% MCWB	26.7	29.3	31.0	34.4	44.8	53.4	59.4	58.8	51.5	42.1	32.9	30.0
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	32.8	34.0	34.2	42.1	57.8	64.4	66.4	65.9	60.4	50.4	38.6	33.8
(28)		0.4% MCDB	33.4	34.4	35.7	47.2	63.1	73.6	75.6	73.1	64.6	51.7	39.3	34.5
(29)		2% WB	31.5	32.4	33.2	38.5	52.5	60.3	63.7	63.0	56.4	46.5	35.9	32.6
(30)		2% MCDB	32.0	33.1	34.3	42.2	57.6	65.7	71.0	67.8	59.1	47.6	36.2	33.4
(31)		5% WB	29.4	31.1	32.4	36.4	49.2	56.6	61.5	60.9	53.9	44.2	34.3	31.6
(32)		5% MCDB	30.1	31.9	33.6	39.0	55.6	61.8	66.8	64.3	56.2	45.2	34.9	32.4
(33)		10% WB	26.7	29.2	31.1	34.7	45.0	53.6	59.7	58.8	51.8	42.3	33.1	30.0
(34)		10% MCDB	27.4	30.0	32.4	36.7	49.2	58.3	63.9	62.6	54.0	43.6	34.0	30.8
(35)	Mean Daily Temperature Range	MDBR	10.2	10.3	9.7	9.5	9.7	9.8	9.0	10.1	8.1	6.6	7.3	9.5
(36)		5% DB MCDBR	8.2	6.0	6.9	11.4	19.1	17.1	17.1	17.5	13.8	8.9	5.5	7.8
(37)		5% WB MCWBR	8.3	5.5	6.0	8.4	13.2	11.2	9.5	10.7	9.4	7.8	5.3	7.6
(38)		5% WB MCDBR	7.5	6.3	5.8	9.5	18.5	16.5	14.6	15.7	12.1	8.4	4.7	7.9
(39)		5% WB MCWBR	7.9	5.9	5.1	7.6	13.2	11.8	9.1	10.4	8.9	7.7	4.9	7.9
(40)	Clear-Sky Solar Irradiance	taub	0.218	0.270	0.304	0.335	0.344	0.344	0.380	0.354	0.329	0.299	0.355	0.369
(41)		taud	1.925	2.050	2.097	2.141	2.401	2.494	2.418	2.472	2.509	2.297	2.557	2.575
(42)		Ebn at Noon	57	176	233	258	272	275	259	255	235	172	60	13
(43)		Edh at Noon	5	18	29	36	31	29	31	26	20	14	5	3
(44)	All-Sky Solar Radiation	RadAvg	22	173	636	1192	1475	1663	1555	1056	567	190	35	2
(45)		RadStd	2	22	61	79	110	145	165	113	65	32	4	0

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page