

MEZEN, Russian Federation

WMO: 224710

Lat: 65.8725N

Lon: 44.2081E

Elev: 19

StdP: 101.10

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.9	-29.7	-35.4	0.1	-32.8	-32.2	0.2	-29.6	12.2	-6.9	10.4	-7.5	1.5	180	0.755

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	25.7	18.2	23.5	16.9	21.4	16.0	19.3	23.9	18.0	22.5	16.7	20.3	4.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	12.5	21.7	16.2	11.5	20.2	15.0	10.7	18.8	55.0	24.0	50.9	22.7	47.1	20.2	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.1	8.1	DB	-35.0	29.0	3.1	1.8	-37.2	30.3	-38.9	31.4	-40.7	32.4	-42.9	33.7	(4)
(5)			WB	-35.1	21.1	3.0	1.7	-37.2	22.2	-39.0	23.2	-40.7	24.2	-42.9	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.4	-13.1	-12.7	-6.7	-1.0	5.2	10.8	14.5	12.4	8.0	1.6	-5.5	-9.7
	DBStd	11.15	8.02	8.99	5.84	4.80	5.55	4.56	4.44	3.79	3.63	3.86	6.61	7.88
	HDD10.0	3856	715	636	519	329	171	44	11	16	80	261	464	610
	HDD18.3	6564	973	869	777	579	406	228	134	187	309	519	714	868
	CDD10.0	355	0	0	0	0	23	69	150	92	21	0	0	0
	CDD18.3	22	0	0	0	0	1	3	14	4	0	0	0	0
	CDH23.3	197	0	0	0	0	9	32	125	31	0	0	0	0
	CDH26.7	30	0	0	0	0	1	4	21	3	0	0	0	0
Wind	WSAvg	3.9	4.0	3.9	4.0	4.1	4.3	4.0	3.6	3.5	3.5	4.0	3.9	4.1
Precipitation	PrecAvg	560	33	26	27	26	41	55	63	79	67	58	43	40
	PrecMax	728	53	53	63	48	104	138	180	159	133	86	87	69
	PrecMin	462	16	9	7	3	10	16	6	13	20	30	18	15
	PrecStd	68	9	10	15	12	21	26	43	31	29	16	17	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.2	2.2	4.8	13.4	24.5	26.7	28.9	26.8	20.1	12.1	4.9	2.2
		MCWB	0.5	1.4	1.9	7.5	15.4	18.9	20.2	19.3	15.9	10.1	4.4	1.2
	2%	DB	0.2	1.2	2.7	9.2	20.5	23.7	26.5	23.4	17.6	9.4	3.2	1.2
		MCWB	-0.4	0.5	0.7	5.2	12.9	15.6	18.5	17.7	13.8	8.0	2.8	0.6
	5%	DB	-1.2	0.2	1.7	6.7	17.6	21.5	24.3	20.9	15.5	7.7	2.1	0.6
		MCWB	-1.8	-0.3	0.3	3.6	11.2	15.0	18.0	16.5	12.5	6.6	1.5	0.0
	10%	DB	-2.9	-1.1	0.8	4.9	14.7	19.0	22.4	18.9	13.6	6.4	1.4	-0.3
		MCWB	-3.5	-1.7	-0.4	2.3	9.5	13.8	17.0	15.4	11.5	5.5	0.8	-0.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.7	1.7	2.2	7.9	16.2	19.7	21.9	20.6	16.5	10.8	4.5	1.4
		MCDB	1.0	2.0	3.9	12.6	21.9	25.4	27.5	25.4	19.5	12.0	4.7	1.7
	2%	WB	-0.3	0.6	1.3	5.7	13.9	17.6	19.7	18.4	14.5	8.1	2.9	0.8
		MCDB	0.2	1.0	2.3	8.6	19.1	21.6	24.2	22.1	16.7	9.1	3.2	1.3
	5%	WB	-1.8	-0.2	0.6	3.9	11.8	15.8	18.6	17.0	13.0	6.7	1.7	0.1
		MCDB	-1.3	0.3	1.6	6.1	16.5	19.7	23.3	20.2	14.9	7.6	1.9	0.6
	10%	WB	-3.4	-1.7	-0.3	2.8	9.8	14.3	17.5	15.7	11.7	5.6	0.9	-0.9
		MCDB	-3.0	-1.1	0.8	4.5	14.4	18.3	21.8	18.4	13.4	6.4	1.3	-0.4
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.4	7.4	7.1	8.4	8.8	9.1	7.8	6.1	4.0	4.4	5.7
		MCDBR	5.2	3.5	5.8	8.8	13.6	12.8	12.5	10.8	9.2	5.3	3.3	3.8
		MCWBR	5.1	3.5	4.5	5.8	7.6	6.8	6.5	6.3	5.7	4.2	3.2	3.7
	5% WB	MCDBR	5.2	3.1	4.7	7.8	12.9	11.0	11.2	9.6	7.6	5.1	3.3	3.7
		MCWBR	5.1	3.1	3.8	5.4	7.7	6.9	6.7	6.2	5.3	4.3	3.4	3.7
Clear-Sky Solar Irradiance	taub	0.217	0.274	0.306	0.338	0.345	0.345	0.382	0.355	0.328	0.299	0.359	0.218	
	taud	1.924	2.061	2.113	2.151	2.400	2.480	2.392	2.444	2.499	2.313	2.579	1.943	
	Ebn at Noon	216	569	742	815	858	867	815	804	746	559	221	28	
	Edh at Noon	20	59	91	113	99	94	100	86	65	46	19	5	
All-Sky Solar Radiation	RadAvg	0.09	0.62	2.07	3.79	4.74	5.16	4.96	3.34	1.80	0.63	0.14	0.02	
	RadStd	0.01	0.09	0.23	0.36	0.41	0.52	0.55	0.36	0.18	0.11	0.02	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page