

KOYNAS, Russian Federation

WMO: 225830

Lat: 64.750N

Lon: 47.650E

Elev: 211

StdP: 14.58

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.5	-29.1	-40.3	0.5	-35.1	-34.0	0.8	-28.9	16.1	15.6	14.0	18.4	1.1	320	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	82.9	65.1	78.6	63.2	74.5	61.3	67.3	78.0	65.2	75.2	63.0	72.1	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	88.5	71.7	61.2	81.3	69.7	59.0	75.2	67.1	31.9	77.9	30.3	75.5	28.6	72.3	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.6	11.6	9.9	DB	-39.5	88.1	7.2	3.1	-44.7	90.3	-48.9	92.2	-52.9	93.9	-58.1	96.2	
			WB	-39.5	70.8	6.8	2.6	-44.3	72.7	-48.3	74.2	-52.1	75.6	-57.0	77.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	31.9	4.5	4.9	18.1	31.2	42.8	53.2	60.9	54.4	45.8	34.4	19.0	11.3	(6)
(7)		DBStd	22.39	17.10	17.35	11.85	9.54	9.91	8.98	8.16	6.60	6.62	7.14	13.64	16.33	(7)
(8)		HDD50	7374	1410	1263	990	564	273	65	10	27	159	483	931	1199	(8)
(9)		HDD65	12167	1875	1683	1455	1013	690	369	178	335	576	948	1381	1664	(9)
(10)		CDD50	758	0	0	0	1	49	162	348	164	33	1	0	0	(10)
(11)		CDD65	76	0	0	0	0	2	16	51	7	0	0	0	0	(11)
(12)		CDH74	920	0	0	0	0	50	222	576	71	1	0	0	0	(12)
(13)		CDH80	228	0	0	0	0	12	57	146	13	0	0	0	0	(13)
(14)	Wind	WSAvg	4.3	3.8	3.8	4.4	4.7	4.9	4.8	4.2	4.1	4.4	4.8	4.1	4.1	(14)
(15)	Precipitation	PrecAvg	24.0	1.4	1.2	1.2	1.5	2.0	2.6	2.7	2.5	2.4	2.0	1.8		(15)
(16)		PrecMax	29.1	3.0	2.2	3.0	3.0	3.9	6.4	5.4	4.3	4.2	4.4	3.5	3.1	(16)
(17)		PrecMin	18.9	0.6	0.3	0.2	0.5	0.7	0.4	0.5	1.6	0.9	0.6	0.5	0.4	(17)
(18)		PrecStd	2.7	0.6	0.5	0.6	0.7	0.8	1.3	1.2	0.9	0.9	0.9	0.7	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.3	35.1	44.2	63.1	81.1	86.0	88.8	81.0	70.2	55.5	42.6	36.5	(19)
(20)		MCWB	32.6	34.0	36.6	50.1	61.1	65.9	68.6	65.3	59.3	51.2	41.0	35.2		(20)
(21)		2%	DB	31.1	32.8	38.3	54.1	72.6	81.1	84.2	74.8	63.4	50.3	38.6	33.9	(21)
(22)		MCWB	30.5	31.8	33.4	43.9	55.9	63.7	66.5	63.0	55.9	47.4	37.6	33.1		(22)
(23)		5%	DB	28.8	30.6	35.7	48.4	66.6	75.7	80.5	70.5	59.2	47.0	35.9	32.5	(23)
(24)		MCWB	28.1	29.5	32.4	40.0	52.9	60.6	64.4	60.7	53.9	45.1	35.1	31.7		(24)
(25)		10%	DB	26.0	27.7	33.7	44.2	61.0	70.2	76.8	66.5	56.1	44.3	33.9	30.6	(25)
(26)		MCWB	25.2	26.6	31.4	37.8	50.6	58.1	63.1	59.0	52.2	42.8	33.1	29.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.7	34.2	38.2	50.4	62.4	68.0	71.2	67.9	60.4	51.7	41.4	35.4	(27)
(28)		MADB	32.9	34.8	43.0	62.7	76.7	81.3	84.0	77.5	66.9	54.9	42.2	36.1		(28)
(29)		2%	WB	30.6	32.1	34.8	44.7	57.9	65.4	68.5	64.8	57.3	47.7	37.8	33.2	(29)
(30)		MADB	31.0	32.9	37.2	52.6	69.4	77.6	79.4	71.1	62.0	49.7	38.6	33.7		(30)
(31)		5%	WB	28.2	29.6	33.2	41.2	54.1	62.4	66.4	61.9	54.8	45.1	35.2	31.8	(31)
(32)		MADB	28.7	30.6	35.1	46.9	64.6	72.5	76.8	68.2	58.4	46.8	35.7	32.5		(32)
(33)		10%	WB	25.3	26.7	31.4	38.5	50.9	59.6	64.5	59.9	52.4	42.9	33.2	29.9	(33)
(34)		MADB	26.1	27.7	33.5	43.1	60.0	69.0	74.1	65.5	55.6	44.3	33.7	30.7		(34)
(35)	Mean Daily Temperature Range	MDBR	12.5	14.9	18.1	16.8	18.0	17.9	18.6	15.2	12.0	7.0	8.8	10.9		(35)
(36)		5% DB	MCDBR	9.4	8.8	14.9	23.8	29.1	26.6	26.1	23.3	18.9	10.5	6.5	7.9	(36)
(37)		MCWBR	9.3	8.5	11.7	14.8	14.9	12.3	11.1	12.2	12.1	8.5	6.5	7.7		(37)
(38)		5% WB	MCDBR	8.9	8.6	12.1	20.5	26.1	23.1	22.9	19.2	16.6	10.3	6.6	7.8	(38)
(39)		MCWBR	9.0	8.5	10.0	13.6	14.2	11.9	11.0	11.3	11.4	8.9	6.6	7.7		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.216	0.276	0.307	0.342	0.343	0.348	0.395	0.359	0.329	0.297	N/A	0.214		(40)
(41)		taud	1.919	2.058	2.109	2.131	2.401	2.489	2.358	2.439	2.510	2.339	N/A	1.933		(41)
(42)		Ebn at Noon	92	189	240	259	274	276	256	256	241	189	N/A	26		(42)
(43)		Edh at Noon	8	20	30	37	32	30	33	28	21	16	N/A	3		(43)
(44)	All-Sky Solar Radiation	RadAvg	44	238	685	1216	1555	1656	1613	1077	565	208	53	14		(44)
(45)		RadStd	5	38	86	120	123	203	147	101	58	30	10	1		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page