

SEGEZHA, Russian Federation

WMO: 226210

Lat: 63.7591N

Lon: 34.2863E

Elev: 367

StdP: 14.50

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.8	-13.9	-24.3	1.4	-19.8	-18.0	2.1	-13.8	21.7	21.3	19.9	23.2	2.1	230	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	79.6	64.5	75.9	62.8	72.4	61.1	67.1	75.5	65.0	72.7	62.9	70.0	7.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	90.8	70.9	61.9	84.0	68.6	59.9	78.0	66.7	31.8	75.5	30.2	72.7	28.6	70.1	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	18.9	16.5	14.3	DB	-24.5	83.8	8.6	4.9	-30.7	87.3	-35.8	90.1	-40.6	92.9	-46.8	96.4
(5)				WB	-25.0	69.7	8.4	2.8	-31.1	71.7	-36.0	73.4	-40.7	74.9	-46.8	77.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	36.3	13.3	13.5	22.3	33.8	45.4	55.4	61.6	57.8	48.4	37.1	26.3	18.8	(6)
(7)		DBStd	19.24	13.78	13.67	9.33	7.95	9.19	7.95	6.86	6.30	6.11	7.24	9.39	12.71	(7)
(8)		HDD50	5932	1137	1022	858	488	202	33	4	9	100	401	711	967	(8)
(9)		HDD65	10554	1602	1442	1323	936	609	304	147	237	497	864	1161	1432	(9)
(10)		CDD50	926	0	0	0	2	60	195	364	250	53	2	0	0	(10)
(11)		CDD65	75	0	0	0	0	2	16	43	14	0	0	0	0	(11)
(12)		CDH74	519	0	0	0	0	24	118	289	88	0	0	0	0	(12)
(13)		CDH80	84	0	0	0	0	3	17	52	12	0	0	0	0	(13)
(14)	Wind	WSAvg	6.5	6.6	6.9	6.9	6.2	6.6	6.3	5.8	5.4	6.3	6.9	6.8	7.1	(14)
(15)	Precipitation	PrecAvg	25.0	1.7	1.3	1.3	1.2	2.0	2.8	3.3	2.8	2.5	2.4	2.0	1.8	(15)
(16)		PrecMax	34.1	2.6	2.8	2.3	2.4	3.7	4.6	9.1	6.1	5.9	4.8	3.2	3.4	(16)
(17)		PrecMin	19.1	0.7	0.2	0.6	0.2	0.7	1.5	0.7	0.4	0.4	0.6	0.5	0.3	(17)
(18)		PrecStd	3.9	0.6	0.6	0.4	0.6	0.7	0.9	1.9	1.4	1.1	1.1	0.6	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.8	37.8	45.0	62.3	77.3	82.3	85.5	81.4	69.5	55.7	45.9	40.0	(19)
(20)		MCWB	35.2	35.2	37.5	49.1	57.8	63.9	68.7	65.9	60.1	51.9	43.5	38.8		(20)
(21)		2%	DB	34.1	35.1	39.8	54.0	70.9	77.6	80.4	76.2	63.9	51.9	43.1	36.8	(21)
(22)		MCWB	32.9	33.4	34.4	44.7	55.2	62.7	65.9	63.3	56.4	49.3	41.5	35.5		(22)
(23)		5%	DB	32.7	33.4	36.6	49.0	65.3	72.8	77.1	72.2	60.5	49.4	40.2	35.1	(23)
(24)		MCWB	31.9	32.1	32.9	41.0	51.9	59.8	64.2	61.7	54.7	47.2	39.0	33.9		(24)
(25)		10%	DB	31.0	31.5	34.3	45.0	61.0	69.0	73.5	68.8	57.8	47.0	37.2	33.5	(25)
(26)		MCWB	30.2	30.4	31.9	38.9	50.3	58.2	62.4	60.2	53.2	45.1	36.0	32.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.3	35.8	38.3	50.9	61.2	67.8	71.2	68.3	60.8	52.9	44.2	39.2	(27)
(28)		MCDWB	36.6	37.1	43.8	58.9	72.0	76.8	81.7	77.8	66.4	54.5	45.3	39.6		(28)
(29)		2%	WB	33.1	33.7	35.2	46.0	57.1	65.2	68.3	65.1	57.6	50.0	41.5	35.8	(29)
(30)		MCDWB	33.7	34.7	38.3	53.3	65.9	73.6	76.7	73.0	62.3	51.8	42.8	36.4		(30)
(31)		5%	WB	32.0	32.3	33.7	42.0	54.0	62.2	66.2	63.0	55.6	47.5	39.1	34.1	(31)
(32)		MCDWB	32.7	33.3	35.7	47.3	63.0	69.8	73.9	70.1	59.1	48.9	40.2	34.8		(32)
(33)		10%	WB	30.1	30.3	32.4	39.3	51.1	59.2	64.1	61.0	53.9	45.3	36.3	32.7	(33)
(34)		MCDWB	31.0	31.6	34.3	44.1	59.6	67.9	71.1	67.1	57.3	46.8	37.1	33.5		(34)
(35)	Mean Daily Temperature Range		MDBR	10.4	11.4	13.1	14.0	15.1	14.3	13.5	11.2	7.4	7.4	9.0		(35)
(36)		5% DB	MCDBR	8.4	9.3	12.6	19.8	23.6	20.1	19.8	19.3	15.4	9.2	7.5	7.3	(36)
(37)			MCWBR	8.3	8.8	9.3	11.8	11.2	9.3	8.4	9.0	9.2	7.0	7.0	7.2	(37)
(38)			MCDBR	7.9	9.1	10.1	18.2	19.7	17.1	16.9	16.0	13.4	8.3	7.4	7.2	(38)
(39)		5% WB	MCWBR	7.9	8.8	8.1	11.6	11.2	8.9	8.5	8.5	8.9	7.0	7.1	7.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.223	0.280	0.308	0.344	0.351	0.344	0.374	0.354	0.328	0.304	0.229	0.206	(40)	
(41)		taud	1.970	2.092	2.155	2.296	2.443	2.496	2.428	2.461	2.515	2.385	2.046	1.954	(41)	
(42)		Ebn at Noon	112	198	245	264	274	278	265	260	245	196	108	50	(42)	
(43)		Edh at Noon	9	21	30	32	31	30	31	28	21	16	8	4	(43)	
(44)	All-Sky Solar Radiation	RadAvg	54	240	714	1176	1494	1700	1572	1155	651	243	58	21	(44)	
(45)		RadStd	6	45	83	117	148	140	181	114	72	32	10	2	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+1.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+1.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page