

PUDOZH, Russian Federation

WMO: 228310

Lat: 61.8214N

Lon: 36.5779E

Elev: 48

StdP: 100.75

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.5	-27.6	-34.4	0.1	-31.4	-30.4	0.2	-27.6	7.2	-2.7	6.1	-3.3	0.4	90	0.595

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	28.2	19.7	26.1	18.6	24.1	17.7	20.9	26.0	19.7	24.5	18.6	22.8	2.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.0	23.5	18.0	13.0	22.2	16.8	12.0	20.8	60.7	25.9	56.7	24.6	52.8	22.8	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.3	4.5	-33.6	30.6	3.9	2.5	-36.5	32.4	-38.8	33.8	-41.0	35.2	-43.8	37.0		
			-33.9	22.6	3.9	1.4	-36.7	23.6	-39.0	24.5	-41.1	25.3	-43.9	26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.0	-10.6	-9.9	-4.7	2.3	9.1	14.1	17.4	14.6	9.4	3.4	-2.9	-7.1
	DBStd	11.04	8.55	8.13	5.30	4.55	4.98	4.23	3.65	3.42	3.65	4.06	5.83	7.63
	HDD10.0	3153	637	558	454	233	78	9	1	4	53	208	388	529
	HDD18.3	5650	896	792	713	479	288	141	61	125	267	464	638	787
	CDD10.0	599	0	0	0	4	50	131	231	145	37	2	0	0
	CDD18.3	54	0	0	0	0	2	13	32	8	0	0	0	0
	CDH23.3	574	0	0	0	2	38	155	299	79	1	0	0	0
	CDH26.7	132	0	0	0	0	6	37	75	13	0	0	0	0
Wind	WSAvg	1.8	1.7	1.7	1.9	1.8	2.2	1.9	1.6	1.5	1.6	1.9	1.8	1.9
Precipitation	PrecAvg	690	42	32	40	41	48	57	68	80	73	81	66	58
	PrecMax	886	91	73	82	92	93	131	220	240	128	179	127	96
	PrecMin	490	8	8	10	13	5	17	14	22	28	3	9	18
	PrecStd	88	19	17	19	20	21	27	40	44	27	35	30	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	3.0	8.9	21.2	27.4	30.3	31.3	28.5	22.3	15.0	8.0	6.0
		MCWB	1.6	2.1	4.1	12.9	16.8	20.2	21.7	20.2	16.9	12.5	6.8	5.4
	2%	DB	1.3	1.8	5.2	15.8	23.6	27.5	28.7	25.5	19.1	11.7	6.5	3.5
		MCWB	0.8	1.1	1.9	9.1	14.5	19.1	20.4	18.6	14.7	10.3	5.8	2.9
	5%	DB	0.7	1.0	3.3	12.2	20.8	24.8	26.6	23.2	17.1	10.3	5.5	2.2
		MCWB	0.3	0.5	1.2	6.7	13.2	17.4	19.4	17.6	13.9	9.3	4.9	1.7
	10%	DB	0.0	0.2	2.1	9.6	18.3	22.5	24.6	21.3	15.4	9.2	4.0	1.2
		MCWB	-0.2	-0.3	0.7	5.3	11.7	15.9	18.5	16.5	12.9	8.2	3.5	0.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	2.4	4.4	12.8	18.4	22.0	23.2	21.8	17.6	12.8	7.1	5.4
		MCDB	1.8	2.8	7.8	19.9	24.8	28.1	29.0	26.5	21.3	14.6	7.6	5.9
	2%	WB	0.9	1.2	2.7	9.6	16.2	20.1	21.5	19.7	15.7	10.6	5.9	3.0
		MCDB	1.2	1.6	4.2	14.6	21.4	26.1	26.8	23.8	18.1	11.4	6.4	3.3
	5%	WB	0.4	0.6	1.7	7.5	14.1	18.5	20.2	18.3	14.3	9.5	4.9	1.7
		MCDB	0.7	1.0	2.8	11.4	19.2	23.6	25.0	21.8	16.4	10.2	5.5	2.1
	10%	WB	-0.2	-0.2	1.0	5.7	12.4	16.7	19.3	17.2	13.2	8.3	3.6	0.8
		MCDB	0.1	0.2	1.9	9.0	17.6	21.4	23.6	20.5	15.1	9.1	4.0	1.1
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.8	9.0	9.9	10.9	10.6	10.1	9.8	8.2	5.3	4.6	5.1
		MCDBR	4.2	4.8	9.8	14.8	15.4	14.5	13.5	13.3	11.6	7.0	4.5	3.7
		MCWBR	4.2	4.5	7.1	8.8	7.6	6.9	6.6	7.2	7.3	5.5	4.2	3.6
	5% WB	MCDWR	4.2	4.5	6.7	13.3	13.6	12.5	11.8	11.1	9.5	6.4	4.2	3.7
		MCWBR	4.2	4.4	5.0	8.5	7.5	6.4	6.3	6.5	6.4	5.3	4.1	3.7
Clear-Sky Solar Irradiance	taub		0.248	0.297	0.322	0.363	0.355	0.351	0.387	0.369	0.339	0.321	0.267	0.217
	taud		2.015	2.073	2.129	2.256	2.445	2.485	2.400	2.426	2.496	2.382	2.111	1.957
	Ebn at Noon		421	641	773	822	866	876	828	813	775	637	399	274
	Edh at Noon		39	74	100	109	99	97	103	92	72	56	35	23
All-Sky Solar Radiation	RadAvg		0.23	0.81	2.18	3.77	5.00	5.36	5.12	3.83	2.16	0.84	0.23	0.11
	RadStd		0.03	0.20	0.29	0.37	0.34	0.36	0.60	0.33	0.22	0.11	0.04	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	-221	-233	N/A	N/A

Nomenclature: See separate page