

MYS KAMENNYJ, Russian FederationWMO: **231460**Lat: **68.500N**Lon: **73.583E**Elev: **16**StdP: **14.69**Time Zone: **5.00 (E05)**Period: **86-94**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -42.8	(c) -39.1	(d) -46.8	(e) 0.4	(f) -42.0	(g) -43.3	(h) 0.4	(i) -38.6	(j) 42.2	(k) 24.7	(l) 37.0	(m) 0.9	(n) 7.5	(o) 60	(p) 1.086

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	66.4	61.4	62.5	58.0	59.2	55.4	62.1	65.6	58.4	61.5	55.9	58.7	13.4	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	78.2	65.1	56.8	68.7	60.5	54.2	62.6	58.1	27.9	65.8	25.4	61.8	23.8	58.8	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
36.7	32.3	28.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-46.9	71.1	7.0	6.7	-51.9	75.9	-56.0	79.8	-59.9	83.5	-65.0	88.4
			-45.7	64.2	5.3	5.7	-49.5	68.2	-52.6	71.6	-55.6	74.8	-59.5	78.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	-14.6	-14.0	0.0	3.9	23.8	36.2	51.3	49.7	40.2	21.9	3.8	-8.8
	DBStd	26.20	14.70	16.90	15.50	14.54	8.80	6.12	7.53	5.61	5.98	11.25	14.99	15.38
	HDD50	12478	2002	1793	1551	1382	812	417	72	76	295	871	1385	1822
	HDD65	17776	2467	2213	2016	1832	1277	865	432	473	743	1336	1835	2287
	CDD50	183	0	0	0	0	0	2	112	68	1	0	0	0
	CDD65	7	0	0	0	0	0	0	7	0	0	0	0	0
	CDH74	31	0	0	0	0	0	0	31	0	0	0	0	0
	CDH80	4	0	0	0	0	0	0	4	0	0	0	0	0
Wind	WSAvg	14.1	14.2	13.3	14.7	14.5	13.7	12.1	12.3	13.7	15.1	16.7	14.6	14.5
Precipitation	PrecAvg	15.3	0.9	0.9	0.8	0.9	1.1	1.1	1.4	2.2	2.0	1.3	1.0	1.0
	PrecMax	24.1	2.1	3.4	2.2	2.6	3.9	3.1	4.2	5.6	3.8	3.0	2.3	3.0
	PrecMin	9.2	0.1	0.0	0.1	0.0	0.4	0.0	0.1	0.2	0.7	0.5	0.3	0.1
	PrecStd	3.3	0.5	0.7	0.5	0.6	0.6	0.7	1.1	1.2	0.7	0.5	0.4	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.7	23.8	31.0	35.0	38.1	57.6	78.0	65.1	53.5	45.0	33.6	26.8
		MCWB	20.7	22.8	29.8	33.2	35.6	52.6	69.8	60.2	50.1	43.0	32.3	25.7
	2%	DB	15.4	19.4	28.5	33.6	36.4	50.1	70.5	61.7	51.7	40.7	30.6	23.3
		MCWB	14.8	18.5	27.7	32.4	34.4	47.3	65.8	58.0	49.3	39.4	29.7	22.6
	5%	DB	11.0	16.6	26.4	32.5	34.9	46.6	65.7	59.5	50.3	37.7	28.5	18.5
		MCWB	10.5	15.9	25.7	31.5	33.2	43.8	60.9	55.9	48.2	36.8	27.6	17.7
	10%	DB	6.7	11.9	23.4	29.2	33.9	43.8	62.7	57.9	48.6	34.7	25.8	14.6
		MCWB	6.0	11.1	22.5	28.3	32.5	41.0	57.9	54.8	46.6	33.8	25.1	13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	23.1	30.1	34.0	36.4	52.9	71.2	61.2	51.0	43.1	32.6	26.0
		MCDB	21.9	23.8	30.6	34.4	37.4	55.9	77.9	64.0	52.6	44.7	33.2	26.7
	2%	WB	14.8	18.6	27.8	32.8	34.8	47.5	65.8	58.3	49.8	39.4	29.9	22.8
		MCDB	15.2	19.2	28.4	33.6	35.9	50.2	70.4	60.8	51.3	40.7	30.4	23.5
	5%	WB	10.5	15.9	25.6	31.5	33.8	43.9	61.6	56.7	48.6	36.7	27.8	17.8
		MCDB	11.2	16.7	26.2	32.6	34.8	46.2	65.2	59.0	50.2	37.6	28.5	18.5
	10%	WB	6.1	10.9	22.6	28.3	32.8	41.3	58.2	55.2	46.8	34.1	25.0	14.1
		MCDB	6.7	11.6	23.4	29.2	33.9	43.4	61.7	57.3	48.5	34.6	25.7	14.8
Mean Daily Temperature Range	5% DB	MDBR	13.2	13.7	15.7	17.4	9.7	7.5	9.7	7.0	5.5	8.7	12.3	14.3
		MCDBR	22.0	16.2	18.7	13.8	6.8	13.3	13.3	9.1	6.9	6.9	12.5	15.8
		MCWBR	21.5	16.4	17.6	13.5	6.3	10.8	9.9	7.1	5.8	6.4	12.0	15.5
	5% WB	MCDBR	22.2	17.1	17.1	13.5	6.7	12.9	12.7	8.3	6.3	6.8	12.5	15.3
		MCWBR	21.8	16.9	17.1	13.3	6.5	10.9	10.4	7.0	5.9	6.3	12.5	14.9
Clear-Sky Solar Irradiance	taub	0.210	0.252	0.302	0.324	0.342	0.360	0.386	0.370	0.319	0.265	0.205	N/A	
	taud	1.865	1.988	2.029	2.066	2.134	2.314	2.344	2.371	2.450	2.200	1.936	N/A	
	Ebn at Noon	16	158	221	256	266	265	252	242	228	159	16	0	
	Edh at Noon	3	16	29	37	39	34	32	28	20	13	2	0	
All-Sky Solar Radiation	RadAvg	7	127	636	1290	1820	1758	1587	1003	512	167	24	0	
	RadStd	0	18	55	103	117	91	198	134	48	22	2	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page