

NOVY PORT, Russian Federation

WMO: 232420

Lat: 67.6878N

Lon: 72.8842E

Elev: 40

StdP: 14.67

Time Zone: 5.00 (E05)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.6	-37.5	-45.5	0.4	-40.3	-42.1	0.5	-37.1	42.7	13.2	36.9	10.3	6.5	0	0.939

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	74.1	65.8	69.7	63.1	64.9	59.3	66.4	73.0	63.2	69.6	60.1	64.5	8.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	88.0	70.8	60.2	78.1	66.9	57.5	70.8	63.7	31.1	72.9	28.7	70.4	26.6	64.1	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.7	26.8	23.6	-43.2	77.6	5.4	6.1	-47.0	82.0	-50.1	85.6	-53.1	89.0	-57.0	93.4
			-43.3	67.3	5.3	4.3	-47.1	70.4	-50.2	72.9	-53.1	75.3	-57.0	78.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	-10.3	-9.5	3.0	12.9	25.5	44.0	56.2	49.9	41.5	26.3	5.5	-2.7
	DBStd	25.47	14.38	16.02	14.97	11.71	8.09	8.35	8.58	6.01	6.48	9.33	14.00	15.61
	HDD50	11163	1869	1665	1458	1114	758	220	34	76	267	733	1336	1633
	HDD65	16315	2334	2085	1923	1564	1223	631	302	467	704	1198	1786	2098
	CDD50	354	0	0	0	0	0	41	225	75	13	0	0	0
	CDD65	29	0	0	0	0	0	1	28	0	0	0	0	0
	CDH74	94	0	0	0	0	0	5	89	0	0	0	0	0
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0
Wind	WSAvg	11.5	12.7	11.4	12.0	12.3	12.8	10.8	10.4	10.7	10.6	11.4	11.6	11.8
Precipitation	PrecAvg	15.6	1.0	0.7	0.9	0.8	1.1	1.3	1.5	2.2	1.8	1.4	1.0	1.1
	PrecMax	24.4	3.3	1.8	2.8	2.0	3.2	3.7	4.0	6.1	4.2	2.9	2.2	2.4
	PrecMin	10.1	0.4	0.0	0.2	0.0	0.5	0.2	0.1	0.5	0.1	0.4	0.2	0.1
	PrecStd	3.9	0.6	0.4	0.6	0.5	0.5	0.8	1.1	1.3	0.9	0.5	0.5	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	25.2	32.3	36.6	47.2	71.2	80.0	70.1	62.3	47.8	33.7	30.1
		MCWB	24.3	23.7	31.3	34.4	43.6	62.0	66.8	62.1	56.9	46.2	33.2	29.8
	2%	DB	19.2	21.5	29.8	34.6	39.8	65.5	76.5	65.0	56.7	42.1	31.2	25.6
		MCWB	18.0	20.7	28.7	33.1	37.3	59.0	66.4	59.6	54.5	40.7	30.7	24.7
	5%	DB	15.9	18.3	27.8	33.3	37.2	61.0	73.7	63.1	54.1	39.9	26.6	22.3
		MCWB	15.2	17.5	26.7	32.1	35.2	54.7	66.0	58.6	52.0	38.6	25.9	21.6
	10%	DB	10.1	14.0	24.5	31.3	35.1	56.7	70.3	60.5	51.6	37.4	23.8	18.7
		MCWB	9.4	13.3	23.4	30.3	33.3	51.6	64.1	56.7	49.5	36.2	23.0	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.4	24.1	31.4	35.1	43.9	63.2	70.2	63.0	57.1	46.0	33.0	29.8
		MCDB	26.1	25.0	32.2	36.4	46.1	70.0	75.9	67.1	61.2	47.5	33.2	30.0
	2%	WB	18.4	20.8	28.9	33.4	37.8	59.7	68.2	60.9	54.8	41.1	30.7	24.9
		MCDB	19.2	21.5	29.5	34.3	39.4	65.3	74.1	64.1	56.6	41.7	31.2	25.7
	5%	WB	15.1	17.6	26.6	32.4	35.1	55.6	66.2	59.1	52.2	38.8	25.9	21.6
		MCDB	16.0	18.4	27.7	33.6	36.7	60.3	73.0	62.9	53.8	39.8	26.4	22.3
	10%	WB	9.6	13.3	23.5	30.2	33.7	51.5	63.7	56.9	49.7	36.3	22.9	17.9
		MCDB	10.2	14.0	24.5	31.2	34.8	56.4	70.3	60.1	51.3	37.4	23.7	18.7
Mean Daily Temperature Range	5% DB	MDBR	13.1	12.8	14.4	14.2	8.6	9.5	11.2	11.1	7.6	7.0	11.3	13.0
		MCDBR	20.7	13.6	14.3	11.3	8.8	16.1	14.0	12.5	9.0	6.5	10.1	13.0
		MCWBR	19.0	13.6	14.4	10.7	7.1	11.2	7.7	8.7	6.6	5.9	10.3	13.1
	5% WB	MCDBR	19.2	13.6	14.6	11.1	8.6	15.4	13.4	11.7	8.5	6.3	10.4	13.3
		MCWBR	18.7	13.6	14.6	10.5	7.2	11.8	8.1	8.9	6.6	6.0	10.5	13.4
Clear-Sky Solar Irradiance	taub	0.209	0.255	0.304	0.326	0.343	0.363	0.389	0.371	0.320	0.271	0.203	N/A	
	taud	1.865	1.997	2.022	2.056	2.131	2.326	2.343	2.373	2.460	2.205	1.928	N/A	
	Ebn at Noon	30	167	224	257	267	266	253	244	231	166	30	0	
	Edh at Noon	3	17	30	38	40	34	33	29	20	14	3	0	
All-Sky Solar Radiation	RadAvg	10	149	670	1261	1899	1840	1612	1045	547	188	30	0	
	RadStd	1	24	52	152	88	103	199	121	64	30	3	0	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page