

TAZOVSKY, Russian Federation

WMO: 232560

Lat: 67.467N

Lon: 78.733E

Elev: 91

StdP: 14.65

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.6	-42.9	-52.8	0.2	-47.5	-48.2	0.3	-42.8	37.8	5.8	31.9	3.5	5.3	120	0.906

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	77.7	64.6	73.0	62.4	68.9	60.5	66.2	74.4	63.8	71.3	61.4	67.8	8.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.1	86.8	70.0	60.6	79.3	67.2	58.2	72.6	65.3	31.0	74.2	29.2	70.8	27.5	67.7	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.5	25.5	22.2	-49.1	83.1	7.1	4.1	-54.2	86.1	-58.4	88.5	-62.4	90.8	-67.6	93.8		
(5)			-49.1	68.9	6.9	2.7	-54.1	70.8	-58.2	72.4	-62.0	73.9	-67.1	75.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	-14.6	-12.4	-0.1	10.1	25.5	47.9	57.8	52.1	40.4	22.6	-1.3	-8.4	
	DBStd	28.66	17.29	17.13	16.61	14.44	10.21	11.22	8.04	6.89	7.61	12.19	16.25	17.65	
	HDD50	12004	2003	1748	1552	1196	761	176	17	53	302	848	1538	1810	
	HDD65	17015	2468	2168	2017	1646	1225	523	252	403	737	1313	1988	2275	
	CDD50	508	0	0	0	0	1	113	260	119	15	0	0	0	
	CDD65	45	0	0	0	0	0	10	31	4	0	0	0	0	
	CDH74	310	0	0	0	0	0	63	223	24	0	0	0	0	
	CDH80	57	0	0	0	0	0	8	47	2	0	0	0	0	
Wind	WSAvg	10.7	11.2	10.7	11.5	11.7	11.3	10.2	9.9	9.4	9.8	10.6	10.5	11.5	
Precipitation	PrecAvg	23.3	1.8	1.7	1.8	1.7	1.5	1.9	2.2	2.6	2.1	2.2	1.8	1.9	
	PrecMax	33.1	5.6	5.2	5.6	3.4	4.4	3.7	6.0	6.6	5.2	3.6	3.3	4.5	
	PrecMin	15.6	0.3	0.2	0.2	0.0	0.1	0.1	0.5	0.9	0.9	0.7	0.4	0.5	
	PrecStd	3.7	1.2	1.1	1.1	0.8	0.8	0.8	1.3	1.2	0.9	0.7	0.7	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	26.0	33.2	39.6	58.2	81.3	85.1	77.1	66.1	47.6	33.8	29.0	
		MCWB	24.9	25.5	31.5	35.8	50.2	62.2	67.4	63.9	58.1	46.7	33.0	28.5	
	2%	DB	19.9	21.4	29.9	36.8	47.3	74.8	79.9	71.8	59.5	43.1	31.2	25.8	
		MCWB	19.2	20.9	28.9	34.2	42.0	62.1	66.0	62.9	54.2	41.9	30.6	25.2	
	5%	DB	14.9	16.7	26.7	34.7	41.9	70.0	75.4	67.2	55.2	39.5	27.1	22.1	
		MCWB	14.2	16.0	26.0	32.9	38.2	60.0	64.3	60.0	51.1	38.5	26.4	21.4	
	10%	DB	9.8	11.8	23.1	32.5	37.8	65.4	71.0	63.1	51.6	36.3	22.6	17.4	
		MCWB	9.1	11.1	22.2	31.1	35.1	57.2	62.0	57.9	48.8	35.3	21.8	16.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.9	25.6	31.8	36.4	51.3	66.5	70.0	66.5	59.9	46.8	33.2	28.7
			MCDB	25.8	25.9	32.8	38.8	57.4	74.7	80.1	73.8	64.0	47.9	33.5	28.9
2%		WB	19.3	20.9	28.9	34.6	42.5	63.2	67.9	63.7	54.8	42.2	30.6	25.3	
		MCDB	20.1	21.4	29.8	36.4	47.0	71.8	76.0	69.7	58.5	42.8	31.1	25.8	
5%		WB	14.2	16.1	25.9	33.1	38.4	60.7	65.3	61.3	51.8	38.7	26.6	21.4	
		MCDB	14.8	16.6	26.6	34.7	41.6	68.9	73.6	65.9	54.8	39.4	27.1	22.0	
10%		WB	9.1	11.2	22.3	31.1	35.4	58.0	63.0	58.6	48.8	35.5	21.9	16.8	
		MCDB	9.8	11.8	23.1	32.6	37.4	65.1	70.3	62.7	51.3	36.3	22.6	17.4	
Mean Daily Temperature Range	5% DB	MDBR	12.9	13.1	14.6	15.2	10.9	12.1	13.5	11.5	9.6	8.8	12.4	12.8	
		MCDBR	17.3	15.7	15.1	10.6	13.9	18.4	19.0	17.1	15.9	9.0	13.1	13.9	
		MCWBR	16.8	15.7	15.0	9.2	9.6	9.0	8.9	8.8	10.1	8.0	13.1	13.8	
	5% WB	MCDBR	17.3	16.0	15.4	11.3	13.6	16.6	17.6	15.9	14.7	8.2	13.1	13.4	
		MCWBR	17.2	16.0	15.3	10.3	9.6	9.3	9.5	9.2	10.2	7.8	13.2	13.4	
Clear-Sky Solar Irradiance	taub	0.210	0.257	0.308	0.326	0.345	0.369	0.404	0.382	0.325	0.269	0.201	N/A		
	taud	1.868	2.005	2.017	2.069	2.168	2.386	2.290	2.318	2.431	2.179	1.899	N/A		
	Ebn at Noon	34	169	223	258	267	265	248	240	229	167	33	0		
	Edh at Noon	4	17	30	38	38	32	34	30	21	14	3	0		
All-Sky Solar Radiation	RadAvg	12	159	670	1358	1735	1748	1593	1049	565	186	34	0		
	RadStd	1	19	53	97	137	146	198	140	78	22	4	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+2.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+2.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page