

OKUNEV NOS, Russian Federation

WMO: 233050

Lat: 66.2574N

Lon: 52.5642E

Elev: 72

StdP: 14.66

Time Zone: 3.00 (E03)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.7	-28.2	-39.8	0.6	-34.5	-33.3	0.8	-27.9	18.8	18.8	17.1	18.1	2.6	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	80.1	63.2	75.9	61.8	72.1	60.3	65.4	75.3	63.6	72.8	62.0	70.0	7.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.8	82.9	68.9	60.1	77.7	67.3	58.2	72.7	66.7	30.2	75.5	29.0	72.9	27.8	69.8	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	16.0	14.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	31.0	-0.8	10.7	16.3	29.0	41.0	52.2	60.2	54.7	45.1	31.5	18.9	11.4
	DBStd	22.29	17.77	15.07	14.44	8.35	10.45	8.93	8.88	6.60	6.15	7.66	12.47	15.10
	HDD50	7666	1573	1099	1044	631	325	79	14	25	171	574	933	1198
	HDD65	12502	2038	1519	1509	1081	747	395	203	327	598	1039	1383	1663
	CDD50	714	0	0	0	0	45	144	331	170	24	0	0	0
	CDD65	74	0	0	0	0	2	10	55	7	0	0	0	0
	CDH74	572	0	0	0	0	21	72	431	48	0	0	0	0
	CDH80	118	0	0	0	0	2	11	100	5	0	0	0	0
(14) Wind	WSAvg	7.3	6.8	7.8	7.9	7.4	7.7	7.8	6.8	6.9	6.8	7.2	7.3	7.1
(15) Precipitation	PrecAvg	20.1	1.4	1.0	1.1	1.2	1.6	2.4	2.4	2.7	2.4	2.1	1.5	1.4
	PrecMax	23.4	2.0	1.5	2.1	2.4	3.0	5.4	5.6	4.6	9.3	3.6	2.6	1.9
	PrecMin	16.7	0.6	0.5	0.3	0.6	0.8	1.0	0.9	1.3	0.9	0.8	0.6	0.7
	PrecStd	2.0	0.4	0.3	0.5	0.6	0.6	1.1	1.1	0.7	1.9	0.7	0.6	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	35.8	41.5	54.4	77.1	80.7	87.6	79.1	66.4	47.3	37.7	34.9
		MCWB	32.5	34.3	36.1	43.9	58.4	64.2	64.8	65.2	59.0	44.7	35.7	33.6
	2%	DB	30.8	33.6	36.9	48.9	69.5	75.0	82.7	73.4	60.9	44.7	35.5	33.3
		MCWB	29.8	32.2	33.1	40.1	55.2	60.5	63.8	62.5	54.6	42.7	34.2	32.4
	5%	DB	27.3	31.6	35.1	44.2	63.2	71.3	78.8	69.4	56.7	42.8	34.2	31.3
		MCWB	26.4	30.1	32.3	37.6	51.7	58.6	62.6	60.6	52.0	41.3	33.1	30.1
	10%	DB	23.9	28.9	33.6	40.5	58.2	67.0	75.0	65.8	53.9	40.8	32.8	29.5
		MCWB	22.9	27.6	31.4	36.5	49.0	57.3	61.9	58.4	50.9	39.5	32.0	28.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.8	34.2	36.2	43.8	59.1	66.1	68.3	66.8	59.2	45.4	36.1	34.0
		MCDB	33.3	34.9	39.9	52.5	73.3	76.3	79.7	75.6	64.8	46.6	37.0	34.4
	2%	WB	30.0	32.4	34.0	40.5	56.0	63.5	66.3	63.9	55.4	43.1	34.4	32.6
		MCDB	30.7	33.5	35.9	45.5	67.8	72.2	77.1	70.9	59.7	44.3	35.2	33.4
	5%	WB	26.4	30.2	32.8	38.6	52.7	61.0	64.4	61.8	52.9	41.3	33.2	30.3
		MCDB	27.1	31.2	34.9	42.8	61.3	67.2	74.7	68.0	55.8	42.6	34.0	31.0
	10%	WB	23.0	27.6	31.4	37.0	49.4	58.0	63.0	59.6	51.1	39.6	32.1	28.5
		MCDB	24.0	29.0	33.6	40.3	57.5	65.8	72.9	64.9	53.7	40.8	32.9	29.5
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	10.9	14.2	13.6	14.7	14.5	14.9	13.1	9.8	6.6	8.9	9.9
		MCDBR	11.8	7.5	8.9	17.2	23.1	20.9	20.9	18.6	15.8	6.9	7.5	7.7
		MCWBR	11.5	8.0	6.5	11.0	12.0	10.0	7.4	10.4	10.0	5.7	7.6	7.7
	5% WB	MCDBR	11.3	8.0	7.5	13.4	21.7	18.2	17.9	16.2	12.9	6.3	7.5	7.2
		MCWBR	11.2	8.2	6.1	9.1	12.4	11.2	7.8	10.3	9.1	5.4	7.5	7.2
(40) Clear-Sky Solar Irradiance	taub		0.215	0.265	0.303	0.335	0.345	0.352	0.405	0.368	0.328	0.288	0.213	0.214
	taud		1.910	2.053	2.096	2.134	2.370	2.466	2.312	2.401	2.487	2.282	1.953	1.922
	Ebn at Noon		60	180	235	259	272	272	250	249	235	177	58	5
	Edh at Noon		6	18	29	36	32	30	34	28	21	15	5	1
(44) All-Sky Solar Radiation	RadAvg		28	219	705	1225	1565	1598	1550	1022	545	184	44	3
	RadStd		2	22	71	121	153	183	195	109	52	24	8	0

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-731	-806	N/A	N/A

Nomenclature: See separate page