

NADYM, Russian Federation

WMO: 234450

Lat: 65.4802N

Lon: 72.6892E

Elev: 19

StdP: 101.10

Time Zone: 5.00 (E05)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.2	-40.9	-47.9	0.0	-44.1	-44.8	0.0	-40.8	10.4	-14.9	9.3	-16.2	1.1	320	0.779

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	28.8	18.3	26.2	17.3	23.4	16.2	19.5	25.7	18.3	24.6	17.0	22.1	3.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.4	22.0	16.0	11.4	20.3	14.6	10.4	19.3	55.6	25.5	51.8	24.4	47.9	22.1	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.8	8.6	7.7	DB	-45.3	31.7	3.3	3.3	-47.6	34.0	-49.6	35.9	-51.4	37.8	-53.8	40.1	(4)
(5)			WB	-45.3	21.5	3.2	2.5	-47.7	23.2	-49.6	24.7	-51.4	26.0	-53.7	27.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.3	-23.7	-21.5	-12.0	-5.1	0.8	12.5	15.7	12.0	6.4	-2.6	-15.3	-19.5	(6)	
	DBStd	15.28	8.93	9.37	8.23	6.33	5.83	5.79	4.89	3.80	4.34	6.09	9.15	10.36	(7)	
	HDD10.0	5611	1046	882	682	454	293	39	5	21	125	391	761	913	(8)	
	HDD18.3	8297	1304	1115	941	704	542	189	114	199	358	649	1011	1172	(9)	
	CDD10.0	409	0	0	0	0	9	115	183	84	17	1	0	0	(10)	
	CDD18.3	52	0	0	0	0	0	15	33	3	0	0	0	0	(11)	
	CDH23.3	585	0	0	0	0	7	171	379	28	1	0	0	0	(12)	
	CDH26.7	173	0	0	0	0	1	41	131	1	0	0	0	0	(13)	
(14) Wind	WSAvg	3.5	2.9	3.1	3.6	3.9	4.3	3.8	3.6	3.4	3.4	3.4	3.3	3.0	(14)	
(15) Precipitation	PrecAvg	514	25	21	25	32	36	60	69	72	52	57	36	30	(15)	
	PrecMax	683	53	40	42	67	74	94	219	148	113	92	69	59	(16)	
	PrecMin	350	8	8	3	2	6	18	10	16	19	24	15	13	(17)	
	PrecStd	77	10	9	10	16	17	17	46	30	25	16	14	10	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.4	-1.4	4.0	9.5	23.8	30.8	32.0	26.3	21.1	11.8	2.8	0.0	(19)	
		MCWB	-2.4	-2.0	1.1	4.7	14.0	18.0	19.9	18.4	15.9	9.2	2.0	-0.6	(20)	
	2%	DB	-6.3	-3.8	1.9	7.0	18.1	27.5	30.0	23.7	17.2	7.9	1.3	-2.0	(21)	
		MCWB	-6.9	-4.4	-0.3	3.2	11.1	16.7	18.7	16.6	13.0	6.7	0.8	-2.6	(22)	
	5%	DB	-8.4	-5.8	0.5	5.1	13.2	25.2	27.9	21.2	14.9	6.0	-0.9	-3.8	(23)	
		MCWB	-8.6	-6.4	-0.8	2.3	8.8	16.1	18.6	15.3	11.7	5.0	-1.3	-4.1	(24)	
	10%	DB	-11.0	-8.4	-0.9	3.4	9.2	22.3	24.9	18.8	13.0	4.5	-3.0	-6.0	(25)	
		MCWB	-11.3	-8.9	-1.9	1.1	5.6	14.9	17.5	14.7	10.7	3.4	-3.3	-6.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.4	-2.0	1.2	5.7	14.5	19.9	21.8	19.2	16.2	9.4	2.3	-0.5	(27)	
		MCDB	-2.4	-1.5	3.0	8.5	22.2	25.5	28.5	23.2	20.3	11.3	2.7	-0.1	(28)	
	2%	WB	-6.6	-4.4	0.2	3.7	11.7	18.2	20.2	17.6	13.9	6.9	0.9	-2.5	(29)	
		MCDB	-6.3	-3.9	1.5	6.3	17.7	24.7	26.9	22.1	16.3	7.4	1.3	-2.1	(30)	
	5%	WB	-8.7	-6.4	-0.7	2.5	9.0	17.1	19.1	16.3	12.2	5.1	-1.2	-4.1	(31)	
		MCDB	-8.4	-5.8	0.5	4.6	13.4	23.3	25.6	20.0	14.3	6.0	-0.9	-3.7	(32)	
	10%	WB	-11.5	-9.0	-1.9	1.5	5.9	15.6	18.0	15.1	10.7	3.5	-3.3	-6.4	(33)	
		MCDB	-11.2	-8.6	-0.8	3.1	9.2	20.9	24.6	18.5	12.5	4.3	-3.1	-6.1	(34)	
(35) Mean Daily Temperature Range	MDBR		7.9	8.9	10.4	10.0	8.1	9.6	9.5	8.4	6.6	5.1	7.6	7.8	(35)	
	5% DB	MCDBR	9.6	7.7	8.1	8.5	14.0	14.0	14.3	12.3	9.5	5.4	6.3	7.0	(36)	
		MCWBR	9.6	7.4	6.7	5.8	8.2	6.3	5.4	6.2	5.8	4.4	6.1	6.9	(37)	
	5% WB	MCDBR	9.5	8.1	8.1	7.4	13.7	12.8	12.9	10.7	8.3	5.1	6.4	7.0	(38)	
		MCWBR	9.5	7.7	6.9	5.4	8.6	6.7	5.5	6.4	5.6	4.4	6.2	6.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.210	0.268	0.319	0.336	0.358	0.377	0.402	0.381	0.331	0.289	0.205	0.215	(40)	
	taud		1.881	2.031	2.020	2.078	2.223	2.385	2.317	2.348	2.446	2.215	1.915	1.890	(41)	
	Ebn at Noon		241	583	721	816	840	834	795	774	742	565	236	38	(42)	
	Edh at Noon		22	62	101	122	118	104	108	95	69	51	20	6	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.11	0.77	2.40	4.54	5.31	5.15	4.85	3.31	1.90	0.68	0.19	0.03	(44)	
	RadStd		0.01	0.06	0.13	0.34	0.40	0.41	0.61	0.38	0.24	0.08	0.02	0.00	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page