

KRASNOSELKUPSKY, Russian FederationWMO: **234650**Lat: **65.7065N**Lon: **82.4552E**Elev: **81**StdP: **14.65**Time Zone: **5.00 (E05)**Period: **86-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-51.5	-46.2	-56.0	0.2	-51.1	-50.8	0.3	-46.1	21.1	3.9	19.1	4.7	4.3	40	0.781

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	82.8	64.7	78.6	62.8	74.1	61.9	67.2	77.5	64.9	74.2	62.8	72.3	7.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	88.4	72.0	61.1	80.7	69.4	58.8	74.1	67.2	31.8	77.4	30.0	74.5	28.4	71.8	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
20.3	17.9	15.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-53.9	69.0	4.7	2.3	-57.3	70.7	-60.1	72.1	-62.7	73.4	-66.1	75.1
				</										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.9	-14.7	-8.8	6.4	16.9	31.9	54.8	62.2	54.2	43.4	23.9	-2.0	-7.8	
	DBStd	29.50	17.33	16.35	16.43	13.51	9.93	10.77	7.91	6.22	7.79	11.76	15.47	18.63	
	HDD50	11057	2006	1647	1352	994	565	72	4	28	227	809	1560	1793	
	HDD65	15839	2471	2067	1817	1444	1026	337	151	337	648	1273	2010	2258	
	CDD50	794	0	0	0	0	5	217	383	159	29	1	0	0	
	CDD65	99	0	0	0	0	1	32	64	2	0	0	0	0	
	CDH74	937	0	0	0	0	4	322	598	13	0	0	0	0	
	CDH80	228	0	0	0	0	0	84	144	0	0	0	0	0	
Wind	WSAvg	7.9	7.5	7.3	8.4	9.2	8.9	8.4	7.4	7.1	7.4	8.4	7.3	7.8	
Precipitation	PrecAvg	32.9	2.5	2.3	2.4	2.4	2.4	2.5	2.2	3.2	2.7	4.1	3.2	3.0	
	PrecMax	40.0	5.6	5.2	4.4	3.9	4.2	4.7	3.9	4.8	5.0	6.9	6.1	4.3	
	PrecMin	21.9	0.7	0.4	0.5	0.3	0.7	0.9	0.5	1.7	1.1	1.4	1.1	0.9	
	PrecStd	4.2	1.1	0.9	0.9	0.8	0.9	0.8	0.8	0.9	0.9	1.2	1.2	1.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.8	26.4	37.3	48.7	64.8	86.1	87.6	75.8	69.9	54.6	32.4	30.7	
		MCWB	22.5	25.3	31.6	38.8	53.9	64.4	67.2	63.8	58.0	47.2	30.8	29.8	
	2%	DB	18.0	21.8	34.0	42.8	56.6	82.6	84.0	72.0	63.9	45.1	28.6	26.5	
		MCWB	16.8	20.7	30.9	36.4	47.1	65.9	64.6	60.8	56.4	43.4	27.5	25.1	
	5%	DB	14.3	18.2	31.3	39.5	50.0	77.5	80.8	68.8	58.9	41.0	25.2	22.3	
		MCWB	13.4	17.5	29.0	34.9	42.4	63.1	63.8	59.4	52.7	38.5	24.3	21.3	
	10%	DB	8.9	13.5	28.5	36.4	45.2	72.1	76.9	65.4	54.8	37.4	20.6	17.4	
		MCWB	8.1	12.5	26.7	32.9	39.5	60.8	62.6	57.8	50.4	35.0	19.8	16.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	25.2	33.7	39.7	56.3	69.9	71.0	65.8	60.6	46.6	31.3	30.1
			MCDB	23.9	26.1	34.9	46.4	64.6	81.0	80.9	72.9	68.4	51.7	32.4	30.7
2%		WB	17.1	20.8	31.1	37.4	48.2	66.8	68.2	62.6	56.8	43.6	27.6	25.6	
		MCDB	18.1	21.6	33.6	41.4	55.2	77.8	78.4	68.9	62.2	45.4	28.6	26.6	
5%		WB	13.5	17.3	29.0	35.3	43.4	64.0	66.0	60.5	53.4	39.1	24.3	21.2	
		MCDB	14.3	18.0	31.1	39.1	48.0	73.2	76.3	66.8	58.9	40.7	25.0	22.2	
10%		WB	8.1	12.6	26.6	33.2	40.4	61.5	64.1	58.5	50.6	35.4	19.7	16.6	
		MCDB	8.8	13.2	28.5	36.2	44.9	71.5	73.3	64.5	54.2	37.0	20.4	17.4	
Mean Daily Temperature Range	5% DB	MDBR	13.2	15.7	17.6	17.8	13.0	16.5	16.5	13.7	11.3	9.6	12.9	14.1	
		MCDBR	14.2	18.5	15.2	17.3	18.9	23.0	21.8	19.2	18.0	10.0	13.8	14.0	
		MCWBR	14.4	18.3	13.3	13.3	12.2	10.0	9.0	10.6	10.9	7.8	13.8	13.4	
	5% WB	MCDBR	14.1	18.0	14.7	15.7	17.3	21.1	19.4	16.7	15.8	9.4	14.4	13.8	
		MCWBR	14.1	17.8	13.1	12.7	12.2	11.2	10.1	10.3	10.0	8.1	14.2	13.1	
Clear-Sky Solar Irradiance	taub	0.216	0.270	0.317	0.337	0.353	0.370	0.412	0.393	0.340	0.282	0.205	0.218		
	taud	1.870	2.012	2.009	2.059	2.212	2.412	2.279	2.306	2.404	2.199	1.900	1.876		
	Ebn at Noon	68	181	228	258	268	267	248	240	230	180	69	9		
	Edh at Noon	7	20	32	39	38	32	36	31	23	16	6	2		
All-Sky Solar Radiation	RadAvg	30	234	743	1397	1693	1755	1594	1029	580	215	62	7		
	RadStd	5	23	62	141	166	150	176	112	87	34	10	0		