

OKTYABR'SKOE, Russian Federation

WMO: 237340

Lat: 62.450N

Lon: 66.050E

Elev: 236

StdP: 14.57

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-35.3	-30.2	-40.3	0.5	-35.0	-35.2	0.8	-30.0	12.3	1.7	10.7	2.8	1.1	130	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	81.5	67.3	78.1	65.2	74.6	63.4	69.2	78.2	67.1	75.5	65.0	72.6	4.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	96.1	74.0	63.8	89.4	71.7	61.7	83.0	69.6	33.4	78.3	31.8	75.7	30.1	72.8	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.6	10.3	9.1	-38.8	86.8	7.7	2.0	-44.4	88.2	-48.9	89.3	-53.2	90.4	-58.8	91.8		
			-39.5	72.0	7.8	1.8	-45.1	73.2	-49.6	74.3	-54.0	75.3	-59.7	76.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.4	-4.2	0.7	16.9	29.9	44.0	57.4	62.8	55.5	44.7	31.7	11.2	0.4	
	DBStd	25.61	14.87	13.87	11.19	10.26	10.08	9.43	7.85	7.23	7.60	8.75	14.42	16.39	
	HDD50	8468	1680	1381	1025	603	248	36	4	25	195	569	1163	1539	
	HDD65	13106	2145	1801	1490	1052	652	262	139	307	608	1033	1613	2004	
	CDD50	956	0	0	0	1	63	258	400	196	37	1	0	0	
	CDD65	119	0	0	0	0	2	34	70	13	0	0	0	0	
	CDH74	842	0	0	0	0	29	255	485	73	0	0	0	0	
	CDH80	146	0	0	0	0	2	51	82	11	0	0	0	0	
Wind	WSAvg	3.7	2.8	3.1	3.9	4.4	4.6	4.6	4.0	3.7	3.7	3.6	3.3	2.9	
Precipitation	PrecAvg	23.3	1.3	0.9	1.1	1.3	1.9	2.5	3.0	3.3	2.5	2.3	1.8	1.5	
	PrecMax	33.5	2.2	2.6	2.7	3.0	4.0	6.1	6.7	7.0	5.2	5.2	3.7	2.6	
	PrecMin	16.1	0.4	0.1	0.2	0.3	0.3	0.4	0.3	1.0	0.3	0.7	0.3	0.4	
	PrecStd	3.9	0.4	0.5	0.6	0.7	0.9	1.3	1.7	1.3	1.2	0.9	0.7	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.5	32.7	42.1	60.1	78.1	85.1	85.6	80.7	70.0	55.3	38.4	32.2	
		MCWB	29.6	31.1	35.0	48.4	59.6	66.8	69.4	68.5	62.0	50.1	36.8	31.2	
	2%	DB	25.1	28.1	37.4	51.8	71.7	80.6	82.4	75.3	64.5	50.5	35.2	29.1	
		MCWB	24.4	26.4	32.3	42.6	57.2	65.6	68.7	65.1	57.7	47.0	34.0	28.2	
	5%	DB	21.1	23.7	34.1	47.2	66.3	76.5	79.4	71.3	59.8	46.9	32.5	25.4	
		MCWB	20.3	22.5	30.8	40.1	54.2	63.0	67.0	62.9	54.2	44.3	31.6	24.6	
	10%	DB	16.4	19.8	31.7	43.5	60.7	72.3	76.3	67.3	56.0	43.0	30.0	21.9	
		MCWB	15.7	18.7	29.2	37.8	50.9	61.4	65.1	60.5	51.9	40.9	29.2	21.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.1	31.0	35.8	50.1	61.2	70.1	72.1	70.6	62.7	51.0	36.9	31.5
			MCDB	30.4	32.4	40.9	58.7	73.4	79.5	81.3	78.9	68.7	54.1	37.5	32.0
2%		WB	24.6	26.6	33.1	44.2	57.9	67.1	70.1	67.0	58.2	47.5	34.1	28.4	
		MCDB	25.1	28.0	36.0	50.0	69.9	76.7	79.5	73.4	63.4	50.0	34.8	29.2	
5%		WB	20.3	22.7	31.3	41.0	54.8	64.8	68.2	64.0	55.1	44.3	31.7	24.7	
		MCDB	21.0	23.7	33.8	46.3	64.3	74.4	77.3	69.2	58.6	46.7	32.5	25.4	
10%		WB	15.7	18.7	29.2	38.3	51.8	62.3	66.4	61.4	52.4	41.1	29.2	21.3	
		MCDB	16.4	19.8	31.7	43.0	60.6	71.1	74.7	66.2	55.8	42.8	30.0	22.0	
Mean Daily Temperature Range	5% DB	MDBR	11.5	12.4	14.6	15.5	16.8	16.2	15.7	13.6	11.6	8.9	10.3	11.8	
		MCDBR	11.4	12.0	15.0	19.0	23.2	20.9	19.2	18.6	16.4	13.2	8.5	12.2	
		MCWBR	11.5	11.4	11.8	12.5	12.4	10.5	9.6	10.2	10.2	9.8	8.4	12.1	
	5% WB	MCDBR	11.8	12.1	14.1	16.8	21.4	19.9	17.7	16.8	15.3	13.0	9.1	11.8	
		MCWBR	11.8	11.6	11.8	12.0	12.8	11.1	9.7	10.0	10.3	10.1	8.9	11.8	
Clear-Sky Solar Irradiance	taub	0.238	0.290	0.335	0.366	0.373	0.390	0.428	0.399	0.348	0.311	0.246	0.229		
	taud	1.957	2.033	2.016	2.092	2.332	2.371	2.248	2.309	2.423	2.316	2.023	1.908		
	Ebn at Noon	125	200	235	256	267	264	248	245	239	199	120	64		
	Edh at Noon	12	23	35	40	35	34	38	33	24	18	11	7		
All-Sky Solar Radiation	RadAvg	90	356	837	1346	1572	1684	1646	1151	673	298	101	40		
	RadStd	6	28	55	151	128	98	149	105	85	37	14	3		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	+1.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page