

BAYKIT, Russian Federation

WMO: 238910

Lat: 61.6801N

Lon: 96.3630E

Elev: 262

StdP: 98.22

Time Zone: 7.00 (E07)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.2	-45.0	-49.3	0.0	-47.3	-47.0	0.0	-45.0	5.1	-15.9	4.2	-19.8	0.0	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	28.8	18.1	26.7	16.7	24.3	15.9	19.2	26.1	18.1	24.1	17.0	22.1	1.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	12.5	21.1	15.9	11.6	19.9	14.8	10.9	19.4	55.9	25.9	52.3	24.4	48.7	21.9	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	4.6	3.8	DB	-47.2	31.4	3.9	2.4	-50.0	33.2	-52.3	34.6	-54.5	35.9	-57.4	37.6	(4)
(5)			WB	-47.2	21.3	3.9	1.0	-50.0	22.0	-52.3	22.6	-54.5	23.1	-57.3	23.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.2	-30.1	-24.0	-11.5	-2.0	4.5	14.6	17.0	13.3	5.6	-3.7	-19.8	-27.1	(6)	
	DBStd	17.60	8.19	8.54	7.42	5.35	4.26	4.50	3.38	3.50	4.07	6.27	10.24	10.83	(7)	
	HDD10.0	6031	1243	951	665	359	179	13	1	10	142	423	895	1150	(8)	
	HDD18.3	8615	1501	1184	923	609	429	126	66	161	381	682	1145	1408	(9)	
	CDD10.0	498	0	0	0	0	8	151	217	111	11	0	0	0	(10)	
	CDD18.3	41	0	0	0	0	0	14	23	3	0	0	0	0	(11)	
	CDH23.3	672	0	0	0	0	3	293	317	58	2	0	0	0	(12)	
	CDH26.7	178	0	0	0	0	0	88	83	7	0	0	0	0	(13)	
(14) Wind	WSAvg	1.3	0.5	0.8	1.4	1.9	2.0	1.6	1.6	1.4	1.4	1.2	0.8	0.5	(14)	
(15) Precipitation	PrecAvg	511	27	20	21	27	41	51	49	83	56	54	46	33	(15)	
	PrecMax	645	51	50	44	52	92	94	85	151	101	108	77	61	(16)	
	PrecMin	324	10	4	1	8	6	13	7	15	12	25	11	17	(17)	
	PrecStd	75	10	11	11	11	19	20	24	39	22	22	16	11	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.8	-2.8	6.3	13.8	22.8	32.0	31.0	27.7	21.9	9.8	1.5	-4.3	(19)	
		MCWB	-10.4	-3.7	1.1	6.5	11.5	19.1	19.2	17.4	14.0	7.6	0.3	-4.9	(20)	
	2%	DB	-12.0	-5.5	3.5	10.6	19.5	29.3	29.1	25.0	18.1	7.2	0.0	-5.7	(21)	
		MCWB	-12.6	-6.3	-0.2	4.6	10.8	17.5	18.8	15.8	11.9	5.2	-1.0	-6.3	(22)	
	5%	DB	-15.4	-8.6	1.0	8.2	16.0	26.8	27.1	22.3	14.7	5.1	-1.7	-8.2	(23)	
		MCWB	-15.9	-9.5	-1.7	3.1	8.6	16.2	17.2	15.5	10.3	3.8	-2.6	-8.6	(24)	
	10%	DB	-18.3	-11.2	-1.0	6.1	12.7	24.3	24.7	20.0	12.0	3.3	-4.2	-11.1	(25)	
		MCWB	-18.7	-11.8	-3.1	1.7	6.8	15.4	16.6	14.8	9.0	2.1	-4.9	-11.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.2	-3.5	1.7	7.1	13.1	20.3	21.5	19.0	14.8	8.2	0.5	-4.8	(27)	
		MCDB	-9.9	-2.8	5.1	12.8	20.9	29.5	28.2	25.0	19.2	9.8	1.2	-4.4	(28)	
	2%	WB	-12.5	-6.3	0.1	5.1	11.2	18.5	19.7	17.5	13.0	5.6	-0.8	-6.4	(29)	
		MCDB	-11.9	-5.5	3.0	9.9	18.5	26.7	26.0	22.1	17.0	6.9	-0.1	-5.8	(30)	
	5%	WB	-15.8	-9.4	-1.4	3.6	9.3	17.2	18.7	16.3	11.1	3.8	-2.6	-8.6	(31)	
		MCDB	-15.3	-8.7	0.9	7.1	15.3	24.7	24.8	20.1	13.5	4.9	-1.7	-8.2	(32)	
	10%	WB	-18.6	-11.8	-3.1	2.3	7.4	16.0	17.7	15.2	9.3	2.2	-5.0	-11.6	(33)	
		MCDB	-18.3	-11.1	-1.1	5.4	12.0	22.7	22.9	19.2	11.7	3.2	-4.3	-11.1	(34)	
(35) Mean Daily Temperature Range	MDBR		6.9	10.1	12.5	10.6	10.2	12.7	11.6	10.2	8.6	5.7	7.3	6.7	(35)	
	5% DB	MCDBR	8.7	9.4	12.6	12.9	16.8	18.3	16.3	14.8	14.8	7.6	6.3	7.4	(36)	
		MCWBR	8.5	8.4	9.4	7.8	9.0	7.7	7.1	6.9	8.2	5.5	5.9	7.2	(37)	
	5% WB	MCDBR	8.7	8.8	12.0	11.6	15.6	16.1	13.6	12.3	12.0	6.3	6.2	7.4	(38)	
		MCWBR	8.4	8.2	9.1	7.6	8.9	7.4	6.8	6.8	7.2	5.0	5.9	7.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.250	0.289	0.318	0.349	0.364	0.387	0.427	0.417	0.341	0.301	0.237	0.213	(40)	
	taud		1.919	1.989	2.017	2.038	2.233	2.369	2.246	2.220	2.416	2.224	1.969	1.862	(41)	
	Ebn at Noon		401	641	771	827	852	839	787	756	768	643	419	264	(42)	
	Edh at Noon		43	80	112	135	121	109	120	113	77	63	39	25	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.35	1.26	2.77	4.32	5.01	5.58	5.05	3.59	2.18	0.97	0.43	0.17	(44)	
	RadStd		0.03	0.09	0.19	0.38	0.38	0.54	0.45	0.31	0.33	0.13	0.06	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page