

GAJNY, Russian Federation

WMO: 239090

Lat: 60.2875N

Lon: 54.3342E

Elev: 198

StdP: 98.97

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -31.9	(c) -28.6	(d) -34.5	(e) 0.1	(f) -31.8	(g) -31.2	(h) 0.2	(i) -28.6	(j) 8.0	(k) -8.1	(l) 7.4	(m) -8.1	(n) 2.0	(o) 250	(p) 0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.5	(c) 28.4	(d) 19.7	(e) 26.5	(f) 18.6	(g) 24.5	(h) 17.3	(i) 20.7	(j) 26.6	(k) 19.6	(l) 24.8	(m) 18.5	(n) 23.0	(o) 2.9	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.7	23.4	17.6	12.9	22.3	16.6	12.1	21.3	60.4	27.0	56.9	24.9	53.3	23.1	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.5	(b) 6.8	(c) 6.2	(e) -34.8	(f) 30.9	(g) 3.9	(h) 1.3	(i) -37.6	(j) 31.8	(k) -39.8	(l) 32.6	(m) -42.0	(n) 33.3	(o) -44.9	(p) 34.2		
(a) 7.5	(b) 6.8	(c) 6.2	(e) -34.9	(f) 21.9	(g) 3.9	(h) 1.1	(i) -37.6	(j) 22.7	(k) -39.9	(l) 23.4	(m) -42.1	(n) 24.0	(o) -44.9	(p) 24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.7	-14.0	-12.6	-4.9	2.5	9.4	14.9	17.7	14.3	8.8	1.8	-6.6	-11.9		
	DBStd	12.45	7.65	7.55	5.03	5.25	5.70	4.65	4.47	4.40	4.35	4.67	6.78	8.09		
	HDD10.0	3684	745	633	463	230	83	11	3	9	72	259	499	678		
	HDD18.3	6160	1003	866	722	475	280	122	67	140	286	514	749	936		
	CDD10.0	652	0	0	0	5	66	158	240	142	37	3	0	0		
	CDD18.3	86	0	0	0	0	4	19	46	15	1	0	0	0		
	CDH23.3	661	0	0	0	1	36	146	370	106	3	0	0	0		
	CDH26.7	144	0	0	0	0	4	27	87	27	0	0	0	0		
(14) Wind	WSAvg	3.2	3.2	3.3	3.5	3.4	3.3	3.2	2.8	2.9	3.2	3.4	3.3	3.2		
(15) Precipitation	PrecAvg	660	42	29	41	37	59	80	72	78	61	64	53	44		
	PrecMax	848	69	72	86	79	160	176	193	147	92	114	103	77		
	PrecMin	521	10	3	9	0	21	10	14	11	14	30	12	20		
	PrecStd	75	14	16	17	19	32	37	38	32	20	20	21	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.3	1.3	8.3	20.1	26.8	29.4	30.6	29.8	23.0	16.5	7.6	2.3		
		MCWB	-0.1	0.0	3.3	11.1	15.5	19.5	20.5	20.5	15.6	10.5	6.8	2.1		
	2%	DB	-0.8	0.2	5.0	15.4	24.0	27.0	29.0	26.2	19.1	12.6	3.9	0.8		
		MCWB	-1.2	-0.4	1.2	8.4	14.1	18.2	20.4	19.0	14.4	9.2	3.4	0.4		
	5%	DB	-2.2	-0.9	3.1	12.3	21.5	24.8	27.3	23.4	16.9	10.2	1.9	-0.2		
		MCWB	-2.5	-1.6	0.2	6.4	12.8	17.1	19.4	17.6	13.0	8.2	1.4	-0.5		
	10%	DB	-4.0	-2.5	1.4	9.9	18.9	22.6	25.4	21.2	15.0	8.2	0.7	-1.8		
		MCWB	-4.4	-3.2	-0.4	5.1	11.8	16.0	18.5	16.5	12.1	6.9	0.3	-2.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.1	0.6	3.7	11.4	17.7	21.1	22.1	21.4	16.8	12.0	6.5	2.1		
		MCDB	0.2	1.0	6.9	18.2	24.1	27.1	28.4	27.9	21.4	14.4	7.2	2.2		
	2%	WB	-1.1	-0.3	2.0	9.2	15.5	19.5	21.0	19.8	15.0	9.8	3.5	0.6		
		MCDB	-0.7	0.2	4.0	14.2	21.1	24.8	27.4	25.3	18.1	11.9	3.8	0.7		
	5%	WB	-2.5	-1.6	0.8	7.4	14.0	18.3	20.2	18.3	13.6	8.4	1.6	-0.5		
		MCDB	-2.2	-1.0	2.3	11.2	19.5	23.2	25.6	22.2	16.0	10.0	1.8	-0.3		
	10%	WB	-4.4	-3.2	-0.2	5.7	12.5	17.0	19.2	17.1	12.5	7.0	0.4	-2.2		
		MCDB	-4.0	-2.4	1.3	9.3	18.0	21.4	24.1	20.5	14.5	8.1	0.7	-1.9		
(35) Mean Daily Temperature Range	MDBR		5.7	6.4	7.3	8.1	9.6	9.2	9.5	8.1	6.6	4.4	4.3	5.1		
	5% DB	MCDBR	5.6	5.4	8.3	11.6	12.8	11.6	11.8	10.9	9.1	7.2	3.9	3.7		
		MCWBR	5.6	5.3	5.6	6.6	6.1	5.1	4.9	4.9	5.0	4.7	3.9	3.9		
	5% WB	MCDBR	5.6	5.5	6.6	10.3	11.0	10.3	10.6	9.8	7.8	6.6	3.9	3.8		
		MCWBR	5.7	5.4	5.1	6.4	6.3	5.1	4.9	4.8	4.8	4.9	4.0	4.0		
(40) Clear-Sky Solar Irradiance	taub		0.268	0.303	0.347	0.374	0.371	0.368	0.399	0.392	0.355	0.325	0.282	0.250		
	taud		1.986	2.030	1.998	2.125	2.377	2.429	2.343	2.344	2.413	2.326	2.088	1.938		
	Ebn at Noon		449	657	748	814	855	863	821	795	765	652	437	308		
	Edh at Noon		48	83	119	127	107	103	110	102	80	63	43	32		
(44) All-Sky Solar Radiation	RadAvg		0.36	1.12	2.32	3.62	4.81	5.19	5.26	3.76	2.15	0.89	0.33	0.18		
	RadStd		0.05	0.24	0.32	0.53	0.54	0.41	0.48	0.40	0.25	0.09	0.07	0.03		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	-274	-327	N/A	N/A

Nomenclature: See separate page