

SYM, Russian Federation

WMO: 239750

Lat: 60.3472N

Lon: 88.3636E

Elev: 86

StdP: 100.30

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-47.4	-43.4	-49.4	0.0	-47.4	-45.9	0.0	-43.4	8.1	-9.9	7.0	-13.7	0.2	310	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	29.6	18.5	27.7	17.9	25.5	17.1	20.5	26.2	19.2	24.8	18.2	23.7	2.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.5	22.6	17.3	12.5	21.5	16.1	11.6	20.4	59.5	26.2	55.4	24.9	51.9	23.7	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.1	5.2	DB	-48.8	33.1	5.1	1.8	-52.5	34.4	-55.4	35.5	-58.3	36.5	-62.0	37.8	(4)
(5)			WB	-49.0	22.5	5.0	1.9	-52.6	23.9	-55.5	25.0	-58.3	26.0	-62.0	27.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.4	-24.2	-19.0	-9.8	-1.6	6.6	15.4	18.2	14.2	7.3	-1.4	-14.8	-21.4	(6)
(7)		DBStd	16.22	10.68	8.83	7.53	5.91	5.41	4.96	3.56	3.69	4.37	6.23	10.34	10.74	(7)
(8)		HDD10.0	5162	1061	811	613	347	137	12	0	7	104	354	744	972	(8)
(9)		HDD18.3	7659	1319	1044	872	597	365	111	47	137	331	612	994	1231	(9)
(10)		CDD10.0	622	0	0	0	0	32	175	254	137	23	1	0	0	(10)
(11)		CDD18.3	76	0	0	0	0	1	24	43	8	1	0	0	0	(11)
(12)		CDH23.3	975	0	0	0	0	19	361	492	100	3	0	0	0	(12)
(13)		CDH26.7	276	0	0	0	0	3	108	143	22	0	0	0	0	(13)
(14)	Wind	WSAvg	1.9	1.6	1.9	2.2	2.4	2.3	1.8	1.6	1.6	1.7	2.1	1.9	1.8	(14)
(15)	Precipitation	PrecAvg	531	28	23	22	26	42	63	68	66	65	51	43	37	(15)
(16)		PrecMax	805	62	49	41	59	143	193	130	160	106	92	79	107	(16)
(17)		PrecMin	338	2	10	5	5	18	9	2	13	20	14	27	14	(17)
(18)		PrecStd	105	14	10	10	13	26	34	34	35	23	17	14	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.2	-0.4	8.2	16.0	26.0	32.3	32.6	29.5	23.6	13.3	3.3	-0.5	(19)
(20)			MCWB	-1.6	-1.1	3.3	8.5	15.7	19.0	19.8	19.1	15.1	9.4	2.0	-1.3	(20)
(21)		2%	DB	-4.1	-2.4	4.7	12.6	22.2	29.6	29.9	26.0	20.0	10.8	1.6	-2.5	(21)
(22)			MCWB	-4.7	-3.2	0.7	6.6	13.3	17.9	19.0	17.8	13.6	7.8	0.9	-3.2	(22)
(23)		5%	DB	-6.7	-4.5	2.5	9.7	19.4	27.5	28.1	23.7	17.0	8.4	0.6	-4.3	(23)
(24)			MCWB	-7.3	-5.3	-0.1	5.1	12.1	17.2	18.5	16.7	12.5	6.3	-0.1	-4.9	(24)
(25)		10%	DB	-9.7	-7.1	0.6	7.2	16.3	25.2	26.1	21.4	14.4	6.1	-0.9	-6.7	(25)
(26)			MCWB	-10.2	-7.9	-1.5	3.4	10.1	16.3	17.7	15.7	11.2	4.4	-1.5	-7.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.6	-0.9	3.7	9.4	16.5	21.3	22.5	20.9	16.4	10.2	2.2	-1.1	(27)
(28)			MCDWB	-1.3	-0.4	7.8	13.8	24.8	28.9	28.5	26.4	21.4	12.2	2.6	-0.6	(28)
(29)		2%	WB	-4.6	-3.1	1.5	7.2	14.2	19.4	21.0	18.9	14.4	8.2	1.1	-3.1	(29)
(30)			MCDWB	-4.2	-2.5	3.8	11.7	20.4	26.1	26.7	24.7	18.8	10.3	1.5	-2.6	(30)
(31)		5%	WB	-7.3	-5.3	0.1	5.2	12.6	18.3	19.9	17.5	13.0	6.4	-0.1	-4.8	(31)
(32)			MCDWB	-6.7	-4.5	2.4	8.9	18.3	24.9	25.3	22.0	16.2	8.2	0.5	-4.3	(32)
(33)		10%	WB	-10.2	-7.9	-1.3	3.7	10.6	17.2	18.9	16.3	11.6	4.7	-1.6	-7.3	(33)
(34)			MCDWB	-9.7	-7.1	0.7	6.9	16.0	23.4	24.0	20.4	14.2	6.1	-0.9	-6.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.1	11.6	12.8	10.7	10.2	11.3	11.2	9.7	7.9	6.3	8.5	9.3	(35)
(36)			MCDBR	8.7	9.7	12.8	14.1	15.0	17.1	15.5	14.6	13.1	8.6	5.3	7.5	(36)
(37)			MCWBR	8.7	9.1	10.1	9.5	8.3	7.3	6.6	7.5	7.7	6.2	5.1	7.4	(37)
(38)		5% WB	MCDBR	8.8	9.5	12.0	12.3	13.7	13.5	12.4	11.9	11.3	7.8	5.4	7.5	(38)
(39)			MCWBR	8.7	9.2	9.8	8.9	8.1	6.7	6.5	6.9	7.1	5.9	5.4	7.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.271	0.306	0.343	0.368	0.387	0.399	0.467	0.413	0.360	0.327	0.272	0.252	(40)	
(41)		taud	1.946	1.986	1.978	2.056	2.264	2.340	2.111	2.261	2.375	2.254	2.004	1.893	(41)	
(42)		Ebn at Noon	433	645	752	816	836	831	752	770	755	638	429	289	(42)	
(43)		Edh at Noon	50	86	121	135	119	113	139	111	83	66	45	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.44	1.35	2.79	4.34	4.90	5.55	5.16	3.74	2.23	1.00	0.47	0.22	(44)	
(45)		RadStd	0.05	0.10	0.24	0.44	0.54	0.62	0.45	0.34	0.32	0.14	0.10	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page