

SEVERO-YENISEYSKIY, Russian Federation

WMO: 239860

Lat: 60.3736N

Lon: 93.0172E

Elev: 1678

StdP: 13.83

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.6	-33.3	-44.5	0.4	-38.7	-39.1	0.6	-33.1	17.6	4.7	16.0	4.6	1.8	250	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	81.7	61.3	78.2	60.0	74.7	59.0	64.4	74.5	62.7	73.3	61.1	71.0	5.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.0	85.3	67.5	59.0	79.4	66.6	57.0	73.7	64.8	30.5	74.4	29.2	73.5	28.0	71.2	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	14.0	12.0	-40.1	86.1	7.8	3.4	-45.7	88.6	-50.2	90.6	-54.6	92.5	-60.3	94.9		
(5)			-40.2	68.0	7.8	1.4	-45.8	69.0	-50.3	69.8	-54.7	70.5	-60.3	71.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	-7.9	-1.4	15.0	29.4	39.0	59.0	61.7	55.4	42.2	26.8	3.7	-3.1	(6)
(7)		DBStd	26.63	13.28	12.43	11.24	9.23	9.81	9.31	7.01	7.00	8.91	11.01	14.28	16.12	(7)
(8)		HDD50	9394	1795	1439	1085	618	371	29	6	27	269	721	1389	1645	(8)
(9)		HDD65	14033	2260	1859	1550	1068	806	219	145	308	684	1185	1839	2110	(9)
(10)		CDD50	924	0	0	0	0	30	299	367	193	35	0	0	0	(10)
(11)		CDD65	91	0	0	0	0	0	40	42	9	0	0	0	0	(11)
(12)		CDH74	865	0	0	0	0	0	435	355	72	3	0	0	0	(12)
(13)		CDH80	160	0	0	0	0	0	89	60	11	0	0	0	0	(13)
(14)	Wind	WSAvg	5.6	5.0	5.1	6.5	7.1	6.7	5.0	4.6	4.8	5.3	5.9	5.5	5.0	(14)
(15)	Precipitation	PrecAvg	25.9	1.3	1.3	1.4	1.7	1.9	2.6	2.8	3.2	2.8	3.0	2.1	1.8	(15)
(16)		PrecMax	51.1	3.3	2.6	3.7	4.2	6.4	7.6	8.7	9.0	7.4	6.0	5.6	4.4	(16)
(17)		PrecMin	14.4	0.2	0.4	0.2	0.2	0.4	0.6	0.3	0.9	0.2	1.1	0.9	0.6	(17)
(18)		PrecStd	9.0	0.7	0.6	0.7	0.9	1.2	1.5	2.0	1.8	1.7	1.1	1.0	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.8	26.4	43.4	56.9	70.5	86.4	85.3	81.5	72.4	54.0	33.4	26.8	(19)
MCWB			19.5	25.0	34.9	42.0	50.7	63.1	64.9	62.5	56.1	45.3	32.4	26.1	(20)	
2%		DB	17.3	23.3	38.1	50.2	66.2	82.5	81.4	75.2	65.6	49.1	31.5	23.8	(21)	
		MCWB	16.3	22.0	30.6	39.2	50.8	60.8	61.7	61.1	52.7	43.2	30.5	22.8	(22)	
5%		DB	14.1	19.4	33.3	46.6	61.2	79.2	78.2	71.6	60.3	44.9	29.2	21.3	(23)	
		MCWB	13.1	18.1	28.8	37.5	48.5	59.3	60.9	59.3	51.0	41.0	28.3	20.3	(24)	
10%		DB	11.3	15.4	30.0	42.5	55.4	75.6	74.6	67.2	55.5	41.3	25.2	17.9	(25)	
		MCWB	10.6	14.0	26.6	34.9	45.3	58.0	59.6	57.6	48.3	38.4	24.0	16.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	25.4	36.2	44.7	55.0	66.0	67.5	66.0	57.7	47.1	32.9	25.9	(27)
MCD B			21.0	26.1	42.9	53.4	63.1	79.2	80.0	74.8	67.5	50.8	33.2	26.5	(28)	
2%		WB	16.4	21.9	31.5	40.8	51.8	63.4	64.8	62.8	54.7	44.1	30.6	23.0	(29)	
		MCD B	17.2	23.2	36.2	48.5	63.6	76.4	75.1	72.4	64.2	47.5	31.3	23.7	(30)	
5%		WB	13.2	18.2	29.1	38.1	49.3	61.7	63.4	61.0	51.6	41.4	28.3	20.4	(31)	
		MCD B	14.0	19.3	33.0	44.6	59.8	75.2	72.8	69.3	57.3	44.6	29.2	21.3	(32)	
10%		WB	10.5	14.2	27.0	36.1	45.7	59.7	61.8	58.8	49.2	38.2	24.1	17.0	(33)	
		MCD B	11.3	15.3	30.1	41.4	55.0	72.9	70.7	65.9	55.4	41.3	25.1	17.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.2	12.9	14.9	14.2	15.0	18.3	16.7	15.6	12.0	9.0	11.3	10.6	(35)
MCDBR			12.4	11.4	15.4	17.6	21.2	24.4	22.3	21.1	19.0	13.0	9.4	9.9	(36)	
MCWBR			12.0	10.8	11.2	10.8	11.3	9.7	8.9	9.6	9.6	9.1	9.4	9.6	(37)	
5% WB		MCDBR	12.7	11.6	14.2	15.4	19.6	20.8	17.4	18.8	16.7	11.9	10.4	9.9	(38)	
		MCWBR	12.3	11.2	11.0	10.4	11.3	9.5	8.6	9.6	9.5	8.9	10.4	9.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.246	0.282	0.312	0.342	0.358	0.371	0.415	0.384	0.332	0.299	0.242	0.217	(40)	
taud		1.972	2.032	2.052	2.090	2.308	2.402	2.263	2.328	2.449	2.300	2.021	1.901	(41)		
Ebn at Noon		152	218	252	268	274	272	255	254	252	217	153	110	(42)		
Edh at Noon		15	26	35	41	36	34	38	33	24	20	14	10	(43)		
(44)	All-Sky Solar Radiation	RadAvg	138	431	859	1334	1559	1733	1577	1148	690	312	151	69	(44)	
(45)		RadStd	18	36	79	115	134	211	136	87	110	48	24	13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page