

KISLOKAN, Russian Federation

WMO: 246060

Lat: 63.590N

Lon: 103.950E

Elev: 211

StdP: 98.82

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -50.6	(c) -48.3	(d) -52.6	(e) 0.0	(f) -50.8	(g) -50.2	(h) 0.0	(i) -48.0	(j) 6.2	(k) -15.9	(l) 5.4	(m) -17.0	(n) 0.1	(o) 260	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	29.4	17.6	27.2	16.5	25.0	15.8	18.7	26.5	17.7	25.0	16.6	23.5	2.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	11.6	21.2	14.7	10.7	20.3	13.7	10.0	19.6	54.2	26.3	50.9	24.8	47.6	23.6	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.5	4.9	4.2	-51.7	32.3	2.0	1.4	-53.1	33.4	-54.3	34.2	-55.5	35.0	-57.0	36.0
			-51.7	20.4	2.0	0.8	-53.1	21.0	-54.3	21.5	-55.5	22.0	-57.0	22.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-8.1	-34.4	-28.5	-16.4	-4.5	3.7	13.6	15.9	12.3	4.1	-6.6	-24.7	-33.1
	DBStd	19.28	8.71	8.45	9.09	6.47	4.59	4.00	3.35	3.88	4.31	7.64	10.82	9.46
	HDD10.0	7016	1376	1077	819	435	199	11	2	19	183	516	1042	1336
	HDD18.3	9679	1634	1311	1078	685	453	151	89	192	427	774	1292	1594
	CDD10.0	404	0	0	0	0	5	118	185	90	6	0	0	0
	CDD18.3	26	0	0	0	0	0	7	14	4	0	0	0	0
	CDH23.3	733	0	0	0	0	3	251	383	96	1	0	0	0
	CDH26.7	183	0	0	0	0	0	73	93	16	0	0	0	0
	WSAvg	1.5	0.9	1.1	1.6	2.0	2.1	1.7	1.6	1.5	1.6	1.6	1.2	0.8
Precipitation	PrecAvg	357	12	11	10	17	26	48	58	71	36	28	22	16
	PrecMax	506	23	26	23	52	54	95	149	210	75	50	41	33
	PrecMin	217	5	2	2	4	10	6	12	11	11	7	11	5
	PrecStd	68	5	5	4	10	11	24	38	36	18	11	8	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-9.2	-5.7	6.2	13.8	23.8	32.7	31.2	28.7	21.7	9.8	1.4	-3.6
		MCWB	-10.4	-7.1	1.6	5.6	12.0	17.8	18.6	18.5	13.1	6.1	-0.1	-4.6
	2%	DB	-11.1	-7.9	3.4	10.5	19.8	30.2	29.3	26.1	17.3	7.1	-1.7	-8.1
		MCWB	-11.9	-9.1	-0.2	3.9	9.5	17.0	17.9	16.6	11.0	4.4	-2.6	-8.8
	5%	DB	-15.1	-10.2	0.1	8.0	15.7	27.5	27.3	23.6	14.3	4.8	-4.9	-14.1
		MCWB	-15.7	-11.0	-2.5	2.7	7.7	16.2	16.8	15.3	9.6	2.9	-5.7	-14.6
	10%	DB	-19.6	-14.1	-2.4	5.7	13.2	25.0	25.4	21.2	12.1	2.7	-8.3	-18.4
		MCWB	-20.0	-14.7	-4.6	1.8	6.4	15.4	16.3	14.4	8.2	1.1	-9.0	-18.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.1	-6.9	2.0	5.9	12.2	19.3	20.3	19.4	14.3	6.6	0.2	-4.8
		MCDB	-9.3	-5.9	6.0	12.6	22.7	29.5	27.5	27.1	18.5	9.2	1.3	-3.8
	2%	WB	-12.0	-9.2	-0.2	4.4	10.0	18.2	19.1	17.7	12.1	4.6	-2.5	-8.8
		MCDB	-10.8	-8.3	3.5	9.6	19.2	27.2	26.2	23.9	15.7	6.8	-1.7	-8.1
	5%	WB	-15.6	-11.0	-2.4	3.1	8.3	17.1	18.1	16.2	10.2	3.0	-5.8	-14.5
		MCDB	-15.0	-10.2	0.1	7.6	15.2	26.2	25.1	21.7	13.8	4.6	-5.0	-14.0
	10%	WB	-20.0	-14.7	-4.5	1.9	6.7	15.8	17.2	15.0	8.6	1.2	-8.9	-18.7
		MCDB	-19.7	-14.0	-2.5	5.4	12.1	23.8	23.6	20.1	11.9	2.5	-8.3	-18.4
Mean Daily Temperature Range	5% DB	MDBR	9.3	13.3	17.1	13.7	11.6	14.7	15.0	13.6	11.1	8.9	9.9	8.7
		MCDBR	12.9	11.0	15.5	15.0	17.9	20.3	19.9	18.7	16.5	9.8	9.8	13.3
		MCWBR	12.2	10.3	12.3	9.6	9.9	9.1	9.7	10.0	10.5	7.3	9.2	13.0
	5% WB	MCDBR	13.0	10.9	14.9	12.2	16.5	18.0	16.4	15.5	14.7	9.3	9.2	13.5
		MCWBR	12.2	10.2	12.1	7.9	9.7	8.9	8.6	8.7	9.5	7.2	8.6	13.2
Clear-Sky Solar Irradiance	taub		0.217	0.268	0.301	0.334	0.351	0.377	0.448	0.417	0.330	0.277	0.205	0.198
	taud		1.895	2.021	2.057	2.074	2.271	2.399	2.160	2.217	2.445	2.246	1.919	1.870
	Ebn at Noon		351	634	773	833	858	842	756	744	764	638	361	159
	Edh at Noon		32	70	102	126	114	104	129	111	72	55	29	15
All-Sky Solar Radiation	RadAvg		0.23	1.09	2.75	4.72	5.40	5.63	5.07	3.56	2.19	0.98	0.36	0.09
	RadStd		0.02	0.07	0.16	0.28	0.43	0.58	0.43	0.27	0.24	0.12	0.03	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	+1.04	N/A	N/A	+1.76	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page