

SEGEN-KYUEL', Russian Federation

WMO: 246610

Lat: 64.000N

Lon: 130.300E

Elev: 208

StdP: 98.85

Time Zone: 9.00 (E09)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-50.5	-49.2	-52.2	0.0	-49.9	-50.8	0.0	-49.0	10.2	-19.5	9.2	-16.6	0.1	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	29.0	18.5	27.1	17.8	25.2	16.7	20.1	26.4	18.9	24.8	17.7	23.4	1.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	13.1	22.8	16.7	12.2	21.5	15.5	11.3	20.2	58.9	26.1	54.7	24.7	50.9	23.3	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.0	5.8	-51.9	32.3	1.8	1.6	-53.2	33.5	-54.2	34.4	-55.2	35.3	-56.4	36.5		
(5)			-51.9	22.2	1.8	1.5	-53.2	23.3	-54.2	24.2	-55.2	25.0	-56.4	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.7	-39.7	-34.6	-19.6	-4.1	6.6	15.1	17.7	14.2	5.2	-9.6	-29.8	-39.3
	DBStd	21.95	6.68	6.09	8.09	6.26	4.42	3.82	3.30	3.34	4.29	7.39	8.22	6.63
	HDD10.0	7749	1541	1248	916	424	123	4	1	6	153	609	1194	1529
	HDD18.3	10282	1799	1482	1174	674	363	109	53	133	395	867	1444	1787
	CDD10.0	558	0	0	0	0	18	158	238	136	8	0	0	0
	CDD18.3	49	0	0	0	0	0	13	33	4	0	0	0	0
	CDH23.3	841	0	0	0	0	3	251	502	86	0	0	0	0
	CDH26.7	205	0	0	0	0	0	54	141	10	0	0	0	0
Wind	WSAvg	1.6	0.9	1.1	1.8	2.3	2.1	1.7	1.8	1.6	2.0	1.8	0.9	0.6
Precipitation	PrecAvg	406	9	8	11	15	40	56	75	60	62	44	18	8
	PrecMax	553	23	22	59	49	86	107	176	127	126	86	40	30
	PrecMin	248	3	0	0	3	0	14	22	2	0	2	2	0
	PrecStd	73	5	6	13	11	23	24	40	34	31	22	11	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.4	-15.3	0.6	10.8	22.8	30.3	32.6	28.1	21.1	5.7	-4.7	-10.9
		MCWB	-12.2	-16.1	-2.8	4.1	11.7	18.6	20.7	18.1	14.0	2.0	-5.8	-12.8
	2%	DB	-17.0	-17.4	-2.0	8.6	19.9	28.3	29.9	25.7	17.3	3.4	-10.8	-20.9
		MCWB	-18.1	-18.2	-4.5	3.1	10.4	16.8	19.6	17.0	10.7	0.1	-11.5	-21.3
	5%	DB	-22.5	-19.7	-4.4	6.5	17.1	26.3	28.0	23.7	14.8	1.5	-13.3	-24.6
		MCWB	-23.0	-20.3	-6.5	1.6	9.2	16.4	18.7	16.2	9.2	-1.6	-14.1	-24.8
	10%	DB	-30.4	-23.7	-6.6	4.8	14.8	24.2	26.2	21.7	12.5	-0.2	-16.1	-29.6
		MCWB	-30.6	-24.0	-8.4	0.4	8.2	15.7	18.0	15.1	7.9	-2.3	-16.7	-29.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-12.0	-16.0	-2.4	4.5	12.4	19.8	22.5	20.0	13.7	4.0	-5.6	-12.6
		MCDB	-10.3	-15.2	-0.1	10.1	21.5	26.8	29.8	25.6	20.0	4.7	-5.2	-10.8
	2%	WB	-18.1	-18.2	-4.3	3.3	11.0	18.4	21.0	18.6	11.8	0.2	-11.4	-21.2
		MCDB	-17.0	-17.4	-2.1	8.3	18.3	25.7	28.1	23.5	15.3	2.2	-10.8	-20.8
	5%	WB	-23.1	-20.3	-6.4	2.0	9.9	17.2	19.8	17.4	10.3	-1.1	-14.1	-24.8
		MCDB	-22.6	-19.6	-4.5	5.6	15.9	24.3	26.1	21.9	13.8	1.2	-13.3	-24.5
	10%	WB	-30.6	-24.0	-8.3	0.8	8.6	16.2	18.7	15.9	8.6	-2.4	-16.6	-29.7
		MCDB	-30.4	-23.7	-6.5	4.2	14.0	23.0	24.4	19.6	11.7	-0.4	-16.0	-29.6
Mean Daily Temperature Range	5% DB	MDBR	7.8	13.1	15.3	11.1	10.1	12.6	12.4	12.0	9.6	9.1	9.1	6.6
		MCDBR	14.2	13.9	14.6	10.5	14.5	17.3	17.6	16.4	14.2	8.6	9.7	13.1
		MCWBR	13.5	13.2	12.3	6.6	7.4	7.9	8.5	8.6	8.7	6.3	9.2	12.7
	5% WB	MCDBR	14.0	13.7	14.4	9.1	13.0	15.3	15.5	14.1	13.1	7.6	9.3	13.1
		MCWBR	13.5	13.1	12.2	5.9	6.7	8.1	8.3	8.3	8.5	5.8	8.8	12.7
Clear-Sky Solar Irradiance	taub	0.180	0.240	0.289	0.341	0.400	0.393	0.477	0.446	0.330	0.258	0.183	0.170	
	taud	1.928	2.110	2.087	2.036	2.120	2.324	2.062	2.104	2.418	2.254	1.924	1.896	
	Ebn at Noon	414	687	788	819	802	823	725	707	757	660	383	179	
	Edh at Noon	28	61	98	130	133	111	141	124	73	52	26	12	
All-Sky Solar Radiation	RadAvg	0.21	1.09	2.92	4.95	5.45	5.74	5.20	3.95	2.36	1.11	0.35	0.08	
	RadStd	0.01	0.04	0.14	0.18	0.51	0.39	0.37	0.35	0.29	0.09	0.02	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+0.55	N/A	N/A	N/A	N/A	N/A	N/A	-162	N/A	N/A

Nomenclature: See separate page