

SUSUMAN, Russian FederationWMO: **247900**Lat: **62.783N**Lon: **148.167E**Elev: **2148**StdP: **13.59**Time Zone: **11.00 (E11)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -60.2	(c) -57.9	(d) -67.7	(e) 0.1	(f) -59.4	(g) -64.1	(h) 0.1	(i) -56.8	(j) 21.8	(k) -2.1	(l) 18.6	(m) -3.2	(n) 1.6	(o) 60	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.9	80.6	60.9	76.6	59.1	72.6	57.3	62.7	76.3	60.6	73.2	58.6	69.4	5.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.0	77.9	66.3	55.8	71.7	63.5	53.9	67.0	62.2	29.4	76.2	27.9	73.7	26.5	69.5	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.1	13.8	11.9	-62.5	86.9	2.2	3.9	-64.0	89.7	-65.3	92.0	-66.5	94.2	-68.1	97.1		
			-62.5	65.8	2.2	3.1	-64.0	68.0	-65.3	69.9	-66.5	71.6	-68.1	73.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-32.7	-26.4	-9.4	14.2	38.2	52.8	58.4	51.8	37.5	10.3	-18.2	-30.8		
	DBStd	35.58	17.49	16.48	13.16	11.41	8.26	6.84	6.10	6.75	8.10	12.45	13.93	16.50		
	HDD50	14266	2562	2140	1842	1073	373	47	8	58	379	1232	2046	2506		
	HDD65	19233	3027	2560	2307	1523	831	369	214	412	826	1697	2496	2971		
	CDD50	524	0	0	0	0	6	130	270	114	4	0	0	0		
	CDD65	15	0	0	0	0	0	2	11	2	0	0	0	0		
	CDH74	642	0	0	0	0	1	160	405	76	0	0	0	0		
	CDH80	132	0	0	0	0	0	24	98	10	0	0	0	0		
	CDH80	132	0	0	0	0	0	24	98	10	0	0	0	0		
(14) Wind	WSAvg	4.4	3.5	3.8	4.6	5.1	6.0	5.5	4.8	4.4	4.8	4.0	3.2	3.4		
(15) Precipitation	PrecAvg	11.6	0.4	0.3	0.2	0.3	0.6	1.6	2.4	2.6	1.3	0.8	0.6	0.4		
	PrecMax	16.7	0.8	0.7	0.9	1.3	1.4	2.8	4.9	5.6	3.0	1.9	1.5	1.2		
	PrecMin	8.1	0.1	0.0	0.0	0.0	0.1	0.5	0.8	0.6	0.2	0.3	0.1	0.1		
	PrecStd	2.0	0.2	0.2	0.2	0.3	0.3	0.6	1.1	1.3	0.8	0.3	0.4	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.3	21.6	22.5	43.4	69.3	83.3	87.3	80.9	67.6	37.5	18.9	18.7		
		MCWB	16.2	19.8	18.2	34.9	52.7	59.0	65.4	62.4	52.0	32.7	16.7	17.7		
	2%	DB	5.8	9.9	19.3	39.5	64.0	78.3	82.7	75.4	61.5	33.4	12.7	5.9		
		MCWB	4.7	9.1	15.9	32.6	48.1	58.0	62.4	59.9	49.0	29.6	11.1	4.7		
	5%	DB	0.7	3.8	16.0	36.1	59.7	74.5	78.6	71.1	56.4	30.4	9.2	1.1		
		MCWB	-0.2	2.6	13.3	30.6	46.2	55.8	60.6	57.4	47.2	27.0	8.0	-0.1		
	10%	DB	-5.1	-1.2	12.0	32.8	54.6	69.9	74.6	67.2	51.7	27.5	4.2	-4.0		
		MCWB	-5.8	-2.3	9.8	27.9	43.3	53.8	59.1	55.9	44.6	24.8	3.2	-4.9		
	0.4%	WB	15.7	20.2	18.6	36.1	53.2	61.5	68.4	65.5	53.1	33.3	16.7	17.4		
		MCDB	16.5	22.6	22.3	41.2	69.1	78.6	82.3	75.3	64.2	37.2	18.6	18.6		
	2%	WB	4.8	8.4	16.0	33.2	49.3	58.6	64.0	61.0	50.7	29.9	11.2	4.8		
		MCDB	5.8	9.2	19.2	38.8	62.0	73.7	77.9	72.7	58.5	33.0	12.5	5.6		
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	-0.4	2.4	13.4	30.7	46.8	57.0	61.9	58.8	48.2	27.2	7.9	0.0		
		MCDB	0.7	3.4	15.9	35.6	57.8	71.8	75.3	68.7	55.7	30.0	9.0	1.1		
	10%	WB	-5.8	-2.5	9.8	28.1	44.2	55.1	60.2	56.9	45.3	24.8	3.2	-4.7		
		MCDB	-5.0	-1.5	11.8	32.3	53.7	67.8	72.0	65.2	51.2	27.3	4.1	-3.8		
	5% DB	MDBR	14.7	19.4	28.1	25.4	21.4	23.8	23.9	23.1	18.8	18.3	15.1	13.9		
		MCDBR	18.0	15.3	29.3	25.9	31.4	35.3	35.7	33.6	29.7	18.6	18.4	19.9		
(36) Mean Daily Temperature Range	5% WB	MCWBR	17.0	14.8	26.2	19.5	17.4	16.0	16.7	18.6	17.6	14.6	17.5	18.3		
		MCDBR	17.9	15.6	28.8	23.7	28.0	31.3	30.4	29.1	27.2	17.7	18.3	19.4		
	5% WB	MCWBR	17.2	14.9	25.8	18.0	15.9	15.1	14.9	16.8	16.5	14.1	17.4	18.7		
		MCDBR	17.2	14.9	25.8	18.0	15.9	15.1	14.9	16.8	16.5	14.1	17.4	18.7		
(40) Clear-Sky Solar Irradiance	taub		0.179	0.236	0.286	0.353	0.380	0.364	0.417	0.396	0.306	0.260	0.188	0.160		
	taud		2.002	2.138	2.073	1.928	2.084	2.383	2.243	2.265	2.465	2.231	1.987	1.907		
	Ebn at Noon		162	231	255	257	262	272	251	245	255	216	148	97		
	Edh at Noon		10	20	32	47	44	34	38	34	23	18	10	5		
(44) All-Sky Solar Radiation	RadAvg		83	366	967	1649	1853	1696	1582	1171	755	419	140	36		
	RadStd		8	27	39	61	123	160	161	108	102	54	13	3		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page