

SUSUMAN, Russian Federation

WMO: 247900

Lat: 62.783N

Lon: 148.167E

Elev: 655

StdP: 93.70

Time Zone: 11.00 (E11)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -51.2	(c) -49.9	(d) -55.4	(e) 0.0	(f) -50.8	(g) -53.4	(h) 0.0	(i) -49.3	(j) 9.8	(k) -18.9	(l) 8.3	(m) -19.6	(n) 0.7	(o) 60	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	27.0	16.1	24.8	15.1	22.6	14.1	17.1	24.6	15.9	22.9	14.8	20.8	2.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	11.1	19.1	13.2	10.2	17.5	12.2	9.6	16.8	50.4	24.6	46.9	23.2	43.7	20.8	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.2	(b) 6.2	(c) 5.3	(e) -52.5	(f) 30.5	(g) 1.2	(h) 2.2	(i) -53.3	(j) 32.1	(k) -54.1	(l) 33.3	(m) -54.7	(n) 34.6	(o) -55.6	(p) 36.2		
			DB													
			WB													
				-52.5	18.8	1.2	1.7	-53.3	20.0	-54.1	21.0	-54.7	22.0	-55.6	23.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.9	-35.9	-32.5	-23.0	-9.9	3.4	11.5	14.7	11.0	3.0	-12.1	-27.9	-34.9
	DBStd	19.76	9.72	9.16	7.31	6.34	4.59	3.80	3.39	3.75	4.50	6.91	7.74	9.17
	HDD10.0	7926	1423	1189	1023	596	207	26	4	32	211	684	1137	1392
	HDD18.3	10685	1682	1422	1282	846	462	205	119	229	459	943	1387	1651
	CDD10.0	291	0	0	0	0	3	72	150	63	2	0	0	0
	CDD18.3	8	0	0	0	0	0	1	6	1	0	0	0	0
	CDH23.3	357	0	0	0	0	1	89	225	42	0	0	0	0
	CDH26.7	73	0	0	0	0	0	13	54	6	0	0	0	0
(14) Wind	WSAvg	2.0	1.6	1.7	2.0	2.3	2.7	2.5	2.1	2.0	2.1	1.8	1.4	1.5
(15) Precipitation	PrecAvg	294	9	8	6	8	15	41	61	66	34	21	16	10
	PrecMax	425	21	18	23	33	35	70	125	143	76	47	39	30
	PrecMin	205	2	1	0	1	2	13	20	15	6	8	3	2
	PrecStd	52	5	4	4	7	8	15	28	32	20	8	9	6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-8.2	-5.8	-5.3	6.3	20.7	28.5	30.7	27.2	19.8	3.1	-7.3	-7.4
		MCWB	-8.8	-6.8	-7.7	1.6	11.5	15.0	18.6	16.9	11.1	0.4	-8.5	-7.9
	2%	DB	-14.5	-12.3	-7.1	4.2	17.8	25.7	28.1	24.1	16.4	0.8	-10.7	-14.5
		MCWB	-15.2	-12.7	-8.9	0.3	9.0	14.4	16.9	15.5	9.4	-1.3	-11.6	-15.2
	5%	DB	-17.4	-15.7	-8.9	2.3	15.4	23.6	25.9	21.7	13.6	-0.9	-12.7	-17.2
		MCWB	-17.9	-16.3	-10.4	-0.8	7.9	13.2	15.9	14.1	8.4	-2.8	-13.3	-17.8
	10%	DB	-20.6	-18.5	-11.1	0.5	12.6	21.1	23.7	19.6	11.0	-2.5	-15.5	-20.0
		MCWB	-21.0	-19.1	-12.3	-2.3	6.3	12.1	15.1	13.3	7.0	-4.0	-16.0	-20.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-9.0	-6.6	-7.5	2.3	11.8	16.4	20.2	18.6	11.7	0.7	-8.5	-8.1
		MCDB	-8.6	-5.2	-5.4	5.1	20.6	25.9	27.9	24.0	17.9	2.9	-7.4	-7.5
	2%	WB	-15.1	-13.1	-8.9	0.7	9.6	14.8	17.8	16.1	10.4	-1.1	-11.5	-15.1
		MCDB	-14.6	-12.6	-7.1	3.8	16.7	23.1	25.5	22.6	14.7	0.6	-10.8	-14.7
	5%	WB	-18.0	-16.4	-10.3	-0.7	8.2	13.9	16.6	14.9	9.0	-2.7	-13.4	-17.8
		MCDB	-17.4	-15.9	-8.9	2.0	14.3	22.1	24.1	20.4	13.2	-1.1	-12.8	-17.2
	10%	WB	-21.0	-19.2	-12.3	-2.2	6.8	12.8	15.6	13.8	7.4	-4.0	-16.0	-20.4
		MCDB	-20.5	-18.6	-11.2	0.2	12.1	19.9	22.2	18.5	10.6	-2.6	-15.5	-19.9
(35) Mean Daily Temperature Range	MDBR		8.2	10.8	15.6	14.1	11.9	13.2	13.3	12.8	10.4	10.2	8.4	7.7
	5% DB	MCDBR	10.0	8.5	16.3	14.4	17.5	19.6	19.8	18.7	16.5	10.3	10.2	11.1
		MCWBR	9.5	8.2	14.6	10.8	9.6	8.9	9.3	10.3	9.8	8.1	9.7	10.2
	5% WB	MCDBR	9.9	8.7	16.0	13.1	15.5	17.4	16.9	16.1	15.1	9.8	10.1	10.8
		MCWBR	9.6	8.3	14.3	10.0	8.9	8.4	8.3	9.3	9.2	7.8	9.7	10.4
(40) Clear-Sky Solar Irradiance	taub		0.179	0.236	0.286	0.353	0.380	0.364	0.417	0.396	0.306	0.260	0.188	0.160
	taud		2.002	2.138	2.073	1.928	2.084	2.383	2.243	2.265	2.465	2.231	1.987	1.907
	Ebn at Noon		511	728	805	809	826	858	791	772	804	681	465	305
	Edh at Noon		31	64	102	148	139	106	119	107	71	57	31	17
(44) All-Sky Solar Radiation	RadAvg		0.26	1.16	3.05	5.20	5.84	5.35	4.99	3.69	2.38	1.32	0.44	0.12
	RadStd		0.03	0.08	0.12	0.19	0.39	0.50	0.51	0.34	0.32	0.17	0.04	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page