

OKHOTSKIY-PEREVOZ, Russian Federation

WMO: 248710

Lat: 61.877N

Lon: 135.529E

Elev: 461

StdP: 14.45

Time Zone: 9.00 (E09)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-63.7	-60.0	-66.7	0.1	-62.8	-63.0	0.1	-60.0	7.3	-15.9	6.4	-23.4	0.2	170	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	82.6	65.0	79.3	63.6	75.7	62.3	67.6	77.8	65.7	75.2	64.0	73.1	5.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	92.0	71.3	62.3	85.5	69.4	60.4	79.8	67.7	32.4	78.0	30.9	75.0	29.6	73.6	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.1	8.7	DB	-63.3	89.0	5.0	2.2	-66.9	90.6	-69.9	91.9	-72.7	93.2	-76.3	94.8	(4)
(5)			WB	-63.4	71.0	4.8	2.3	-66.9	72.7	-69.6	74.0	-72.3	75.3	-75.8	77.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	-43.1	-33.9	-5.7	22.3	44.3	59.0	64.3	58.8	42.3	17.2	-19.6	-38.4	(6)	
(7)		DBStd	40.37	11.53	11.01	14.78	11.28	7.89	6.17	6.40	6.00	7.67	12.80	14.72	13.26	(7)	
(8)		HDD50	14107	2885	2348	1727	832	207	6	1	7	250	1017	2087	2740	(8)	
(9)		HDD65	18627	3350	2768	2192	1282	641	193	90	206	681	1482	2537	3205	(9)	
(10)		CDD50	1053	0	0	0	0	31	278	446	279	19	0	0	0	(10)	
(11)		CDD65	97	0	0	0	0	0	14	70	13	0	0	0	0	(11)	
(12)		CDH74	1070	0	0	0	0	10	217	694	149	0	0	0	0	(12)	
(13)		CDH80	227	0	0	0	0	1	32	177	17	0	0	0	0	(13)	
(14)	Wind	WSAvg	3.3	1.4	1.8	3.2	4.4	5.1	4.5	4.0	3.7	4.0	3.7	2.3	1.6	(14)	
(15)	Precipitation	PrecAvg	16.0	0.5	0.3	0.4	0.7	1.5	1.9	2.8	2.5	2.2	1.6	1.0	0.4	(15)	
(16)		PrecMax	21.7	1.3	0.8	2.2	2.6	2.6	3.7	5.1	5.0	4.4	4.1	3.7	1.5	(16)	
(17)		PrecMin	11.5	0.1	0.1	0.0	0.1	0.5	0.7	1.2	0.9	0.7	0.6	0.1	0.1	(17)	
(18)		PrecStd	2.6	0.3	0.2	0.4	0.5	0.6	0.6	1.1	0.9	1.0	0.7	0.7	0.3	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.4	4.5	36.1	53.1	74.0	84.6	88.8	82.1	69.7	45.1	31.2	7.9	(19)	
(20)		MCWB	-0.2	3.8	30.6	39.8	52.4	64.4	68.0	65.3	55.9	39.7	30.2	7.0	7.0	(20)	
(21)		2%	DB	-13.5	-5.2	30.9	47.5	67.7	80.0	84.6	78.4	63.7	40.5	17.4	-1.0	(21)	
(22)		MCWB	-14.1	-5.7	26.3	36.5	49.1	61.5	66.4	64.1	52.7	36.6	16.4	-1.5	-1.5	(22)	
(23)		5%	DB	-20.6	-11.9	26.8	43.5	63.2	76.6	81.3	74.3	58.9	36.9	9.2	-11.9	(23)	
(24)		MCWB	-20.9	-12.5	23.1	34.4	47.9	60.0	65.0	63.3	50.3	33.4	8.4	-12.2	-12.2	(24)	
(25)		10%	DB	-26.6	-17.1	21.5	40.3	59.1	73.0	77.7	70.5	55.2	33.7	0.8	-19.8	(25)	
(26)		MCWB	-26.8	-17.5	18.5	32.5	45.9	58.4	64.2	60.7	48.5	31.4	0.3	-20.1	-20.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.2	3.8	31.3	40.2	54.6	66.5	71.4	68.9	57.3	40.2	30.5	7.1	(27)	
(28)		MDCB	0.2	4.6	35.7	51.4	71.2	79.2	83.4	76.5	65.0	43.6	31.3	7.5	7.5	(28)	
(29)		2%	WB	-13.7	-5.8	26.7	37.0	50.7	64.1	68.7	66.4	54.5	37.0	16.7	-1.3	(29)	
(30)		MDCB	-13.4	-5.4	30.3	45.5	63.4	76.6	79.9	74.5	61.1	39.7	17.2	-0.6	-0.6	(30)	
(31)		5%	WB	-20.8	-12.3	23.0	34.9	48.8	62.1	66.9	64.0	52.0	34.2	8.4	-12.3	(31)	
(32)		MDCB	-20.5	-11.9	26.9	42.8	60.1	72.7	77.1	71.5	57.5	36.4	9.1	-12.1	-12.1	(32)	
(33)		10%	WB	-26.7	-17.4	18.4	32.8	47.0	60.1	65.3	62.2	49.5	31.2	0.3	-20.0	(33)	
(34)		MDCB	-26.6	-17.1	21.6	39.4	57.2	70.0	74.8	69.0	54.4	33.6	0.8	-19.7	-19.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.5	20.0	31.1	26.6	20.1	21.2	19.8	20.1	18.4	13.7	14.3	10.9	10.9	(35)	
(36)		5% DB	MCDBR	18.4	24.2	28.0	24.8	29.2	28.2	26.8	25.4	25.6	14.6	18.0	20.7	20.7	(36)
(37)		MCWBR	18.1	23.6	23.8	15.7	14.0	12.4	11.3	12.8	15.6	10.4	17.6	20.2	20.2	(37)	
(38)		5% WB	MCDBR	18.3	23.9	26.7	21.7	23.6	24.4	22.0	21.9	20.7	12.9	18.1	21.0	21.0	(38)
(39)		MCWBR	18.0	23.5	22.8	14.1	11.8	12.0	10.3	12.1	13.5	9.7	17.7	20.4	20.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.204	0.253	0.302	0.371	0.426	0.414	0.508	0.437	0.346	0.284	0.215	0.173	0.173	(40)	
(41)		taud	1.995	2.097	2.059	1.983	2.109	2.273	1.983	2.169	2.397	2.278	1.993	1.896	1.896	(41)	
(42)		Ebn at Noon	158	226	252	253	250	257	224	233	240	213	145	108	108	(42)	
(43)		Edh at Noon	12	22	34	45	44	38	49	38	25	19	11	7	7	(43)	
(44)	All-Sky Solar Radiation	RadAvg	121	440	989	1577	1653	1852	1697	1324	785	377	166	58	58	(44)	
(45)		RadStd	6	17	35	64	121	123	93	104	89	30	14	3	3	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+1.04	+1.78	N/A	N/A	N/A	N/A	-356	-373	N/A	N/A

Nomenclature: See separate page